SPILL PREVENTION CONTROL AND COUNTERMEASURE (SPCC) PLAN

Prepared for

The University of Connecticut
Storrs Campus
Storrs, Connecticut

Prepared by

CDM Smith

77 Hartland Street, Suite 201
East Hartford, Connecticut
(860) 529-7615
www.cdmsmith.com

Original Date of Plan: 2002

Date of Last Amendment/P.E. Certification: 2015

Date of Last Plan Review: 2015

July 2021 Amended September 2022

SPILL PREVENTION, CONTROL, AND COUNTERMEASURE PLAN THE UNIVERSITY OF CONNECTICUT, STORRS CAMPUS FACILITY INFORMATION

1.	Name	of Facility:	The University of Connecticut, Storrs Campus	1,
2.	Type o	f Facility:	State University	-
3.	Locatio	on of Facilit	y: Storrs, Connecticut 06269	-
4.	Name	and Addres	s of Owner or Operator:	
		<u>G</u> 3!	ne University of Connecticut ulley Hall 52 Mansfield Road, Unit 2086 corrs, CT 06269-2086	•
5.	Design	,	ns accountable for oil spill prevention at the facility:	;
	Name:	Stanley N	olan	
	Title:	Executive	Director of Energy and Building Trades	
	Name:	Michael G	Sorman (
	Title:	Associate	Director of Trade Services	
FACILIT	Y MANA	AGEMENT A	APPROVAL (40 CFR 112.7)	
approva	al of the	managem	t this Spill Prevention, Control and Countermeasure ent of The University of Connecticut, Storrs Campus a curces to fully implement the Plan.	
		Signature:	Mich for	
		Name:	P. Michael Jednak	
		Title:	AVP Facilities Operations and Building Services	
		Date:	11-15-22	

SPILL PREVENTION, CONTROL, AND COUNTERMEASURE PLAN THE UNIVERSITY OF CONNECTICUT, STORRS CAMPUS


Certification of the Inapplicability of the Substantial Harm Criteria

(Attachment C-II to 40 CFR 112 Appendix C)

	ility Nam		The U Storrs	4500000 IV	of Connecticut, Storrs Campus
1.	Does t	he facilit	y transfei	r oil over	water to or from vessels and does the facility have a total oil storage 2,000 gallons?
	Yes		No	X	
2.	facility la abovegr	ack secon	dary constorage to	tainment	torage capacity greater than or equal to 1 million gallons <u>and</u> does the that is sufficiently large to contain the capacity of the largest ufficient freeboard to allow for precipitation within any aboveground oil
	Yes		No	X	
3.	facility lo appendix wildlife a see Appe Wildlife	ocated at x or a cor and sensi endices I, and Sens	a distand nparable tive envir II, and III	te (as calce formula ¹) conments to DOC/I ronments	torage capacity greater than or equal to 1 million gallons <u>and</u> is the culated using the appropriate formula in Attachment C-III to this) such that a discharge from the facility could cause injury to fish and ? For further description of fish and wildlife and sensitive environments, NOAA's "Guidance for Facility and Vessel Response Plans: Fish and 5" (see Appendix E to this part, section 13, for availability) and the
	Yes		No	X	
4.	facility lo	cated at x or a cor	a distanc nparable	e (as calc	corage capacity greater than or equal to 1 million gallons <u>and</u> is the ulated using the appropriate formula in Attachment C-III to this) such that a discharge from the facility would shut down a public
			formula is		cumentation of the reliability and analytical soundness of the comparable
	² For th described			R part 112	, public drinking water intakes are analogous to public water systems as
	Yes		No	X	
5.		xperience			corage capacity greater than or equal to 1 million gallons and has the discharge in an amount greater than or equal to 10,000 gallons within
	Yes		No	X	
					CERTIFICATION
his do	ocument,	and that	based or	n my inqui	ersonally examined and am familiar with the information submitted in iry of those individuals responsible for obtaining this information, I rue, accurate, and complete.
Name	: <u>P. N</u>	lichael Je	dnak		Signature: 11-13-22
Γitle:	AVP F	acilities (Operation	ns and Bu	ilding Svcs Date: //-/35-22

SPILL PREVENTION, CONTROL, AND COUNTERMEASURE PLAN THE UNIVERSITY OF CONNECTICUT, STORRS CAMPUS PROFESSIONAL ENGINEER CERTIFICATION (40 CFR 112.3(d))

- 1. By means of this certification the Professional Engineer attests:
 - I. That he/she is familiar with the requirements for this part;
 - II. That he/she or his/her agent has visited and examined the facility;
 - III. That the Plan has been prepared in good accordance with good engineering practice, including consideration of applicable industry standards, and with the requirements of this part;
 - IV. That procedures for required inspections and testing have been established; and
 - V. That the Plan is adequate for the facility.
- 2. Such certification shall in no way relieve the owner or operator of a facility of his/her duty to prepare and fully implement such Plan in accordance with the requirements of this part.



Tamara Burke Devine, PE	
Printed Name of Registered	
Professional Engineer	
Pane BADa	
Signature of Registered Professional Engineer	
Date: November 8, 2022	Facility: <u>University of Connecticut</u> <u>Storrs Campus</u>
Registration No. <u>18944</u>	Location: Storrs, Connecticut 06269
State: Connecticut	Date of Plan: <u>September 2022</u>

SPILL PREVENTION, CONTROL, AND COUNTERMEASURE PLAN REVIEW DOCUMENTATION FORM

THE UNIVERSITY OF CONNECTICUT, STORRS CAMPUS (PER 40 CFR Section 112.5(b), THE SPCC PLAN MUST BE REVIEWED AT LEAST EVERY 5 YEARS)

NAME CERTIFICATION DATE

Jason Coite, Environmental Compliance Manager	I have completed review and evaluation of the SPCC Plan for The University of Connecticut, Storrs Campus onand will amend* the Plan as a result.	April 2015
Jennifer Williams, EHS Specialist	I have completed review and evaluation of the SPCC Plan for The University of Connecticut, Storrs Campus in July 2021 and will amend* the Plan as a result. SIGNATURE/TITLE	11/18/2021
Jennifer Williams, EHS Specialist	I have completed review and evaluation of the SPCC Plan for The University of Connecticut, Storrs Campus on November 2022 and will (will not) amend* the Plan as a result. SIGNATURE/TITLE	11/09/2022
	I have completed review and evaluation of the SPCC Plan for The University of Connecticut, Storrs Campus onand will (will not) amend* the Plan as a result. SIGNATURE/TITLE	
	I have completed review and evaluation of the SPCC Plan for The University of Connecticut, Storrs Campus onand will (will not) amend* the Plan as a result. SIGNATURE/TITLE	

^{*}A PROFESSIONAL ENGINEER MUST CERTIFY TECHNICAL AMENDMENTS TO THE PLAN. PE CERTIFICATION IS NOT REQUIRED FOR NON-TECHNICAL AMENDMENTS SUCH AS CHANGES TO PHONE NUMBERS, NAMES, ETC.

SPILL PREVENTION, CONTROL, AND COUNTERMEASURE PLAN THE UNIVERSITY OF CONNECTICUT, STORRS CAMPUS SPCC PLAN CROSS REFERENCE TABLE

Final SPCC Rule Description of Section		Plan Section(s)	
§ 112.7 General requiren	I		
§ 112.7 Facility management approval and commitment		Page i	
§ 112.7(a)	General requirements; discussion of facility's conformance with rule requirements	1.1, 1.2	
§ 112.7(a)(3)	Description of facility physical layout and facility diagram	2.1	
§ 112.7(a)(3)(i)	Oil storage containers	3.1-3.5	
§ 112.7(a)(3)(ii)	Discharge prevention measures; loading/unloading facility transfers	3.1-3.5, 5.2, 5.3, 5.4	
§ 112.7(a)(3)(iii)	Discharge and drainage controls	3.1-3.5	
§ 112.7(a)(3)(iv)	Countermeasures for discharge discovery, response and cleanup, disposal of recovered materials. Contact list and phone numbers.	7.0	
§ 112.7(b)	Potential discharge volume	3.1-3.5	
§ 112.7(c)	Secondary containment	3.1-3.5	
§ 112.7(d)	Contingency planning	7.0	
§ 112.7(e)	Inspections, tests, and records	4.0, 4.1	
§ 112.7(f)	Personnel training	6.0	
§ 112.7(g)	Security	4.2	
§ 112.7(a)(3)(ii)	Transfer Areas	5.2	
§ 112.7(h)	Tank Truck Loading/unloading Rack	5.1/Not Applicable	
§ 112.7(i)	Brittle fracture evaluation requirements	Not Applicable	
§ 112.7(j)	Conformance with State requirements	Not Applicable	
§ 112.8 and § 112.12 Req	uirements for onshore facilities.		
§ 112.8(b) and § 112.12(b)	Facility drainage	2.3	
§ 112.8(c) and § 112.12(c)	Bulk storage containers	3.1-3.5	
§ 112.8(d) and § 112.12(d)	Facility transfer operations, pumping, and facility process	5.3	

TABLE OF CONTENTS

Facilit	ry Information and Management Approval	i
Certifi	ication of the Inapplicability of the Substantial Harm Criteria	ii
Profes	ssional Engineer Certification	iii
	Plan Review Documentation Form	
	Plan Cross Reference Table	
JI CC	rian cross hererence rable	v
SECTI(<u>on</u>	<u>PAGE</u>
1.0	INTRODUCTION	1
1.1		
1.2		
1.3	Scope	2
1.4	Applicability	3
1.5	PLAN REVIEW AND AMENDMENT PROCEDURES	4
1.6	Plan Distribution	4
1.7	Policy Statement	5
2.0	GENERAL SITE INFORMATION	1
2.1	CAMPUS DESCRIPTION (40 CFR 112.7(A))	1
2.2	OIL STORAGE (40 CFR 112.7(A)(3)(I))	1
2.3	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	
3.0	SPILL PREDICTION, PREVENTION, CONTROL, & COUNTERMEASURES	4
3.1	,	
	JST-3, Mansfield Apartment Lift Station Emergency Generator	
	JST-10, Beach Hall Emergency Generator	
	JST-13, Biobehavioral #4 Annex Building Emergency Generator	
	JST-14, Commissary Warehouse Emergency Generator	
	JST-15, Dodd Research Center	
	JST-16, Eastwood Road Lift Station Emergency Generator	
	JST-18, Fenton River Well Field Pump Station Emergency Generator	
	JST-20, UST-21, UST-22, UST-23, UST-24, UST-25, Central Utility Plant	
	JST-28, Motor Pool	
	JST-29, Motor Pool	
	JST-32, Northwood Apartment Lift Station Emergency Generator	
	JST-35, Plant Science Research and Education Facility	
	JST-36, Plant Science Research and Education Facility	
	JST-39, Psychology Building	
	JST-40, Spring Hill Isolation Farm	
	JST-41, Spring Hill Isolation Farm	
	JST-45, WPCF Poilor	
	JST-46, WPCF Boiler JST-52, Supplemental Utility Plant	
3.2		
_	ST-35, Portable Emergency Generator (Taylor)	
	ST-36, Engineering #1 Castleman Building	
	ST-38, Gampel Pavilion Emergency Generator	

	AST-46, IMS/Gant Building Emergency Generator Day Tank	32
	AST-47, IMS-Physics Loading Dock Emergency Generator	33
	AST-48, Jorgensen Emergency Generator	34
	AST-50, Motor Pool	35
	AST-51, Motor Pool	36
	AST-53, Psychology Day Tank	37
	AST-55, Mink Barn	
	AST-56, South Campus Chiller Plant Emergency Generator	
	AST-57, Plant Science Research and Education Facility	
	AST-59, Plant Science Research and Education Facility	
	AST-63, Putnam Refectory Dining Facility	
	AST-64, Student Union Dining Facility (The Bistro)	
	AST-65, North (McConaughy) Dining Facility	
	AST-66, Whitney Dining Facility	
	AST-67, Gelfenbien (Towers) Dining Facility	
	AST-68, Northwest Dining Facility	
	AST-69, Shippee Dining Facility	
	AST-70, Buckley Dining Facility	
	AST-72, McMahon Dining Facility	
	AST-73, South Campus Dining Facility	
	AST-76, WPCF Headworks Building Emergency Generator Day Tank	
	AST-77, North Parking Garage Emergency Generator	
	AST-80, AST-81, AST-82, Central Utility Plant Day Tanks #1, #2, #3	
	AST-124, Student Union – Union Street Market (USM)	
	AST-126, Portable Emergency Generator (Electric Mobile)	
	AST-127, Motor Pool	
	AST-130, Public Safety Building Emergency Generator	
	AST-131, Reclaimed Water Facility Emergency Generator	
	AST-132, Willimantic Well Field Emergency Generator	
	AST-133, Nextel Radio Towers Emergency Generator	
	AST-134, Infirmary Portable Emergency Generator	
	AST-135, Student Recreational Center/Fieldhouse Fire Pump	
	AST-138, Student Union (Earth Wok & Fire)	
	AST-139, Student Union (One Plate, Two Plates)	
	AST-140, Edwards Freitas Ice Forum (Ice Rink), Fire Pump	
	AST-142, Motor Pool	
	AST-142, Motor Pool	
	AST 14F, Isolation Farm Emergency Consister	
	AST 147, Curlouville Lift Station Emergency Congretor	
	AST 148, William tic Wallfield Emergency Congretor Day Tank	
	AST 140. Makila Surply Fuel Truck	
	AST 150 and AST 151. Symplemental Hitility Plant Day Tanks	
	AST-150 and AST-151, Supplemental Utility Plant Day Tanks	
	AST-152, Farm Services Fuel Tank	
	AST-153, Hockey Arena Emergency Generator	
_	AST-154, Public Safety Building Emergency Generator	
3.	3 DRUMS	
	D-1, Motor Pool	/9

D-2	2, WPCF Sludge Pump Building and Garage	80
D-3	3, WPCF SHT Building	81
D-4	1, Planning Design and Construction Warehouse	82
D-5	5, Farm Services	83
D-6	5, Plant Services Laboratory Area	84
	7, Plant Services Workshop Area	
3.4	Transformers	86
3.5	ELEVATOR TANKS	90
3.6	Spill History	93
4.0 I	NSPECTIONS AND SECURITY	93
4.1	INSPECTIONS, TESTS, AND RECORDS (40 CFR 112.7(E))	93
Un	derground Storage Tanks (USTs)	
Abo	oveground Storage Tanks (ASTs)	95
	oveground Tank Periodic Integrity Testing	
	um Storage	
	nsformers	
Ele	vators	97
4.2	SECURITY (40 CFR 112.7(G))	97
5.0	OIL HANDLING PROCEDURES	
5.1	TANK CAR/TRUCK LOADING/UNLOADING RACK (40 CFR 112.7(H)	98
5.2	TANK TRUCK LOADING/UNLOADING (40 CFR 112.7(A)(3)(II))	98
5.3	FACILITY TRANSFER OPERATIONS PUMPING AND FACILITY PROCESS (40 CFR 112.8(d) AND 112.	
5.4	Drum Loading/Unloading	101
6.0 F	PERSONNEL TRAINING (40 CFR 112.2(F))	
7.0 S	SPILL RESPONSE (40 CFR 112.7(A))	104
7.1	Overview	104
7.2	REPORTING A DISCHARGE	104
7.3	SPILL CONTROL EQUIPMENT	105
7.4	CONTROL RELEASE OF OIL	105
7.5	EMERGENCY RESPONSE	106
7.6	DISPOSAL OF CLEAN-UP MATERIAL	106
7.7	DISCHARGE NOTIFICATION	106
Fed	deral Spill Reporting	106
Cor	nnecticut DEEP Spill Reporting	108

FIGURES

1	Site Location Map	End of Plan
2	Storrs Campus Overview Map	End of Plan
2-1 to 2-53	Storrs Campus SPCC Site Plans	End of Plan

APPENDICES

Α	Monthly Oil Storage Inspection Checklists
В	Example SPCC Personnel Training Log
С	UConn Emergency Spill Procedural Flow Diagram
D	UConn Spill Contractor Contact List
Е	UConn Spill History Log
F	Discharge Notification Forms

1.0 INTRODUCTION

1.1 Purpose

This plan has been developed to provide a framework for the University's management of stored oil and its response to an uncontrolled release of oil that may have an impact on the environment.

1.2 Background

The Federal Water Pollution Control Act, as amended by the Clean Water Act of 1977 (CWA), authorized the establishment of methods, procedures, equipment and other requirements for the prevention and containment of discharges of oil and hazardous substances from vessels and onshore and offshore facilities. The US Environmental Protection Agency's (EPA) Oil Pollution Prevention regulations, developed because of the CWA, are contained within Title 40 of the Federal Code of Regulations (CFR) Part 112. The regulations state that facilities that have oil storage of more than 1,320 gallons aboveground or 42,000 gallons underground are required to put a Spill Prevention Control and Countermeasure (SPCC) Plan in place to prevent and/or mitigate discharges of oil to navigable waters and adjoining shorelines.

The SPCC rule was first promulgated in 1973 (effective January 1974) with significant amendments made to 40 CFR 112 in a final rule issued on July 17, 2002. A number of changes and clarifications to regulations were made, including but not limited to: exempting underground storage tanks (UST) from the 42,000-gallon threshold if the tanks are in compliance with 40 CFR 280; eliminating the threshold for a single 660-gallon aboveground tank (AST); only counting containers with a capacity of 55-gallons or greater when determining the total storage capacity; changing the required testing and inspection requirements; and reducing the plan review frequency from every three to every five years.

Since EPA issued the final SPCC rule in July 2002, EPA has made several other amendments including the December 2006, December 2008 and November 2009 final rules, to address a number of issues raised in the July 2002 final rule. These revisions included: modified requirements for facilities with smaller oil storage capacity, qualified oil-filled operational equipment and mobile refuelers; exemptions for specific oil containers and types of oil; tailored requirements to specific industry sectors (e.g. farms, oil production facilities) and to streamline certain requirements. The effective date of the December 5, 2008 and November 13, 2009 final rules is January 14, 2010 with a compliance date of November 10, 2010, which was ultimately extended to November 10, 2011.

Regulations governing the preparation of an SPCC Plan (40 CFR 112.7) require that specific information be included to demonstrate that the facility is in compliance with the established standards and meets the intent of the regulation to minimize the harmful effects of oil upon navigable waters.

The term "oil" is defined at 40 CFR 112.2 and Section 311(a)(1) of the CWA as:

Oil means oil of any kind or in any form, including, but not limited to: fats, oils, or greases of animal, fish, or marine mammal origin; vegetable oils, including oils from seeds, nuts, fruits, or kernels; and, other oils and greases, including petroleum, fuel oil, sludge, synthetic oils, mineral oils, oil refuse, or oil mixed with wastes other than dredged spoil.

The US Coast Guard (USCG) maintains a separate list of substances it considers oil for its regulatory purposes. The USCG *List of Petroleum and Non-petroleum Oils* may be used as a guide to determine if a particular substance is an oil; however, the USCG list is not comprehensive and does not include all oils that are subject to 40 CFR Part 112. The USCG list can be found here:

https://homeport.uscg.mil/Lists/Content/Attachments/376/2013.03.18%200PA90%20Oils%20and%20oil-likes.pdf.

The term "harmful quantities" is defined in 40 CFR Part 110 (also referred to as the "sheen rule") with discharges of harmful quantities including those that (a) violate applicable water quality standards, or (b) cause a film, sheen, or discoloration of the surface of the water or (c) adjoining shoreline or cause a sludge or emulsion to be deposited beneath the surface of the water or adjoining shoreline.

<u>1.3</u> <u>Scope</u>

The Storrs Campus, the Depot Campus and the Avery Point Campus all have current oil storage capacity and operations that require the development and implementation of a site-specific SPCC Plan. Each Plan describes the facility, its oil storage tanks, secondary containment structures, site drainage and security features, potential for releases that will impact the environment, training requirements for facility personnel, and procedures for responding to and reporting an emergency release. A Professional Engineer must certify the SPCC Plans and they must be fully reviewed, updated and recertified at least once every five years. On an annual basis, facility management conducts a review of each Plan to determine whether any modifications are required. Administrative changes, such as names of staff members and telephone numbers, are allowed without PE Certification. Any substantive modification of the Plans, especially the installation of a new tank, requires a new PE stamp. Facility personnel identified in the Plans attend annual training to maintain familiarity with the SPCC requirements.

Where applicable, references to the corresponding federal regulatory requirements have been provided. This plan addresses the general requirements of 40 CFR 112.7 and the relevant portions of the SPCC Plan requirements for onshore facilities in 40 CFR 112.8 and 40 CFE 112.12. On-shore facilities (excluding production facilities) with petroleum and non-petroleum oils, excluding animal, fish, marine mammal, and vegetable oils, must comply with the additional SPCC requirements outlined in 40 CFR 112.8. Onshore facilities that store or use animal fats, oils and greases and fish, marine mammal, and vegetable oils, which for the UConn Storrs Campus includes waste kitchen grease stored in containers with a capacity of 55 gallons or greater, must comply with the additional SPCC requirements outlined in 40 CFR 112.12.

1.4 Applicability

This document presents the SPCC Plan for the UConn Storrs Campus in accordance with the most recent amendments to 40 CFR Part 112 and is an update to the facility's previous SPCC Plan. The requirement to prepare an SPCC Plan is applicable to the UConn Storrs campus because the facility could reasonably be expected to discharge oil in quantities that may be harmful into the navigable waters of the United States and it stores oil in excess of the following threshold values:

- The aggregate aboveground oil storage capacity of the facility is greater than 1,320 gallons; or
- The completely buried oil storage capacity of the facility is greater than 42,000 gallons.

For purposes of the underground oil storage aggregate capacity determination, the completely buried storage capacity of a facility excludes the capacity of a completely buried tank, as defined in 40 CFR 112.2, and connected underground piping, underground ancillary equipment, and containment systems, that are currently subject to all of the technical requirements of 40 CFR 280 (EPA Underground Storage Tank (UST) Regulations) or all of the technical requirements of a State UST program approved under 40 CFR 281. For purposes of the aggregate aboveground storage capacity, only containers of oil with a capacity of 55 gallons or greater are counted. Oil-filled electrical, operating, and mechanical equipment (e.g., transformers, circuit breakers, electrical switches, hydraulic and lubricating systems, heat transformer systems) with capacities greater than 55 gallons are included in the facility's aggregate aboveground storage capacity.

SPCC Plan Criteria	UConn Storrs Conditions	SPCC Plan Required
Total completely buried UST volume greater than 42,000	Total = 0 gallons	No
gallons, not subject to 40 CFR 280	Total – O gallons	110

Total aboveground volume greater than 1,320 gallons	Approximate Total = 80,000 gallons	Yes
Reasonably expected to discharge oil in harmful quantities to navigable water	Proximity to navigable waterways: Fenton River and/or Willimantic River	Yes

There are no oil production or oil drilling facilities at the UConn Storrs Campus. Therefore, 40 CFR 112.9 and 112.10 are not applicable.

The UConn Storrs Campus is not required to prepare a Facility Response Plan as defined in 40 CFR 112.20. As required by Section 3.0 of Appendix C to 40 CFR 112, certification of the non-applicability of the substantial harm criteria is included at the beginning of this document, with the SPCC Plan certifications.

1.5 Plan Review and Amendment Procedures

A registered Professional Engineer must certify any technical amendment to this SPCC Plan as defined in 40 CFR Section 112.5. The regulations per 40 CFR 112.5 require amendment of the SPCC Plan under the following conditions:

- Whenever there is a change in the facility design, construction, operation, or maintenance that affects the facility's potential for the discharge of oil.
- At a minimum, this SPCC Plan must be reviewed and evaluated at least once every five years. A sign-off sheet to document these reviews is attached to the front of this SPCC Plan (page iv).

1.6 Plan Distribution

This SPCC Plan is not required to be filed with the U.S. EPA. Per 40 CFR 112.3(e), a copy must be available for on-site review by the EPA Regional Administrator during normal working hours. The Plan is available for electronic review 24 hours per day on the Environmental Health and Safety website (https://ehs.uconn.edu/environmental-programs/). UConn maintains a copy of this SPCC Plan at the following addresses:

The University of Connecticut Storrs Campus Facilities Operations 25 LeDoyt Road, Unit 3252 Storrs, CT 06269

And

University of Connecticut
Environmental Health & Safety – Environmental Programs
28 Professional Park Road
Storrs, CT 06268

And

University of Connecticut Public Safety Building 126 North Eagleville Road Storrs, CT 06269

1.7 Policy Statement

As stated in the University's Health and Safety Policy, UConn is committed to providing a healthful and safe environment and complying with federal and state health and safety standards. UConn is also committed to complying with all applicable environmental laws and regulations.

2.0 GENERAL SITE INFORMATION

2.1 Campus Description (40 CFR 112.7(a))

The University of Connecticut (UConn) is located in the Storrs section of Mansfield, Connecticut in a rural setting on Route 195 at approximately 41' 48" N and 72' 15" W. The location of the UConn Storrs Campus is shown on **Figure 1** and the general layout of the facility and buildings is provided on **Figure 2** (Campus Overview). **Figures 2-1 through 2-53** show the campus subdivided into tiles that show buildings, roads, and oil storage locations. Facility drainage features are described in Sections 2.3 and Section 3.

The UConn Storrs Campus is comprised of approximately 4,000 acres and serves approximately 22,000 undergraduate and graduate students. UConn is a state university campus that includes student and faculty housing, libraries, classrooms and lecture halls, laboratories, research buildings, agricultural study buildings, auditoriums and athletic fields and facilities. The campus contains farmlands, more than 373 buildings, 23 miles of roadways and approximately 60 acres of parking. The campus also includes an onsite Water Pollution Control Facility (WPCF) for wastewater treatment that services the campus as well as other off-campus residential and commercial areas along Route 195, elderly housing, Town of Mansfield Municipal Buildings along Routes 195 and 275, and the E.O. Smith High School in Mansfield. The WPCF (and adjacent water reclamation facility) do not receive or treat any stormwater from the campus. The campus also operates its own Central Utility Plant (CUP) that provides heat, electrical power, and chilled water to much of the University using cogenerating steam-driven turbines. The CUP also includes a steam boiler system as a source of auxiliary or back-up heat. Both the turbines and the boiler system primarily run on natural gas but have the ability to use No. 2 fuel oil as a backup fuel source. The University also operates its own water supply and distribution system. Water is supplied from two well fields located off campus (Willimantic River well field and the Fenton River well field). To ensure water service during dry months, as a supplement to UConn's on-site water supply, a Connecticut Water Company interconnection was added to the facility.

2.2 Oil Storage (40 CFR 112.7(a)(3)(i))

The UConn Storrs Campus stores oil in aboveground storage tanks (ASTs), underground storage tanks (USTs), oil-filled equipment and 55-gallon drums for heating, emergency and hydraulic power, and grease disposal. The UConn Storrs Campus makes every reasonable effort to ensure that these tanks are doublewalled tanks and that storage containers are located inside buildings. A tank or container is

considered to have secondary containment if the containment system or building it is located in is capable of holding oil and it is constructed so that any discharges from a primary containment system, such as a pipe or tank, will not escape the containment before cleanup occurs. Portable tanks are positioned or located to prevent a discharge and are provided with adequate secondary containment or countermeasures at the time of use to prevent a discharge from reaching navigable waters. Details on each UST and AST, including tank capacity, construction, and oil contents are outlined in Sections 3.1 through 3.2, respectively.

There are multiple drum storage areas on the Storrs Campus that store waste oil, motor oil, and transmission oil (see Section 3.3). In addition, the UConn Storrs Campus has many oil-filled electrical transformers, as discussed in section 3.4, and elevator hydraulic oil tanks, as discussed in Section 3.5.

2.3 Facility Drainage (40 CFR 112.8(b))

The UConn Storrs Campus stormwater drainage patterns generally follow the storm drainage system and/or site topography in the immediate area of any potential spill or release event. In general, stormwater generated from the campus is collected via stormwater catch basins and discharges to either one of the on-site ponds, Mirror Lake and Swan Lake, or to one of the on-site watercourses, Eagleville Brook or Roberts Brook. The Storrs Campus sits on top of a sub-regional drainage divide that runs roughly from northeast to southwest. Stormwater runoff from the northern and western portions of the main campus generally flows to the west, into Eagleville Brook basin. Ultimately, Eagleville Brook discharges into Eagleville Pond, an impoundment along the Willimantic River immediately upstream of CT Route 275. Stormwater runoff from southern and eastern portion of the main campus collects in either Swan Lake¹ or Mirror Lake and ultimately discharges into Roberts Brook. Drainage from the portion of campus that is east of CT Route 195 will primarily discharge directly into the Roberts Brook basin. Roberts Brook drains to the Fenton River, approximately 0.3 miles north of where Gurleyville Road crosses the Fenton River. Local watercourses and impoundments are shown on Figure 1.

Stormwater generated from Charter Oak Suites/Apartments (Figure 2-6) and Hilltop Apartment vicinities (Figure 2-41) discharge through oil/water separators before entering retention ponds. Stormwater

¹ Swan Lake has a secondary, high level outlet to Eagleville Brook that is active during significant storm events.

generated from the parking garages (North and South Garage) also discharges through oil/water separators before entering the drainage system.

None of the UConn Storrs Campus bulk storage tanks are equipped with diked storage areas which are subject to precipitation (40 CFR 112.8[b][1]), valves used on diked storage areas (40 CFR 112.8[b][2]), or treated water systems requiring pumping conveyance (40 CFR 112.8[b][5]). A diversion system that would retain oil within the facility is not required since the tanks located at the Storrs Campus are of double walled construction or are equipped with secondary containment.

3.0 SPILL PREDICTION, PREVENTION, CONTROL, & COUNTERMEASURES

In general, spills of oil may occur at the campus during tank filling operations, from slow leaks at tank locations, or due to unforeseen events such as mechanical failures or accidents involving breaches in fuel supply lines or other parts of the fueling systems on campus. While the majority of tanks and tank fill pipes are located in areas where a spill would be contained within a building or infiltrate into the ground, some storage tank fill pipes are located in areas that are exposed to stormwater and near stormwater catch basins that are connected to the university storm sewer system or nearby water bodies. Therefore, a leak or spill from the tank systems or during the tank filling operations could potentially discharge to navigable waters directly via the university storm sewer system. Specific spill prediction scenarios for each bulk storage container are included in Sections 3.1 through 3.3.

Oil-filled operational equipment inside the campus buildings (hydraulic elevators, some transformers and emergency generators) would not be expected to impact navigable waters due to the general lack of pathways for a related oil spill to exit the building. For other oil-containing operational equipment located throughout the campus, such as transformers located outdoors, there is a potential for a release of oil to navigable waters via the storm drainage systems. However, the more likely spill scenario to the environment is infiltration into the ground.

In addition to the general SPCC requirements of 40 CFR 112.7, onshore facilities (excluding production facilities) with petroleum and non-petroleum oils, excluding animal, fish, marine mammal and vegetable oils, must comply with the additional SPCC requirements outlined in 40 CFR 112.8. Onshore facilities that store or use animal fats, oils and greases and fish, marine mammal, and vegetable oils, must comply with the additional SPCC requirements outlined in 40 CFR 112.12. General prevention practices are ensured through the use of proper oil loading and handling procedures (Section 5.0), through the practice of regular maintenance and inspection of the tank systems, and through security measures (Section 4.0). General control measures include the use of tanks and containers that are constructed of materials compatible with their contents (40 CFR 112.8(c)(1) and 112.12(c)(1)). General countermeasure procedures are described in Section 7.0.

Specific physical descriptions, spill predictions, spill prevention practices, spill control measures, and spill countermeasures associated with each bulk storage tank or storage container and with oil-filled equipment are described in the following Sections 3.1 through 3.5. Locations of the ASTs, USTs, drum storage areas and oil-filled electrical equipment are shown on **Figures 2-1 to 2-53**. Tank identification

numbers consist of an abbreviation for the type of tank followed by a number. UConn's tank numbering is not sequential, as some tanks listed in previous SPCC Plan versions have been removed or re-located to a different UConn Campus. The Campus Overview Map (**Figure 2**) and accompanying table show the individual tank ID and referenced figure number.

3.1 Underground Storage Tanks (USTs)

In accordance with 40 CFR 112.1(d)(4), completely buried USTs operating under a state approved UST program compliant with 40 CFR 281 are not subject to the SPCC rule. Although a completely buried UST is not itself regulated under SPCC regulations, unloading and loading operations associated with the tank are subject to SPCC requirements. The locations of the registered USTs are included on the facility diagrams in the Figures at the end of this Plan. Note that the design, inspection, and monitoring of these USTs are covered under the Connecticut Department of Energy & Environmental (CT DEEP's) UST program (RCSA 22a-449(d)-1 to 22a-449(d)-113). Information regarding the design, inspection, and monitoring of the UST is presented and discussed within this Plan for reference and informational purposes only. All USTs presented in this section are operated under the state's UST rule and program. The following section includes specific physical descriptions and spill predictions for each underground storage tank. The tanks are presented on the following pages by tank identification number in numerical order. SPCC regulated activities associated with underground storage tanks at the Storrs Campus consist of the transfers of Ultra Low Sulfur Diesel (ULSD) and gasoline.

USTs for Heating

The following UConn Storrs Campus USTs contain heating oil for consumptive purposes onsite:

- **UST-35** and **UST-36**: Two (2) 1,000-gallon ULSD heating fuel tanks at Plant Science Research and Education Facility
- UST-40 and UST-41: Two (2) 1,000-gallon ULSD heating fuel tanks at Spring Hill Isolation Farm
- UST-46: One (1) 2,500-gallon ULSD heating fuel tank at the WPCF

USTs for Emergency Generators

The following UConn Storrs Campus USTs used for emergency generators contain ULSD #2 Fuel Oil:

- UST-3: One (1) 600-gallon ULSD emergency generator tank at the Mansfield Apartment Lift Station
- UST-10: One (1) 2,000-gallon ULSD emergency generator tank at Beach Hall
- UST-13: One (1) 1,500-gallon ULSD emergency generator tank at Biobehavioral #4 Annex Building
- UST-14: One (1) 1,000-gallon ULSD emergency generator tank at Commissary Warehouse
- UST-16: One (1) 600-gallon ULSD emergency generator tank at Eastwood Road Lift Station
- UST-18: One (1) 3,000-gallon ULSD emergency generator tank at Fenton River well field pumphouse

- UST-32: One (1) 600-gallon ULSD emergency generator tank at Northwood Apartment Lift Station
- UST-45: One (1) 2,500-gallon ULSD emergency generator tank at the WPCF

USTs for Heating and/or Power Generators

The Central Utility Plant has six (6) 50,000-gallon ULSD tanks used for heating and to run the turbines for power generation when natural gas is not available. The 4,000-gallon ULSD tank located at the Dodd Research Center is primarily used for heating the building but also fuels the emergency generator at this location. A 2,000-gallon ULSD tank located at the Psychology Building is primarily used for the emergency generator but also fuels the boiler for heating the building. A 30,000-gallon ULSD tank located at the Supplemental Utility Plant is used for heating and to run the emergency generators. The following UConn Storrs Campus USTs used for heating and/or emergency generators contain ULSD #2 Fuel Oil:

- UST-15: One (1) 4,000-gallon ULSD tank at Dodd Research Center
- UST-20 through UST-25: Six (6) 50,000-gallon ULSD tanks at the Central Utility Plant
- UST-39: One (1) 2,000-gallon ULSD tank at Psychology Building
- UST-52: One (1) 30,000-gallon ULSD tank at the Supplemental Utility Plant

USTs for Vehicle Fueling

The Motor Pool has one unleaded gasoline UST and one ULSD fuel oil UST used for fueling vehicles. Both tanks are 10,000 gallons. The following UConn Storrs Campus USTs are used for vehicle fueling:

- UST-28: One (1) 10,000-gallon ULSD tank at Motor Pool
- UST-29: One (1) 10,000-gallon gasoline tank at Motor Pool

UST-3, Mansfield Apartment Lift Station Emergency Generator

General Description [112.7(a)(1)]

Tank ID	UST-3
Capacity	600 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Outside at Mansfield Apartments Lift Station, 2 South Eagleville Road. Lift station is on to the east of loop road through the apartments in the woods between the road and Storrs Road (Route 195) (See Figure 2-50).
Surroundings	Fenced in grass area sloped towards the wooded area east of the tank.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment.
Transfer Piping	Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel east towards the wooded area where product would pond and infiltrate into the ground. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: The underground portion of the piping is enclosed in 3-inch diameter
[40 CFR 112.8(c)(2)]	PVC piping
Overfill Protection	Yes, Veeder Root TLS 300c
Level gauge	Yes, Veeder Root TLS 300c
Alarms	Yes, Veeder Root TLS 300c
Security	Campus has 24-hour security, sufficient lighting, and tank is enclosed with a 6-
	foot fence topped with barbwire and gate is locked.

UST-10, Beach Hall Emergency Generator

General Description [112.7(a)(1)]

Tank ID	UST-10
Capacity	2,000 gallons
Contents	ULSD
Construction	Single-walled FRP
Location	Outside, northwest side of Charles Lewis Beach Hall (See Figure 2-24)
Surroundings	Grass area sloped down towards sidewalk north of the tank.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	A release from the primary container will result in a discharge beneath the ground surface.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground generator day tank (not SPCC regulated, less than 55 gallons). Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel west on the sidewalk towards a nearby catch basin that drains north to Swan Lake. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: None, single-walled construction
Containment	Piping: Double-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes vent whistler
Level gauge	Yes, visual level gauge
Alarms	None
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

UST-13, Biobehavioral #4 Annex Building Emergency Generator

General Description [112.7(a)(1)]

Tank ID	UST-13
Capacity	1,500 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Outside, to the south of Biobehavioral #4 Annex Building, 3107 Horsebarn Hill Road (See Figure 2-9)
Surroundings	Asphalt area sloped adjacent to a slope down towards a nearby field to the south.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground generator day tank (not SPCC regulated, less than 55 gallons). Releases from the underground transfer piping would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel south down the steep slope to an adjacent field. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: None, single-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes overfill drop tube
Level gauge	None
Alarms	None
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

UST-14, Commissary Warehouse Emergency Generator

General Description [112.7(a)(1)]

Tank ID	UST-14
Capacity	1,000 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Outside on north corner of Commissary Warehouse, 30 Gurleyville Road (See Figure 2-25)
Surroundings	Adjacent to the Commissary Warehouse on top of grassy hill, sloped down to the northeast away from the tank. Tank is next to emergency generator.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground generator day tank (not SPCC regulated, less than 55 gallons). Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel northwest down driveway to Gurleyville Road and potentially discharge to Roberts Brook. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Yes double-walled construction
Containment	Piping: Double-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes overfill drop tube
Level gauge	None
Alarms	None
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

UST-15, Dodd Research Center

General Description [112.7(a)(1)]

Tank ID	UST-15
Capacity	4,000 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Outside Dodd Research Center, 405 Babbidge Road (near east corner of
	building) (See Figure 2-32)
Surroundings	Adjacent to the sidewalk on a small hill sloped east of the tank, separate from
	emergency generator and boiler.
Use	Fuel source for emergency generator and boiler.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment tank.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground generator day tank (not SPCC regulated, less than 55 gallons). A release from aboveground piping would be contained by the building's walls and floor. A release from belowground piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel east from tank/fueling area to a nearby storm drain. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 300c
Level gauge	Yes, Veeder Root TLS 300c
Alarms	Yes, Veeder Root TLS 300c
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

<u>UST-16, Eastwood Road Lift Station Emergency Generator</u>

General Description [112.7(a)(1)]

Tank ID	UST-16
Capacity	600 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Outside at Eastwood Road Lift Station, South Eagleville Road (south of
	intersection with Eastwood Road) (See Figure 2-51)
Surroundings	Fenced in grassy area sloped down towards the wooded area southeast of the
	tank.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment tank.
Transfer Piping	Releases from the underground transfer piping would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel south to the wooded area. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: None, single-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 300c
Level gauge	Yes, Veeder Root TLS 300c
Alarms	Yes, Veeder Root TLS 300c
Security	Campus has 24-hour security, sufficient lighting, and a 6-foot fence topped with barbed wire and a locked gate surrounding the lift station. Fill port is locked.

UST-18, Fenton River Well Field Pump Station Emergency Generator

General Description [112.7(a)(1)]

Tank ID	UST-18
Capacity	3,000 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Fenton River well field, 223 Gurleyville Road, tank is located outside, adjacent
	to the pump station (See Figure 2-5)
Surroundings	Tank is located in an underground vault. Vault is within a fenced in area
	sloped northeast towards the Fenton River.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment tank.
Transfer Piping	Transfer piping conveys ULSD from UST to emergency generator. A release from aboveground piping would be contained by the building's walls and floor. A release from belowground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel over an unimproved, unpaved area northeast towards the Fenton River, which is approximately 350 feet away. Product would infiltrate the ground and possibly enter the Fenton River. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 300c
Level gauge	Yes, Veeder Root TLS 300c
Alarms	Yes, Veeder Root TLS 300c
Security	Campus has 24-hour security, sufficient lighting, and a 6-foot fence topped
	with barbed wire and locked gate surrounding the pump station. Fill port is
	locked.

UST-20, UST-21, UST-22, UST-23, UST-24, UST-25, Central Utility Plant

General Description [112.7(a)(1)]

Tank IDs	UST-20, 21, 22, 23, 24, and 25
Capacity	50,000 gallons each (6 separate tanks)
Contents	ULSD
Construction	Double-walled Steel with FRP coating
Location	Central Utility Plant, 240 Glenbrook Road, east of buildings (See Figure 2-23)
Surroundings	Asphalt area sloped towards Glenbrook Road east of tanks.
Use	Fuel source for boilers, turbines and emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment tank.
Transfer Piping	Transfer piping conveys ULSD from the UST to Central Utility Plant. A release from aboveground piping would be contained by the building's walls and floor. A release from belowground piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharge from fueling would travel east towards Glenbrook Road. Product would enter a nearby catch basin. Final discharges would be the Sam's Food Store Outfall to stream. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 350
Level gauge	Yes, Veeder Root TLS 350
Alarms	Yes, Veeder Root TLS 350
Security	Campus has 24-hour security, sufficient lighting, and fill ports are locked

UST-28, Motor Pool

General Description [112.7(a)(1)]

Tank ID	UST-28
Capacity	10,000 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Outside at Motor Pool, 9 Discovery Drive, north of fueling station (See Figure
	2-15)
Surroundings	Asphalt area sloped south
Use	Fuel source for dispensing fuel.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment tank.
	,
Transfer Piping	Leaks from dispenser hoses would discharge to pavement and flow south and
	east towards grassy area. Releases from the underground transfer piping
	would be contained within the containment wall of the double-walled piping.
	If breached, a release most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel south towards a catch basin
	approximately 375 feet away. There is a possibility a release would enter the
	catch basin that drains to Eagleville Brook via the outfall west of 125 North
	Eagleville Road. Quantity could vary from small drips/leaks to tank/hose
	failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled construction
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 350
Level gauge	Yes, Veeder Root TLS 350
Alarms	Yes, Veeder Root TLS 350
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

UST-29, Motor Pool

General Description [112.7(a)(1)]

Tank ID	UST-29
Capacity	10,000 gallons
Contents	Gasoline
Construction	Double-walled FRP
Location	Outside at Motor Pool, 9 Discovery Drive, north of fueling station (See Figure 2-15)
Surroundings	Asphalt area sloped south
Use	Fuel source for dispensing fuel.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment tank.
Transfer Piping	Leaks from dispenser hoses would discharge to pavement and flow south and east towards grassy area. Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel south towards a catch basin approximately 375 feet away. There is a possibility a release would enter the catch basin that drains to Eagleville Brook via the outfall west of 125 North Eagleville Road. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled construction
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 350
Level gauge	Yes, Veeder Root TLS 350
Alarms	Yes, Veeder Root TLS 350
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

UST-32, Northwood Apartment Lift Station Emergency Generator

General Description [112.7(a)(1)]

Tank ID	UST-32
Capacity	600 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Outside at Northwood Apartment Lift Station, intersection of North Eagleville
	Road and Northwood Road, 1 Northwood Road (See Figure 2-34)
Surroundings	Fenced in grassy area sloped down towards the wooded area east of the tank.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of
	the secondary containment tank.
Transfer Piping	Releases from the underground transfer piping would most likely infiltrate
	into the ground.
Bulk Transfers	Discharges from fueling would travel east towards the wooded area. Quantity
	could vary from small drips/leaks to tank/hose failure up to the entire
	contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: None, single-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 300c
Level gauge	Yes, Veeder Root TLS 300c
Alarms	Yes, Veeder Root TLS 300c
Security	Campus has 24-hour security, sufficient lighting, and a 6-foot fence topped with barbed wire and a locked gate surrounding the lift station. Fill port is locked.

UST-35, Plant Science Research and Education Facility

General Description [112.7(a)(1)]

Tank ID	UST-35
Capacity	1,000 gallons
Contents	ULSD
Construction	Single-walled FRP
Location	Outside at Plant Science Education and Research Facility, 59 Agronomy Road, tank is located in grass area on north corner of the main building (See Figure 2-52)
Surroundings	Grassy area sloped northeast of the tanks.
Use	Fuel source for boilers.

Spill Prediction [112.7(b)]

Primary Container	A release from the primary container will result in a discharge beneath the ground surface.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground boiler. A release from aboveground piping would be contained by the building's walls and floor. Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel northeast towards the grassy/wooded area. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker unloading operations are conducted in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: None, single-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes vent whistler
Level gauge	Yes
Alarms	No
Security	Campus has 24 hour security, sufficient lighting, this facility is entirely fenced
	and the gate is locked when faculty/staff are not present. Fill port is locked.

UST-36, Plant Science Research and Education Facility

General Description [112.7(a)(1)]

Tank ID	UST-36
Capacity	1,000 gallons
Contents	ULSD
Construction	Single-walled FRP
Location	Outside at Plant Science Education and Research Facility, 59 Agronomy Road, tank is located in grass area on northeast corner of the main building (See Figure 2-52)
Surroundings	Grassy area sloped northeast of the tanks.
Use	Fuel source for boilers.

Spill Prediction [112.7(b)]

Primary Container	A release from the primary container will result in a discharge beneath the ground surface.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground boiler. A release from aboveground piping would be contained by the building's walls and floor. Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel northeast towards the grassy/wooded area. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker unloading operations are conducted in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: None, single-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes vent whistler
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, this facility is entirely fenced
	and the gate is locked when faculty/staff are not present. Fill port is locked.

UST-39, Psychology Building

General Description [112.7(a)(1)]

Tank ID	UST-39
Capacity	2,000 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	Outside Bousfield Psychology Building on northeast side of building, 406
	Babbidge Road (See Figure 2-32)
Surroundings	Grassy area sloped towards the sidewalk east of the tank.
Use	Fuel source for emergency generator and boiler.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of
	the secondary containment tank.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground generator day
	tank, AST-53. A release from aboveground piping would be contained by the
	building's walls and floor. Releases from the underground transfer piping
	would be contained within the containment wall of the double-walled piping.
	If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel east towards the sidewalk and/or to the
	ground. Quantity could vary from small drips/leaks to tank/hose failure up to
	the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, overfill drop tube
Level gauge	None
Alarms	None
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

UST-40, Spring Hill Isolation Farm

General Description [112.7(a)(1)]

Tank ID	UST-40
Capacity	1,000 gallons
Contents	ULSD
Construction	Single-walled FRP
Location	Outside Spring Hill Isolation Farm, approximately 950 Storrs Road (Route 195),
	tank is located in road in center of barns (See Figure 2-53).
Surroundings	Asphalt area north of each building sloped southeast to buildings and fields.
Use	Fuel source for boilers.

Spill Prediction [112.7(b)]

Primary Container	A release from the primary container will result in a discharge beneath the ground surface.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground boiler. A release from aboveground piping would be contained by the building's walls and floor. Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel southeast towards the buildings and down the driveway to adjacent fields. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker unloading operations are conducted in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: None, single-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, vent whistler
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

UST-41, Spring Hill Isolation Farm

General Description [112.7(a)(1)]

Tank ID	UST-41
Capacity	1,000 gallons
Contents	ULSD
Construction	Single-walled FRP
Location	Outside Spring Hill Isolation Farm, approximately 950 Storrs Road (Route 195),
	tank is located in road in center of barns (See Figure 2-53).
Surroundings	Asphalt area north of each building sloped southeast to buildings and fields.
Use	Fuel source for boilers.

Spill Prediction [112.7(b)]

Primary Container	A release from the primary container will result in a discharge beneath the ground surface.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground boiler. A release from aboveground piping would be contained by the building's walls and floor. Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel southeast towards the buildings and down the driveway to adjacent fields. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker unloading operations are conducted in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: None, single-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes vent whistler
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security and sufficient lighting. Fill port is locked.

UST-45, WPCF Emergency Generator

General Description [112.7(a)(1)]

Tank ID	UST-45
Capacity	2,500 gallons
Contents	ULSD
Construction	Doubled-walled FRP
Location	WPCF, behind (north of) headworks building, 40 LeDoyt Road Extension (See Figure
	2-15)
Surroundings	Grassy area sloped south towards wastewater headworks building and main
	driveway.
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial wall of the secondary containment tank.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground generator day tank, AST-76. A release from the aboveground piping would be contained by the building's walls and floor. Releases from the underground transfer piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel south from tank/fueling area to the ground/grass and into storm drain system. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is
	located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 300c
Level gauge	Yes, Veeder Root TLS 300c
Alarms	Yes, Veeder Root TLS 300c
Security	Campus has 24-hour security, sufficient lighting, the WPCF is entirely fenced and
	the gate is locked when WPCF staff is not present. Fill port is locked.

UST-46, WPCF Boiler

General Description [112.7(a)(1)]

Tank ID	UST-46
Capacity	2,500 gallons
Contents	ULSD
Construction	Double-walled FRP
Location	WPCF, behind (north of) control building,40 LeDoyt Road Extension (See Figure 2-
	15).
Surroundings	Grassy area sloped south towards wastewater control building and main driveway.
Use	Fuel source for boiler.

Spill Prediction [112.7(b)]

MITTEGRECION [112.7(D)]	
Primary Container	Releases from the primary tank will be contained inside the interstitial wall of
	the secondary containment tank.
Transfer Piping	Transfer piping conveys ULSD from the UST to an aboveground boiler. A release
	from aboveground piping would be contained by the building's walls and floor.
	Releases from the underground transfer piping would be contained within the
	containment wall of the double-walled piping. If breached, a release would
	most likely infiltrate into the ground.
Bulk Transfers	Discharges from fueling would travel south from tank/fueling area to a nearby
	storm drain. Quantity could vary from small drips/leaks to tank/hose failure up
	to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

	1 V-1X-1X-11
Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 300c
Level gauge	Yes, Veeder Root TLS 300c
Alarms	Yes, Veeder Root TLS 300c
Security	Campus has 24-hour security, sufficient lighting, fill port is locked, and the
	WPCF is entirely fenced and the gate is locked when staff is not present. Fill
	port is locked.

UST-52, Supplemental Utility Plant

General Description [112.7(a)(1)]

Tank IDs	UST-52
Capacity	30,000 gallons
Contents	ULSD
Construction	Double-walled Steel with urethane coating
Location	Supplemental Utility Plant, King Hill Road, north of building (See Figure 2-26) Building under construction at time of inspection (July 2022)
Surroundings	Asphalt area sloped to catch basins in parking lot.
Use	Fuel source for boilers and emergency generators.

Spill Prediction [112.7(b)]

껃	ii Prediction [112.7(b)]	
	Primary Container	Releases from the primary tank will be contained inside the interstitial wall of
		the secondary containment tank.
•	Transfer Piping	Transfer piping conveys ULSD from the UST to the generator day tanks in the Supplemental Utility Plant and the boilers. A release from aboveground piping would be contained by the building's walls and floor. A release from belowground piping would be contained within the containment wall of the double-walled piping. If breached, a release would most likely infiltrate into the ground.
	Bulk Transfers	When completed, discharge from fueling was assumed to travel north or west towards a catch basin. Product would enter a nearby catch basin. Final discharges would be outfall to Eagleville Brook. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

-		
	Visual Inspections	Monthly (see Section 4.1)
	Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
		unloading operations are conducted in accordance with Section 5.2 of this
		Plan. A spill kit is available for all fueling deliveries and is located inside the
		vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled and aboveground piping is contained inside building.
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, Veeder Root TLS 350
Level gauge	Yes, Veeder Root TLS 350
Alarms	Yes, Veeder Root TLS 350
Security	Campus has 24-hour security, sufficient lighting, and fill ports are locked

3.2 Aboveground Storage Tanks (ASTs)

This section of the Plan includes specific physical descriptions, spill predictions and spill countermeasures associated with each of the aboveground storage tanks listed below. The tanks are presented on the following pages in numerical order by tank identification number. Spill countermeasures are explained within this section. Spill prevention practices are explained in Section 4.1.2. The majority of the ASTs at the UConn Storrs Campus contain petroleum and non-petroleum oils used for heating and emergency power generation with a smaller number of ASTs used for storage of vehicle maintenance oils, used oil, and waste kitchen grease. Only ASTs with a capacity greater than 55 gallons are discussed in this SPCC Plan. ASTs with a capacity less than 55 gallons are exempt from SPCC regulations.

ASTs for Heating

The following are aboveground tanks used to store ULSD for heating purposes:

- AST-53: One (1) 100-gallon ULSD day tank at the Psychology Building
- AST-55: One (1) 330-gallon ULSD tank at Mink Barn
- AST-59: One (1) 275-gallon ULSD tank at Plant Science Research and Education Facility

ASTs for Emergency Generators

The following UConn Storrs Campus ASTs contain ULSD used for emergency generators to provide temporary power during outages:

- AST-38: One (1) 500-gallon ULSD tank at Gampel Pavilion
- AST-46: One (1) 275-gallon ULSD day tank at IMS Building
- AST-47: One (1) 275-gallon ULSD tank at IMS Building
- AST-48: One (1) 185-gallon ULSD tank at Jorgenson
- AST-56: One (1) 1,000-gallon ULSD tank at South Campus Chiller Plant
- AST-76: One (1) 80-gallon ULSD day tank at the WPCF, Headworks Building
- AST-77: One (1) 200-gallon ULSD tank at North Parking Garage
- AST-80 and 81: Two (2) 150-gallon ULSD tanks at Central Utility Plant
- AST-82: One (1) 275-gallon ULSD tank at Central Utility Plant
- AST-130: One (1) 400-gallon ULSD tank at Public Safety
- AST-131: One (1) 1,000-gallon ULSD tank at Reclaimed Water Facility
- AST-132: One (1) 1,000-gallon ULSD tank at the Willimantic Wellfield
- AST-133: One (1) 330-gallon ULSD tank at the Nextel Radio Towers
- AST-135: One (1) 150-gallon ULSD tank at the Fieldhouse (Student Recreational Facility)
- AST-140: One (1) 150-gallon ULSD tank at the Edwards Freitas Ice Forum (Ice Rink)
- AST-144: One (1) 1,500-gallon ULSD tank at the High Head Lift Station
- AST-145: One (1) 209-gallon ULSD tank at the Isolation Farm Emergency Generator
- AST-147: One (1) 1,727-gallon ULSD tank at Gurleyville Lift Station

- AST-148: One (1) 323-gallon ULSD day tank at the Willimantic Wellfield pump station
- AST-150 and 151: Two (2) 300-gallon ULSD tanks at the Supplemental Utility Plant
- AST-153: One (1) 260-gallon ULSD tank at the Hockey Arena
- AST-154: One (1) 600-gallon ULSD tank at Public Safety

The following UConn Storrs Campus ASTs are trailer-mounted portable generators with ULSD fuel tanks used to provide temporary power at various locations:

- **AST-35:** One (1) 300-gallon ULSD tank on Taylor portable generator, trailer mounted (currently stored at Planning Design and Construction Warehouse)
- **AST-126:** One (1) 150-gallon ULSD tank on Electric Mobile portable generator, trailer mounted (currently stored at Planning Design and Construction Warehouse)
- **AST-134:** One (1) 342-gallon ULSD tank on portable generator, trailer mounted, at Infirmary (Student Health Services)

ASTs for Fueling, Lubrication, and Hydraulic Actuation

The following UConn Storrs Campus ASTs contain ULSD, gasoline, and other oils used for fueling vehicles or equipment, lubrication of equipment, or hydraulic actuation:

- AST-36: One (1) 135-gallon hydraulic oil tank at Engineering #1 Castleman Building
- AST-51: One (1) 275-gallon engine oil tank at Motor Pool
- AST-57: One (1) 275-gallon ULSD day tank at Plant Science Research and Education Facility
- AST-127: One (1) 275-gallon transmission oil tank at Motor Pool
- AST-142: One (1) 275-gallon engine oil tank at Motor Pool
- AST-143: One (1) 250-gallon hydraulic oil tank at Engineering #1 Castleman Building
- AST-149: One (1) 100-gallon mobile supply truck used for refilling other tanks on site
- AST-152: One (1) 2,500-gallon ULSD fuel tank at Farm Services

Additionally, there is one AST used to store used oil at Motor Pool:

• AST-50: One (1) 1,000-gallon used oil tank at Motor Pool

ASTs for Waste Grease

Lastly, there are thirteen (13) waste kitchen grease tanks at the following locations:

- AST-63: One (1) 200-gallon grease tank at Putnam Refectory Dining Facility
- AST-64: One (1) 200-gallon grease tank at Student Union (The Bistro)
- AST-65: One (1) 200-gallon grease tank at North (McConaughy) Dining Facility
- AST-66: One (1) 200-gallon grease tank at Whitney Dining Facility
- AST-67: One (1) 200-gallon grease tank at Gelfenbien (Towers) Dining Facility
- AST-68: One (1) 200-gallon grease tank at Northwest Dining Facility
- AST-69: One (1) 200-gallon grease tank at Shippee Dining Facility
- AST-70: One (1) 200-gallon grease tank at Buckley Dining Facility
- AST-72: One (1) 200-gallon grease tank at McMahon Dining Facility

- AST-73: One (1) 200-gallon grease tank at South Campus Dining Facility
- AST-124: One (1) 200-gallon grease tank at Student Union Street Market (USM)
- AST-138: One (1) 200-gallon grease tank at Student Union (Earth Wok & Fire)
- AST-139: One (1) 200-gallon grease tank at Student Union (One Plate, Two Plates)

AST-35, Portable Emergency Generator (Taylor)

General Description [112.7(a)(1)]

Tank ID	AST-35
Capacity	300 gallons
Contents	ULSD
Construction	Single-walled steel, trailer mounted
Location	Location varies as the generator and fuel tank are portable, trailer mounted.
	At the time of inspection, the generator is located outside the Planning Design
	and Construction Warehouse. (See Figure 2-15).
Surroundings	Varies, when stored: on pavement that slopes to grass area.
Use	Fuel source for portable generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank would spill onto the surrounding pavement and flow to nearby grass. Spill prediction is dependent on location of generator. Countermeasures (such as absorbent, portable booms or portable containment berms) are used to prevent discharge to navigable waters.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Portable generators are filled at the Motor Pool and used throughout the Storrs and UConn Depot Campuses (wherever needed). Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading and unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available at the Motor
	Pool for all fueling activities and is located inside the UConn vehicles.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary Containment [40 CFR 112.8(c)(2)]	Tank: None, single-walled construction Piping: n/a
Overfill Protection	No
Level gauge	Yes, float gauge
Alarms	None
Security	Fill port is locked.

AST-36, Engineering #1 Castleman Building

General Description [112.7(a)(1)]

Tank ID	AST-36
Capacity	135 gallons
Contents	Hydraulic oil
Construction	Single-walled steel
Location	Inside Engineering #1 Castleman Building, Room 116, 261 Glenbrook Road
	(See Figure 2-28)
Surroundings	Concrete floor
Use	Hydraulic oil used in operation of research and testing equipment.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the building.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	Bulk transfers are limited to adding or replacing the hydraulic fluid and would
	be performed manually. Quantity could vary from small drips/leaks to
	tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Quarterly (see Section 4.1)
Bulk Transfers	Bulk transfers are infrequent and would be manually performed by UConn
	personnel or an outside contractor. Should a spill/leak occur, UConn
	personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	None, manually filled.
Level gauge	Yes, visual float level gauge.
Alarms	None
Security	Fill port is locked.

AST-38, Gampel Pavilion Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-38
Capacity	500 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside of Gampel Pavilion on southwest side on Gampel Service Drive (See
	Figure 2-36)
Surroundings	Gravel
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would travel south from tank/fueling area to a nearby
	storm drain. Quantity could vary from small drips/leaks to tank/hose failure
	up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, overfill whistle.
Level gauge	Yes, visual float level gauge.
Alarms	Yes, overfill whistle.
Security	Campus has 24-hour security, sufficient lighting and the tank is behind a
	concrete wall and is gated.

AST-46, IMS/Gant Building Emergency Generator Day Tank

General Description [112.7(a)(1)]

Tank ID	AST-46
Capacity	275 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Inside IMS Building, 4th floor, 97 North Eagleville Road (See Figure 2-22)
Surroundings	Inside building
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space of the secondary containment tank. If breached, releases would be contained by the building's walls and floor.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	No bulk transfers are conducted with this tank. All transfers occur with typical operation between the tank at the loading dock, AST-47, or with the emergency generator.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Bulk transfers are not performed with this tank.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction and building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, pump shut-off
Level gauge	Yes, auto level sensor
Alarms	Yes, high Level alarm
Security	Campus has 24-hour security and sufficient lighting

AST-47, IMS-Physics Loading Dock Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-47
Capacity	275 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Inside IMS Building in loading dock 1st floor, 97 North Eagleville Road (See Figure 2-22)
Surroundings	Inside building
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank. If breached, releases would be contained
	by the building's walls and floor.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	If there is a spill or release outside of the second wall, the oil would discharge
	onto the floor and would be contained within the building. Quantity could
	vary from small drips/leaks to tank/hose failure up to the entire contents of a
	single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in accordance with Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction and building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, overfill protection
Level gauge	Yes, visual level gauge
Alarms	None
Security	Campus has 24-hour security and sufficient lighting

AST-48, Jorgensen Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-48
Capacity	185 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Jorgensen Center, 2132 Hillside Road (See Figure 2-28)
Surroundings	Located inside small room below loading dock, access from outside door to
	side of loading dock on east side of building. Concrete floor with brick
	containment berm.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space of the secondary containment tank. If breached, releases would be contained by the containment berm and the building's walls and floor.
Transfer Piping	Releases from the transfer piping would be to the floor of the building. Releases would be contained within the containment berm or by the building's walls and floor.
Bulk Transfers	Discharges that occur outside of the building from fueling would travel north from tank/fueling area to a nearby storm drain (<100 feet away). Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Single-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes, containment berm
Level gauge	Yes, visual level gauge
Alarms	None
Security	Campus has 24-hour security and sufficient lighting

AST-50, Motor Pool

General Description [112.7(a)(1)]

Tank ID	AST-50
Capacity	1,000 gallons
Contents	Waste oil
Construction	Double-walled steel
Location	Outside Motor Pool, 9 Discovery Drive, west side of building (See Figure 2-15)
Surroundings	Outside adjacent to Motor Pool surrounded with gravel and pavement. The
	ground is sloped northward and west towards an intermittent stream.
Use	Waste oil tank

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained within the interstitial space
	of the secondary containment tank.
Transfer Piping	Releases from the transfer piping will be contained inside the building or
	would infiltrate into the gravel ground around the tank.
Bulk Transfers	Transfers to the tank are primarily manual, performed from inside the
	building where any spills would be contained by the building's walls and floor.
	Bulk transfers are performed when the waste oil is pumped out of the tank to
	a tanker truck for offsite disposal. The quantity of releases from a bulk
	transfer could vary from small drips/leaks to tank/hose failure up to the entire
	contents of a single compartment of the waste oil truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste oil removal) are conducted by an outside
	contractor. Tanker loading operations are conducted in accordance with
	Section 5.2 of this Plan. A spill kit is available at the Motor Pool. Should a
	spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Single-walled, building walls and floor provide secondary containment
[40 CFR 112.8(c)(2)]	for interior piping.
Overfill Protection	Yes, auto level sensor
Level gauge	Yes, visual level gauge
Alarms	Yes, high level alarm
Security	Campus has 24-hour security, sufficient lighting, and fill port is locked

AST-51, Motor Pool

General Description [112.7(a)(1)]

Tank ID	AST-51
Capacity	275 gallons
Contents	Engine oil
Construction	Single-walled steel
Location	Inside Motor Pool, 9 Discovery Drive (See Figure 2-15)
Surroundings	Inside building, concrete floor, located inside containment tub
Use	Lubricant, engine oil

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained within containment tub and
	the building.
Transfer Piping	Releases from the transfer piping will be contained within the plastic
	secondary containment tub or within the building's walls and floor.
Bulk Transfers	Spills and releases would be contained within the building but potentially
	could discharge through the overhead doors with migration of product
	towards the catch basins. Quantity could vary from small drips/leaks to
	tank/hose failure up to the entire contents of a single compartment of the
	fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor. Tank is also located within a plastic container
Containment	to contain small spills and leaks.
[40 CFR 112.8(c)(2)]	Piping: Building's walls and floor
Overfill Protection	None
Level gauge	None
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and fill port is locked

AST-53, Psychology Day Tank

General Description [112.7(a)(1)]

Tank ID	AST-53
Capacity	100 gallons
Contents	ULSD
Construction	Double-walled steel
Location	On the roof of the Psychology Building, 406 Babbidge Road (See Figure 2-32)
Surroundings	On roof of building, enclosed inside a structure.
Use	Fuel source for boiler

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	No bulk transfers are conducted with this tank. All transfers occur with typical
	operation between UST-39, or with the boiler.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Bulk transfers are not performed with this tank.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double walled construction
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes, visual level gauge
Alarms	Yes, high level alarm and cutout switch
Security	Inside locked room

AST-55, Mink Barn

General Description [112.7(a)(1)]

Tank ID	AST-55
Capacity	330 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Inside Mink Barn (Rosebrook), Towers Loop Road (See Figure 2-1)
Surroundings	Inside building, within containment tub
Use	Fuel source for boiler

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space of the secondary containment tank or contained inside the containment tub or the building.
Transfer Piping	Releases from the transfer piping will be contained inside the plastic containment tub around the tank or contained by the building.
Bulk Transfers	Spills and releases from the tank will discharge into the containment tub. Other spills may result from filling of the AST and would be located in the vicinity of the fill pipe. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations (fuel deliveries) are conducted by an outside
	contractor. Tanker unloading operations are conducted in accordance with
	Section 5.2 of this Plan. A spill kit is available for all fueling deliveries and is
	located inside the vehicle. Should a spill/leak occur, UConn personnel are
	immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary Containment [40 CFR 112.8(c)(2)]	Tank: Double-walled and containment tub Piping: Building's walls and floor
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	Yes, high level alarm
Security	Campus has 24-hour security and sufficient lighting

AST-56, South Campus Chiller Plant Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-56
Capacity	1,000 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside on west side of South Campus Chiller Plant, off of Bolton Road (See Figure 2-43)
Surroundings	Gravel and fenced area behind the chiller plant. The ground is level.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would travel to the ground/grass area. Quantity could
	vary from small drips/leaks to tank/hose failure up to the entire contents of a
	single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes, visual level gauge
Alarms	Yes, high level alarm
Security	Campus has 24-hour security, sufficient lighting, fill port is locked, inside fence
	and gated.

AST-57, Plant Science Research and Education Facility

General Description [112.7(a)(1)]

Tank ID	AST-57
Capacity	275 gallons
Contents	ULSD
Construction	Single-walled steel
Location	Inside Barn #1 at Plant Science Research and Education Facility, 59 Agronomy
	Road (See Figure 2-52)
Surroundings	Inside the metal storage barn, Barn #1, on a concrete floor within a
	containment tub
Use	Fuel source for dispensing fuel for equipment.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained within the containment tub or contained by the building.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	Spills and releases from the filling of the tank would potentially discharge to
	the ground. Quantity could vary from small drips/leaks to tank/hose failure up
	to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Containment tub and building
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	Yes, high level alarm
Security	Campus has 24-hour security, sufficient lighting, this facility is entirely fenced
	and the gate is locked when staff are not present.

AST-59, Plant Science Research and Education Facility

General Description [112.7(a)(1)]

Tank ID	AST-59
Capacity	275 gallons
Contents	ULSD
Construction	Single-walled steel
Location	Inside greenhouse at Plant Science Research and Education Facility, 59
	Agronomy Road (See Figure 2-52)
Surroundings	Located inside greenhouse on level stone within containment tub
Use	Fuel source for furnace

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained within the containment tub.
Transfer Piping	Releases from the transfer piping will be contained inside the greenhouse, to
	the ground.
Bulk Transfers	Spills and releases from the filling of the tank would potentially discharge to
	the ground. Quantity could vary from small drips/leaks to tank/hose failure up
	to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Containment tub with 360-gallon capacity.
Containment	Piping: Single-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	Yes, high level alarm
Security	Campus has 24-hour security, sufficient lighting, this facility is entirely fenced
	and the gate is locked when staff are not present.

AST-63, Putnam Refectory Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-63
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside Putnam Refectory (See Figure 2-35)
Surroundings	Inside kitchen
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.12(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes, visual
Alarms	None
Security	Campus has 24-hour security, sufficient lighting

AST-64, Student Union Dining Facility (The Bistro)

General Description [112.7(a)(1)]

Tank ID	AST-64
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside Student Union (north end of building), basement, formerly served
	Chuck and Augie's (See Figure 2-28)
Surroundings	Inside building closet in basement
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank
	through permanently installed piping or through temporary piping connected
	to the tank. Releases from all transfer piping will be contained inside the
	building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.
	entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

_		1===::(=/(=/(:/)
	Visual Inspections	Monthly (see Section 4.1)
	Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
		conducted by an outside contractor. Tanker loading operations are conducted
		in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
		grease pickups and is located inside the vehicle. Should a spill/leak occur,
		UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.12(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and tank is located in locked
	closet

AST-65, North (McConaughy) Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-65
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside North Dining Facility, formerly called McConaughy (See Figure 2-16)
Surroundings	In kitchen of dining facility
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary Containment [40 CFR 112.12(c)(2)]	Tank: Building's walls and floor Piping: Building's walls and floor
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting

AST-66, Whitney Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-66
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside Holcomb Dining Facility (See Figure 2-25)
Surroundings	Located inside, in basement
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary Containment [40 CFR 112.12(c)(2)]	Tank: Building's walls and floor Piping: Building's walls and floor
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and tank is locked

AST-67, Gelfenbien (Towers) Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-67
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside Towers Dining Facility (See Figure 2-13)
Surroundings	In closet at loading dock.
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary Containment [40 CFR 112.12(c)(2)]	Tank: Building's walls and floor Piping: Building's walls and floor
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and tank is locked

AST-68, Northwest Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-68
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside Northwest Dining Facility (See Figure 2-16)
Surroundings	In electrical closet in basement
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.12(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and tank is locked

AST-69, Shippee Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-69
Capacity	150 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside Shippee Dining Facility (See Figure 2-33)
Surroundings	In the kitchen
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are conducted by an outside contractor. Tanker loading operations are conducted in accordance with Section 5.2 of this Plan. A spill kit is available for all waste grease pickups and is located inside the vehicle. Should a spill/leak occur, UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary Containment [40 CFR 112.12(c)(2)]	Tank: Building's walls and floor Piping: Building's walls and floor
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and tank is locked

AST-70, Buckley Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-70
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside Buckley Dining Facility (See Figure 2-33)
Surroundings	In the kitchen
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.12(c)	
(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and tank is locked

AST-72, McMahon Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-72
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside McMahon Dining Facility (See Figure 2-42)
Surroundings	Located inside kitchen
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the
Bulk Transfers	building. Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40CFR 112.12(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and tank is locked

AST-73, South Campus Dining Facility

General Description [112.7(a)(1)]

Tank ID	AST-73
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside South Campus Dining Facility (See Figure 2-43)
Surroundings	Located inside kitchen
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the
Bulk Transfers	building. Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40CFR 112.12(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and tank is locked

AST-76, WPCF Headworks Building Emergency Generator Day Tank

General Description [112.7(a)(1)]

Tank ID	AST-76
Capacity	80 gallons
Contents	ULSD
Construction	Single-walled steel
Location	Located inside Headworks Building at WPCF,40 LeDoyt Road Extension (See Figure 2-15)
Surroundings	Inside Headworks Building.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will discharge onto the floor within the
	building and be contained within the building.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	No bulk transfers are conducted with this tank. All transfers are in operation
	between the tank at the loading dock, UST-45, or with the emergency
	generator.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Bulk transfers are not performed with this tank.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's floors and walls.
Containment	Piping: Building's floors and walls.
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, fill gauge and fire cutoff valve.
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, this facility is entirely fenced
	and the gate is locked when WPCF staff is not present.

AST-77, North Parking Garage Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-77
Capacity	200 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside on southwest side of North Parking Garage, 103 North Eagleville Road
	(See Figure 2-27)
Surroundings	On concrete pad on sloped ground towards North Parking Garage
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would travel from tank/fueling area towards the
	parking garage. Quantity could vary from small drips/leaks to tank/hose
	failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes
Level gauge	None
Alarms	Yes, overfill alarm
Security	Campus has 24-hour security, sufficient lighting and fill port is locked

AST-80, AST-81, AST-82, Central Utility Plant Day Tanks #1, #2, #3

General Description [112.7(a)(1)]

Tank IDs	AST-80, 81, and 82
Capacity	Two 150-gallon tanks & one 275-gallon tank
Contents	ULSD
Construction	Double-walled steel
Location	Inside Central Utility Plant, 240 Glenbrook Road (See Figure 2-23)
Surroundings	Inside building
Use	Fuel source for emergency generators.

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the primary tank will be contained within the interstitial space of the secondary containment tank and within the building.
Transfer Piping	Releases from the transfer piping would be contained within the interstitial space of the double-walled piping. If breached, a release from the transfer piping will be contained inside the building.
Bulk Transfers	No bulk transfers are conducted with these tanks. All transfers occur with typical operation between UST-20, UST-21, UST-22, UST-23, UST-24, and UST-25, or with the emergency generators.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Bulk transfers are not performed with this tank.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes
Level gauge	None
Alarms	Yes, overfill alarm
Security	Campus has 24-hour security, sufficient lighting, and this facility is locked at all
	times.

AST-124, Student Union – Union Street Market (USM)

General Description [112.7(a)(1)]

Tank ID	AST-124
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside building in kitchen area of Union Street Market (See Figure 2-31)
Surroundings	Inside building
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank
	through permanently installed piping or through temporary piping connected
	to the tank. Releases from all transfer piping will be contained inside the
	building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that
	occur inside during bulk transfers will be contained within the building. There
	is the potential of a spill/leak to discharge outside to the loading dock area.
	The quantity could vary from small drips/leak to tank/hose failure up to the
	entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are conducted by an outside contractor. Tanker loading operations are conducted in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur, UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.12(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting

AST-126, Portable Emergency Generator (Electric Mobile)

General Description [112.7(a)(1)]

Tank ID	AST-126
Capacity	150 gallons
Contents	ULSD
Construction	Single-walled steel, trailer mounted
Location	Location varies as the generator and fuel tank are portable, trailer mounted. At the time of inspection, the generator is located outside the Planning Design and Construction Warehouse. (See Figure 2-15)
Surroundings	Varies, when stored: on pavement that slopes to grass area.
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank would spill onto the surrounding pavement and flow to nearby grass. Spill prediction is dependent on location of generator. Countermeasures (such as absorbent, portable booms or portable containment berms) are used to prevent discharge to navigable waters.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Portable generators are filled at the Motor Pool and used throughout the
	Storrs and UConn Depot Campuses (wherever needed). Quantity could vary
	from small drips/leaks to tank/hose failure up to the entire contents of a
	single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tank loading operations are conducted by UConn personnel in accordance
	with Section 5.2 of this Plan. A spill kit is available at the Motor Pool for all
	fueling activities.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: None, single-walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes, float gauge
Alarms	None
Security	Fill port is locked.

AST-127, Motor Pool

General Description [112.7(a)(1)]

Tank ID	AST-127
Capacity	275 gallons
Contents	Transmission Oil
Construction	Single-walled steel
Location	Inside Motor Pool, 9 Discovery Drive (See Figure 2-15)
Surroundings	Inside building, concrete floor, located inside containment tub
Use	Transmission oil for vehicles

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained within containment tub and the building.
Transfer Piping	Releases from the transfer piping will be contained within the plastic secondary containment or within the building's walls and floor.
Bulk Transfers	Spills and releases would be contained within the building but potentially could discharge through the overhead doors with migration of product towards the catch basins. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor. Tank is also located within a plastic container
Containment	to contain small spills and leaks.
[40 CFR 112.8(c)(2)]	Piping: Building's walls and floor
Overfill Protection	None
Level gauge	None
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, and fill port is locked

AST-130, Public Safety Building Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-130
Capacity	400 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside near northeast corner of Public Safety Building, 126 North Eagleville Road (See Figure 2-22)
Surroundings	On concrete pad, ground is level.
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would travel into a nearby storm drain approximately
	10 feet away. Quantity could vary from small drips/leaks to tank/hose failure
	up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security, sufficient lighting and fill port is locked

AST-131, Reclaimed Water Facility Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-131
Capacity	1,000 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside on west side of Reclaimed Water Facility, 48 LeDoyt Road Extension (See Figure 2-20)
Surroundings	On concrete pad, ground is level.
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would discharge onto the ground and to surrounding
	grass. Quantity could vary from small drips/leaks to tank/hose failure up to
	the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes
Alarms	No
Security	Campus has 24 hour security, sufficient lighting, this facility is entirely fenced
	and the gate is locked when plant staff is not present.

AST-132, Willimantic Well Field Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-132
Capacity	1,000 gallons
Contents	ULSD
Construction	Single-walled steel in aboveground concrete vault
Location	Outside on northwest corner of Willimantic well field lift station, Spring Manor Road (See Figure 2-11)
Surroundings	Concrete vault
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the concrete vault.
Transfer Piping	Releases from the transfer piping will be contained inside the building or
	discharge to the ground.
Bulk Transfers	Discharges from fueling would discharge onto the ground and to surrounding
	grass. Quantity could vary from small drips/leaks to tank/hose failure up to
	the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Concrete vault
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	None
Security	Campus has 24-hour security, sufficient lighting and fill port is locked and
	gated

AST-133, Nextel Radio Towers Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-133
Capacity	330 gallons
Contents	ULSD
Construction	Single-walled steel
Location	Outside next to the Nextel Radio Towers, Towers Court Road (south of Busby Suites) (See Figure 2-12)
Surroundings	Grass sloped south towards a wooded area
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank would discharge to the ground.
	Countermeasures (such as absorbent, portable booms or portable
	containment berms) are used to prevent discharge to navigable waters.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would discharge onto the ground and to surrounding
	grass. Quantity could vary from small drips/leaks to tank/hose failure up to
	the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Unknown, assumed single-walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	None
Security	Campus has 24-hour security, sufficient lighting, fill port is locked and area is
	gated.

AST-134, Infirmary Portable Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-134
Capacity	342 gallons
Contents	ULSD
Construction	Single-walled steel, trailer mounted
Location	Outside, west side of Infirmary (Health Services) Building, 234 Glenbrook
	Road, tank is part of a trailer mounted generator with fuel tank (See Figure 2-
	23)
Surroundings	Pavement
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank would discharge to the surrounding area. Spill prediction is dependent on location of generator. Countermeasures (such as absorbent, portable booms or portable containment berms) are used to prevent discharge to navigable waters.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would discharge onto the ground and to surrounding grass or nearby catch basin. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: None, single-walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	None
Security	Campus has 24 hour security, sufficient lighting and fill port is locked

AST-135, Student Recreational Center/Fieldhouse Fire Pump

General Description [112.7(a)(1)]

Tank ID	AST-135
Capacity	150 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside on south corner of Student Recreational Center/Fieldhouse, 2111 Hillside Road (See Figure 2-31)
Surroundings	Pavement
Use	Fuel source for fire pump/emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling will travel over pavement to a catch basin approximately 25 feet away west of the tank. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	None
Security	Campus has 24-hour security and sufficient lighting

AST-138, Student Union (Earth Wok & Fire)

General Description [112.7(a)(1)]

Tank ID	AST-138
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled stainless steel
Location	Inside Student Union, in kitchen area of Earth Wok & Fire (See Figure 2-31)
Surroundings	Inside building
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the
Bulk Transfers	building. Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are conducted by an outside contractor. Tanker loading operations are conducted in accordance with Section 5.2 of this Plan. A spill kit is available for all waste grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.12(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting

AST-139, Student Union (One Plate, Two Plates)

General Description [112.7(a)(1)]

Tank ID	AST-139
Capacity	200 gallons
Contents	Kitchen grease
Construction	Single-walled plastic
Location	Inside Student Union, in kitchen area of One plate, Two plates (See Figure 2-31)
Surroundings	Inside building
Use	Waste grease tank

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will be contained within the building.
Transfer Piping	Waste grease is generated and transferred from kitchen sources to the tank through permanently installed piping or through temporary piping connected to the tank. Releases from all transfer piping will be contained inside the building.
Bulk Transfers	Waste grease is transferred to a tanker truck for disposal offsite. Releases that occur inside during bulk transfers will be contained within the building. There is the potential of a spill/leak to discharge outside to the loading dock area. The quantity could vary from small drips/leak to tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker loading operations (waste grease pickup for offsite disposal) are
	conducted by an outside contractor. Tanker loading operations are conducted
	in accordance with Section 5.2 of this Plan. A spill kit is available for all waste
	grease pickups and is located inside the vehicle. Should a spill/leak occur,
	UConn personnel is immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.12(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	None
Security	Campus has 24-hour security, sufficient lighting

AST-140, Edwards Freitas Ice Forum (Ice Rink), Fire Pump

General Description [112.7(a)(1)]

Tank ID	AST-140
Capacity	150 gallons
Contents	ULSD
Construction	Single-walled steel
Location	Inside shed on east side of Edward Freitas Ice Forum (Ice Rink), Stadium Road
	(See Figure 2-49)
Surroundings	Located in shed separate from ice rink. Pavement all around shed.
Use	Fuel source for fire pump/emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the tank will discharge onto the floor within the shed and be contained by the shed.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	Spills and releases from the tank that occur inside the building would be contained within the building. A release that occurs outside the building would discharge onto the ground. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	None
Security	Campus has 24-hour security and sufficient lighting

AST-142, Motor Pool

General Description [112.7(a)(1)]

Tank ID	AST-142
Capacity	275 gallons
Contents	Engine Oil
Construction	Doubled-walled HDPE encased with galvanized steel
Location	Inside Motor Pool, 9 Discovery Drive, in oil storage room in back. (See Figure
	2-15)
Surroundings	Inside building
Use	Lubricant, engine oil

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained within the interstitial space
	of the secondary containment tank or inside the building.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	Spills and releases would be contained within the building. Quantity could
	vary from small drips/leaks to tank/hose failure up to the entire contents of a
	single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is available for all fueling deliveries and is located inside the
	vehicle. Should a spill/leak occur, UConn personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled tank and building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	Yes, high-level alarm
Security	Campus has 24-hour security and sufficient lighting

AST-143, Engineering #1 Castleman Building, New Tank

General Description [112.7(a)(1)]

Tank ID	AST-143
Capacity	250 gallons (estimated)
Contents	Hydraulic oil
Construction	Single-walled steel
Location	Inside Engineering #1 Castleman Building, Room 116, 261 Glenbrook Road
	(See Figure 2-28)
Surroundings	Concrete floor
Use	Hydraulic oil used in operation of research and testing equipment.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the building.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	Bulk transfers are limited to adding or replacing the hydraulic fluid and would
	be performed manually. Quantity could vary from small drips/leaks to
	tank/hose failure up to the entire contents of the tank.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Quarterly (see Section 4.1)
Bulk Transfers	Bulk transfers are infrequent and would be manually performed by UConn
	personnel or an outside contractor. Should a spill/leak occur, UConn
	personnel are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	None, manually filled
Level gauge	Yes, visual float level gauge.
Alarms	None
Security	Fill port is locked.

AST-144, High Head Lift Station Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-144
Capacity	1,500 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside to the west of the High Head Lift Station, Towers Loop Road (See Figure 2-3)
Surroundings	On concrete pad, ground is level.
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would travel southwest towards a wooded area and headwaters for Eagleville Brook. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security, sufficient lighting.

AST-145, Isolation Farm Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-145
Capacity	209 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside, north of barns at the Spring Hill Isolation Farm (See Figure 2-53)
Surroundings	On concrete pad, ground is level.
Use	Fuel source for emergency generator.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would travel southeast towards the buildings and
	down the driveway to adjacent fields. Quantity could vary from small
	drips/leaks to tank/hose failure up to the entire contents of a single
	compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, this facility is entirely fenced and the gate is locked when staff is not present.

AST-147, Gurleyville Lift Station Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-147
Capacity	1,727 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside to the east of the Gurleyville Lift Station, intersection of Gurleyville
	Road and Horsebarn Hill Road, Gurleyville Road (See Figure 2-25)
Surroundings	On concrete pad, ground is level.
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would travel north towards the unnamed intermittent watercourse. Product would infiltrate the ground and possibly enter the Roberts Brook and, further downstream, the Fenton River. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, this facility is entirely fenced
	and the gate is locked when staff is not present.

AST-148, Willimantic Wellfield Emergency Generator Day Tank

General Description [112.7(a)(1)]

Tank ID	AST-148
Capacity	323 gallons
Contents	ULSD
Construction	Single-walled steel
Location	Located inside Willimantic Wellfield pump house, Spring Manor Road (See
	Figure 2-11)
Surroundings	Inside pump house
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the tank will be contained within the building.
Transfer Piping	Releases from the transfer piping will be contained inside the building.
Bulk Transfers	No bulk transfers are conducted with this tank. All transfers occur with typical
	operation between AST-132, or with the emergency generator.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Bulk transfers are not performed with this tank.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Building's walls and floor
Containment	Piping: Building's walls and floor
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, the pump station is locked at
	all times.

AST-149, Mobile Supply Fuel Truck

General Description [112.7(a)(1)]

Tank ID	AST-149
Capacity	100 gallons
Contents	ULSD
Construction	Single-walled steel
Location	In bed of truck, located outside Facilities Operations (25 LeDoyt Road) when not in use. Moved around campus as needed to refuel other ASTs and USTs.
Surroundings	Varies, when at Facilities Operations: stored in parking lot that drains to catch
	basins.
Use	Refueling of other ASTs and USTs.

Spill Prediction [112.7(b)]

Spin Frediction [11217 (S)]	
Primary Container	Releases from the primary tank would spill onto the surrounding pavement and
	flow to nearby catch basins. Spill prediction is dependent on location of mobile
	tank and truck. Countermeasures (such as absorbent, portable booms or portable
	containment berms) are used to prevent discharge to navigable waters.
Transfer Piping	Releases from the transfer piping would spill onto the surrounding pavement and
	flow to nearby catch basins. Spill prediction is dependent on location of mobile
	tank and truck. Countermeasures (such as absorbent, portable booms or portable
	containment berms) are used to prevent discharge to navigable waters.
Bulk Transfers	Discharges from fueling activities would discharge onto the ground and to nearby
	catch basins. Quantity could vary from small drips/leaks to tank/hose failure up to
	the entire contents of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tank loading and unloading operations are conducted manually by UConn
	personnel in accordance with Section 5.2 of this Plan. A spill kit is available in the
	truck for all fueling activities.

Spill Control Measures [112.7(a)(3)(iii)]

Spili Control Micasarcs [11	2.7(a)(3)(11))
Secondary Containment	Tank: None, single-walled construction
[40 CFR 112.8(c)(2)]	Piping: None
Overfill Protection	No
Level gauge	No
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, the truck/tank are located in a
	locked parking lot at night.

AST-150 and AST-151, Supplemental Utility Plant Day Tanks

General Description [112.7(a)(1)]

Tank IDs	AST-150 and 151
Capacity	300 gallons, each
Contents	ULSD
Construction	Steel with open top steel rupture tank
Location	Inside Supplemental Utility Plant, King Hill Road (See Figure 2-26)
	Building under construction at time of inspection (July 2022)
Surroundings	Inside building
Use	Fuel source for emergency generators.

Spill Prediction [112.7(b)]

Primary Container	Spills and releases from the primary tank will be contained within the open top rupture tank and within the building.
Transfer Piping	Releases from the transfer piping would be contained within the interstitial space of the double-walled piping. If breached, a release from the transfer piping will be contained inside the building.
Bulk Transfers	No bulk transfers are conducted with these tanks. All transfers occur with typical operation between UST-52, these tanks, and the emergency generators.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Bulk transfers are not performed with this tank.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled
[40 CFR 112.8(c)(2)]	
Overfill Protection	Yes
Level gauge	Yes
Alarms	Yes, overfill alarm
Security	Campus has 24-hour security, sufficient lighting, and this facility is locked at all
	times.

AST-152, Farm Services Fuel Tank

General Description [112.7(a)(1)]

Tank ID	AST-152
Capacity	2,500 gallons
Contents	ULSD
Construction	Double-walled steel, raise on supports
Location	Farm Department, south of the Farm Services Building, 3099 Horsebarn Hill
	Road (See Figure 2-9)
Surroundings	Asphalt area sloped south towards a grassy field. Tank surrounded by
	bollards.
Use	Fuel source for dispensing fuel.

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained within the interstitial space
	of the secondary containment tank.
Transfer Piping	Leaks from dispenser hoses would discharge to paved surface. Larger spills
	could flow over pavement towards grassy field to the south.
Bulk Transfers	Discharges from fueling would travel south to the grassy field. Quantity could
	vary from small drips/leaks to tank/hose failure up to the entire contents of a
	single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by an outside contractor. Tanker
	unloading operations are conducted in accordance with Section 5.2 of this
	Plan. A spill kit is located next to the fueling dispenser and is available for all
	fueling deliveries and dispensing. Should a spill/leak occur, UConn personnel
	are immediately notified.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double-walled construction
Containment	Piping: Double-walled construction
[40 CFR 112.8(c)(2)]	
Overfill Protection	None
Level gauge	Yes, visual level gauge
Alarms	Yes, leak detection
Security	Campus has 24-hour security and sufficient lighting. Tank surrounded by
	bollards.

AST-153, Hockey Arena Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-153
Capacity	260 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Located outside Hockey Arena on Jim Calhoun Way (See Figure 2-48)
	Building under construction at time of inspection (July 2022)
Surroundings	On South side of building between building and driveway
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	When completed, discharge from fueling was assumed to travel south into the driveway and flow into a nearby storm drain. Quantity could vary from small drips/leaks to tank/hose failure up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, the pump station is locked at
	all times.

AST-154, Public Safety Building Emergency Generator

General Description [112.7(a)(1)]

Tank ID	AST-154
Capacity	600 gallons
Contents	ULSD
Construction	Double-walled steel
Location	Outside near northeast corner of Public Safety Building, 126 North Eagleville
	Road (See Figure 2-22)
Surroundings	On concrete pad, ground is level.
Use	Fuel source for emergency generator

Spill Prediction [112.7(b)]

Primary Container	Releases from the primary tank will be contained inside the interstitial space
	of the secondary containment tank.
Transfer Piping	This is a belly tank under the generator so there is no exposed transfer piping.
Bulk Transfers	Discharges from fueling would travel into a nearby storm drain approximately
	10 feet away. Quantity could vary from small drips/leaks to tank/hose failure
	up to the entire contents of a single compartment of the fuel truck.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Tanker unloading operations are conducted by UConn personnel in
	accordance with Section 5.2 of this Plan. A spill kit is available for all fueling
	deliveries and is located inside the UConn vehicle.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Tank: Double walled construction
Containment	Piping: n/a
[40 CFR 112.8(c)(2)]	
Overfill Protection	No
Level gauge	Yes
Alarms	No
Security	Campus has 24-hour security, sufficient lighting and fill port is locked

3.3 Drums

Oils are stored in 55-gallon drums in several locations throughout the UConn Storrs Campus, including Farm Services, Plant Science, Landscape Services, Motor Pool, and WPCF. These drums/containers are all located indoors and are placed on secondary spill pallets. Should a drum of oil spill or leak, the spill pallet would contain the contents of the oil drum. The following section includes specific physical descriptions and spill predictions for each drum storage area.

D-1, Motor Pool

General Description [112.7(a)(1)]

Drum Storage ID	D-1
Capacity	Variable up to thirteen (13) x 55-gallons (715 gallons, max)
Contents	Waste oil and motor oil
Construction	Single-walled steel drum (oil compatible)
Location	Located inside Motor Pool in back storage room. (See Figure 2-15)
Surroundings	Spill pallets on concrete floor
Use	Oil for vehicles and equipment and waste oil for disposal.

Spill Prediction [112.7(b)]

Primary Container	Drum overturn or damage by vehicles or equipment. A release from the drums will be contained by the spill pallet and the building's walls and floor.
Transfer Piping	n/a
Small Transfers	Small spills will be contained by the spill pallet and the building's walls and floor. Spills during transfers to the drums are not expected to exceed 5 gallons.
Bulk Transfers	Drum overturn or damage by mishandling or equipment impact. The maximum that could be released is 715 gallons if all drums were full and ruptured simultaneously.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)	
Bulk Transfers	Drum handling is conducted in accordance with Section 5.3 of this Plan.	1

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Spill pallets have a minimum 55-gallon secondary containment capacity.
Containment	
[40 CFR 112.8(c)(2)]	
Overfill Protection	Spills due to overfill would be contained by spill pallets.
Level gauge	No
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, and Motor Pool is secured
	when not in use.

<u>Spill Countermeasures [112.7(a)(3)(iv)]:</u> Any spills or leaks from the drum storage area will be contained and will be cleaned up either by properly trained UConn Facilities staff, UConn Fire Department personnel, or outside spill response contractor in accordance with Section 7.0 of this Plan.

D-2, WPCF Sludge Pump Building and Garage

General Description [112.7(a)(1)]

	
Tank ID	D-2
Capacity	One x 55-gallons (55 gallons, max)
Contents	Waste oil
Construction	Single-walled steel drum (oil compatible)
Location	Located inside Sludge Pump Building at WPCF (See Figure 2-15)
Surroundings	Spill pallet on concrete floor
Use	Waste oil disposal.

Spill Prediction [112.7(b)]

Primary Container	Drum overturn or damage by vehicles or equipment. A release from the drums will be contained by the spill pallet and the building's walls and floor.
Transfer Piping	n/a
Small Transfers	Small spills will be contained by the spill pallet and the building's walls and floor. Spills during transfers to the drums are not expected to exceed 5 gallons.
Bulk Transfers	Drum overturn or damage by mishandling or equipment impact. The maximum that could be released is 55 gallons if the drum was full and ruptured.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)	
Bulk Transfers	Drum handling is conducted in accordance with Section 5.3 of this Plan.	1

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Spill pallet has a 55-gallon secondary containment capacity.
Containment	
[40 CFR 112.8(c)(2)]	
Overfill Protection	Spills due to overfill would be contained by spill pallet.
Level gauge	No
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, and WPCF buildings are
	secured when not occupied.

Spill Countermeasures [112.7(a)(3)(iv)]: Any spills or leaks from the drum area will be contained and will be cleaned up either by properly trained UConn Facilities staff, UConn Fire Department personnel, or outside spill response contractor in accordance with Section 7.0 of this Plan.

D-3, WPCF SHT Building

General Description [112.7(a)(1)]

Tank ID	D-3
Capacity	Variable up to two (2) x 55-gallons (110 gallons, max)
Contents	Motor oil
Construction	Single-walled steel drum (oil compatible)
Location	Located inside Sludge Holding Tank (SHT) Building at WPCF (See Figure 2-15)
Surroundings	Spill pallets on concrete floor
Use	Oil for vehicles and equipment.

Spill Prediction [112.7(b)]

_		
	Primary Container	Drum overturn or damage by vehicles or equipment. A release from the
		drums will be contained by the spill pallet and the building's walls and floor.
	Transfer Piping	n/a
	Small Transfers	Small spills will be contained by the spill pallet and the building's walls and
		floor. Spills during transfers to the drums are not expected to exceed 5
		gallons.
	Bulk Transfers	Drum overturn or damage by mishandling or equipment impact. The
		maximum that could be released is 110 gallons if both drums were full and
		ruptured simultaneously.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)	
Bulk Transfers	Drum handling is conducted in accordance with Section 5.3 of this Plan.	1

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Spill pallets have at least 55-gallon secondary containment capacity.
Containment	
[40 CFR 112.8(c)(2)]	
Overfill Protection	Spills due to overfill would be contained by spill pallets.
Level gauge	No
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, and WPCF buildings are
	secured when not occupied.

<u>Spill Countermeasures [112.7(a)(3)(iv)]:</u> Any spills or leaks from the drum storage area will be contained and will be cleaned up either by properly trained UConn Facilities staff, UConn Fire Department personnel, or outside spill response contractor in accordance with Section 7.0 of this Plan.

D-4, Planning Design and Construction Warehouse

General Description [112.7(a)(1)]

Tank ID	D-4
Capacity	One x 55-gallons (55 gallons, max)
Contents	Motor oil
Construction	Single-walled steel drum (oil compatible)
Location	Located inside Planning Design and Construction Warehouse (See Figure 2-15)
Surroundings	Spill pallet on concrete floor
Use	Oil for equipment.

Spill Prediction [112.7(b)]

Primary Container	Drum overturn or damage by vehicles or equipment. A release from the drum will be contained by the spill pallet and the building's walls and floor.
Transfer Piping	n/a
Small Transfers	Small spills will be contained by the spill pallet and the building's walls and
	floor. Spills during transfers to the drum are not expected to exceed 5 gallons.
Bulk Transfers	Drum overturn or damage by mishandling or equipment impact. The
	maximum that could be released is 55 gallons if the drum was full and
	ruptured.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Drum handling is conducted in accordance with Section 5.3 of this Plan.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Spill pallet has 55-gallon secondary containment capacity.
Containment	
[40 CFR 112.8(c)(2)]	
Overfill Protection	Spills due to overfill would be contained by spill pallet.
Level gauge	No
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, and buildings are secured
	when not occupied.

<u>Spill Countermeasures [112.7(a)(3)(iv)]:</u> Any spills or leaks from the drum will be contained and will be cleaned up either by properly trained UConn Facilities staff, UConn Fire Department personnel, or outside spill response contractor in accordance with Section 7.0 of this Plan.

D-5, Farm Services

General Description [112.7(a)(1)]

Tank ID	D-5
Capacity	Variable up to nine (9) x 55-gallons (495 gallons, max)
Contents	Waste oil and motor oil
Construction	Single-walled steel drums (oil compatible)
Location	Located inside Farm Services Warehouse/Barn (See Figure 2-9)
Surroundings	Spill pallets on concrete floor
Use	Oil for vehicles and equipment and waste oil collection.

Spill Prediction [112.7(b)]

Primary Container	Drum overturn or damage by vehicles or equipment. A release from the drums will be contained by the spill pallet and the building's walls and floor.
Transfer Piping	n/a
Small Transfers	Small spills will be contained by the spill pallet and the building's walls and floor. Spills during transfers to the drums are not expected to exceed 5 gallons.
Bulk Transfers	Drum overturn or damage by mishandling or equipment impact. The maximum that could be released is 495 gallons if all drums were full and ruptured simultaneously.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)	
Bulk Transfers	Drum handling is conducted in accordance with Section 5.3 of this Plan.	1

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Spill pallets have a minimum 55-gallon secondary containment capacity.
Containment	
[40 CFR 112.8(c)(2)]	
Overfill Protection	Spills due to overfill would be contained by spill pallets.
Level gauge	No
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, and buildings are secured
	when not occupied.

<u>Spill Countermeasures [112.7(a)(3)(iv)]:</u> Any spills or leaks from the drum storage area will be contained and will be cleaned up either by properly trained UConn Facilities staff, UConn Fire Department personnel, or outside spill response contractor in accordance with Section 7.0 of this Plan.

D-6, Plant Services Laboratory Area

General Description [112.7(a)(1)]

Tank ID	D-6
Capacity	One x 55-gallons (55 gallons, max)
Contents	Waste oil
Construction	Single-walled steel drum (oil compatible)
Location	Located in laboratory area at Plant Services (See Figure 2-52)
Surroundings	Spill pallet on concrete floor
Use	Waste oil disposal.

Spill Prediction [112.7(b)]

Primary Container	Drum overturn or damage by vehicles or equipment. A release from the drum
	will be contained by the spill pallet and the building's walls and floor.
Transfer Piping	n/a
Small Transfers	Small spills will be contained by the spill pallet and the building's walls and
	floor. Spills during transfers to the drum are not expected to exceed 5 gallons.
Bulk Transfers	Drum overturn or damage by mishandling or equipment impact. The
	maximum that could be released is 55 gallons if the drum was full and
	ruptured.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)
Bulk Transfers	Drum handling is conducted in accordance with Section 5.3 of this Plan.

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Spill pallet has a 55-gallon secondary containment capacity.
Containment	
[40 CFR 112.8(c)(2)]	
Overfill Protection	Spills due to overfill would be contained by spill pallet.
Level gauge	No
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, and buildings are secured
	when not occupied.

<u>Spill Countermeasures [112.7(a)(3)(iv)]:</u> Any spills or leaks from the double-walled tanks will be contained and will be cleaned up either by properly trained UConn Facilities staff, UConn Fire Department personnel, or outside spill response contractor in accordance with Section 7.0 of this Plan.

D-7, Plant Services Workshop Area

General Description [112.7(a)(1)]

Tank ID	D-6
Capacity	Four x 55-gallons (220 gallons, max)
Contents	Waste oil and motor oil
Construction	Single-walled steel drums (oil compatible)
Location	Located in workshop area at Plant Services (See Figure 2-52)
Surroundings	Spill pallet on concrete floor
Use	Waste oil disposal.

Spill Prediction [112.7(b)]

Primary Container	Drum overturn or damage by vehicles or equipment. A release from the drums will be contained by the spill pallet and the building's walls and floor.
Transfer Piping	n/a
Small Transfers	Small spills will be contained by the spill pallet and the building's walls and floor. Spills during transfers to the drums are not expected to exceed 5 gallons.
Bulk Transfers	Drum overturn or damage by mishandling or equipment impact. The maximum that could be released is 220 gallons if all drums were full and ruptured simultaneously.

Spill Prevention Measures [112.7(a)(3)(ii)]

Visual Inspections	Monthly (see Section 4.1)	
Bulk Transfers	Drum handling is conducted in accordance with Section 5.3 of this Plan.	1

Spill Control Measures [112.7(a)(3)(iii)]

Secondary	Spill pallets have a minimum 55-gallon secondary containment capacity.
Containment	
[40 CFR 112.8(c)(2)]	
Overfill Protection	Spills due to overfill would be contained by spill pallets.
Level gauge	No
Alarms	No
Security	Campus has 24-hour security, sufficient lighting, and buildings are secured
	when not occupied.

<u>Spill Countermeasures [112.7(a)(3)(iv)]:</u> Any spills or leaks from the drum storage area will be contained and will be cleaned up either by properly trained UConn Facilities staff, UConn Fire Department personnel, or outside spill response contractor in accordance with Section 7.0 of this Plan.

3.4 <u>Transformers</u>

The following transformers located on the ground are owned and operated by UConn. Transformers are typically located on concrete pads surrounded by bollards to protect them from physical damage. In general, these transformers do not currently have secondary containment or a drainage system engineered in such a way as to prevent spilled oil from entering the environment. Oil-filled equipment, such as transformers, do not consume oil and are not considered a bulk storage container per 40 CFR 112.2. Oil-filled electrical equipment, therefore, is exempt from bulk storage requirements outlined in 112.8(c) and secondary containment requirements in 112.7(c). In lieu of secondary containment, transformers are thoroughly inspected quarterly by UConn Storrs Campus Facilities Operations Personnel. UConn personnel inspecting the transformers look for conditions that pose the potential of a spill to the environment and will conduct preventive maintenance when necessary. The pole-mounted transformers are owned by UConn and operated by Eversource Energy. Pole-mounted transformers at UConn typically contain less than 55 gallons of oil and are not included in the inventory below. An inventory of transformers having capacities more than 55 gallons at the UConn Storrs Campus is provided below and their locations are shown on Figures 2-1 to 2-53.

BUILDING NAME	TRANSFORMER CAPACITY (GALLONS)
5P-1X 147	6991
AG/BIO	605
ALUMNI HOUSE	150
ATHLETIC FACILITIES	113
BABBIDGE LIBRARY	294
BABBIDGE LIBRARY	605
BABBIDGE LIBRARY	605
BASKETBALL FACILITY	388
BEACH	189
BENTON	365
BIO 4	198
BIO 4 ANNEX	330
BIO PHARMACY	490
BIO PHARMACY	490
BUCKLEY	327
BUDDS BLDG	157
BURTON COMPLEX	348
CENTRAL UTILITY PLANT	1331
CENTRAL UTILITY PLANT	93

BUILDING NAME	TRANSFORMER CAPACITY
CENTRAL WAREHOUSE	(GALLONS)
CHARTER OAKS APTS	189
CHARTER OAKS APTS CHARTER OAKS APTS	364
CHARTER OAKS APTS	189
CHARTER OAKS APTS	351
CHARTER OAKS APTS	
	189
CHARTER OAKS APTS	189
CHARTER OAKS APTS	189
CO CENUSIAND	211
COLLECT OF A C	720
COLLEGE OF A.G.	189
COMMUNICATIONS	94
COMPUTER CENTER UPS	360
CO-OP	335
CO-OP EMERGENCY	435
C-PROJECT C-3-C	205
C-PROJECT C-4-C	205
C-PROJECT DINING HALL	345
C-PROJECT EM. POWER	144
CUE BLDG	465
DODD BLDG	320
ENGINEERING 1 41	430
ENGINEERING 1 42	248
ENGINEERING 1 43	179
ENGINEERING II 44	275
ENGINEERING II 45	280
E-PROJECT-SHAKESPEARE	113
E-PROJECT-TROY 39	113
FACILITIES MODULAR 46	153
FACILITIES OPERATIONS 47	195
FENTON RIVER 49	69
FENTON RIVER 50	69
FENTON RIVER 51	69
FIELD HOUSE 52	325
FINE ARTS	229
FINE ARTS	229
FINE ARTS	229
FINE ARTS	183
FINE ARTS	183
FINE ARTS	183
FOOTBALL PRACTICE FIELD53	151

BUILDING NAME	TRANSFORMER CAPACITY (GALLONS)
FOUNDATION 54	431
FRAT HOUSES-GILBERT RD 57	57
GAMPEL 55	400
GENTRY SCH. OF ED. 56	206
GILBERT RD FRAT HOUSE 58	57
GRAD DORMS 59	207
GULLEY HALL 78	124
HALE HALL	347
HALL DORM 79	347
HAWLEY ARMORY 80	215
HICKS DORM 84	124
HIGH HEAD 134	251
HILLTOP APTS #23 BPA 77	120
HILLTOP APTS #23 CPA 62	104
HILLTOP APTS #23 CPB 63	104
HILLTOP APTS #23 DPA 64	204
HILLTOP APTS #23 DPB 76	104
HILLTOP APTS #23 EPA 75	104
HILLTOP APTS #23 EPB 74	225
HILLTOP APTS #23 FPA 73	113
HILLTOP APTS #23 FPB 67	113
HILLTOP APTS #23 GPA 68	204
HILLTOP APTS #23 GPB 69	104
HILLTOP APTS #23 HPA 66	104
HILLTOP APTS #23 HPB 65	113
HILLTOP APTS #23 IPA 70	204
HILLTOP APTS #23 JPA 72	113
HILLTOP APTS #23 JPB 71	113
HILLTOP APTS 60	113
HILLTOP APTS 61	113
HILLTOP SUITES 85	324
HORTICULTURE STORAGE 87	113
HUMAN DEVELOPMENT 31	129
HUSKY VILLAGE #1 88	250
HUSKY VILLAGE #2	250
HUSKY VILLAGE 90	250
ISLAMIC CENTER	130
JONES ANNEX	206
JONES BUILDING	50
JONES BUILDING	50
JONES BUILDING	50

BUILDING NAME	TRANSFORMER CAPACITY (GALLONS)
JORGENSON AUD.	295
K-LOT	172
KOONS HALL	193
McCONAUGHY HALL	438
MCMAHON HALL	295
MOTOR POOL	208
MUSIC LIBRARY	255
NATE KATTER THEATER	351
NATHAN HALE INN	191
NEW CHEMISTRY	500
NEW CHEMISTRY	500
NORTH CAMPUS (LITCHFIELD)	347
NORTH PARKING GARAGE	263
OAK HALL	440
OAK HALL	225
ORCHESTRA-BAND	345
PUBLIC SAFETY	152
RADIO TOWER	45
RADIO TOWERS	63
RADIO TOWERS	42
RYAN REFECTORY	345
SEWAGE PLANT	373
ICE RINK	221
STADIA #1 (SOCCER)	339
STADIA #2 (SOFTBALL)	244
SOUTH CAMPUS BLDG A	254
SOUTH CAMPUS BLDG B	254
SOUTH CAMPUS C	254
SOUTH CAMPUS CHILLER	338
SOUTH CAMPUS D	344
SPARE	205
STORRS HALL	418
TOWER GENERATOR	250
TOWERS #1	331
TOWERS #2	331
TOWERS #5	331
TOWERS #6	331
TOWERS DINING HALL	411
TOWERS LOOP PUMP ST.	355
TOWERS STUDENT	193
TRACK AND FIELD	280

BUILDING NAME	TRANSFORMER CAPACITY (GALLONS)
VON DER MEHDEN HALL	229
WARING CHEMISTRY	175
WARING CHEMISTRY	209
WILBUR CROSS	302
WOOD HALL	179

3.5 Elevator Tanks

In general, elevator tanks use hydraulic fluid for their operation. At the UConn Storrs campus, the elevator systems have a hydraulic oil reservoir with a capacity to hold between 55 and 328 gallons. Similar to transformers, reservoirs associated with hydraulic elevators are considered oil-filled operational equipment and not considered bulk oil storage containers per 40 CFR 112.2 because their contents are "in use". Therefore, these hydraulic reservoirs are exempt from secondary containment requirements. The oil reservoirs for each elevator system are contained within an interior room with cinder block walls and coated concrete floors. The elevator shaft sumps are designed to contain any oil discharges from the elevator piston system. Otis Elevator Company inspects the elevators on an annual basis. The following elevator hydraulic tanks with a capacity greater than 55 gallons are present at the UConn Storrs Campus with a total capacity of approximately 13,650 gallons.

	ELEVATOR	TANK SIZE
BUILDING NAME	MANUFACTURER	(GALLONS)
PUTNAM REFECTORY	GENERAL	70
WILBUR CROSS #2	KONE	100
WILBUR CROSS #3	KONE	100
WILBUR CROSS #4	KONE	100
JORGENSEN AUDITORIUM #1	GENERAL	130
JORGENSEN AUDITORIUM #2	MONTGOMERY	125
BENTON MUSEUM	MONTGOMERY	90
KOONS HALL	OTIS	85
LIFE SCIENCES	ELEVATOR SYSTEMS	277
PATHOBIOLOGY #1	MONTGOMERY	165
PATHOBIOLOGY #2, ATWATER	MONTGOMERY	193
STORRS HALL	DOVER	100
BABBIDGE LIBRARY, NORTH #1	SCHINDLER	110
BABBIDGE LIBRARY, NORTH #2	SCHINDLER	110
BUDDS	MONTGOMERY	90
DODD RESEARCH #1	MONTGOMERY	85
DODD RESEARCH #2	MONTGOMERY	110
GULLEY HALL	MCE	110
HUMAN DEVELOPMENT CTNR.	MONTGOMERY	100

DUIL DING NAME	ELEVATOR	TANK SIZE
FINE ARTS	MANUFACTURER OTIS	(GALLONS)
HICKS BUILDING	MONTGOMERY	175
JONES BUILDING	MONTGOMERY	175
MUSIC LIBRARY #1	MONTGOMERY	144
MUSIC LIBRARY #2	MONTGOMERY	144
MUSIC/DRAMA (ORCHESTRA BAND)	MONTGOMERY	127
WHITE BUILDING, DIARY MANUF.	MONTGOMERY	132
FACILITIES OPERATIONS	MONTGOMERY	95
GAMPEL #1	ALLIED/BAXCO	95
GAMPEL #2	ALLIED/BAXCO	130
MCCONAUGHY HALL (NC)	DOVER	121
NORTHWEST QUAD/BATTERSON	KONE	124
NORTHWEST QUAD/GOODYEAR	KONE	124
NORTHWEST QUAD/HANKS	KONE	124
NORTHWEST QUAD/ROGERS	KONE	124
NORTHWEST/QUAD KITCHEN	KONE	122
NORTHWEST QUAD/DINING	KONE	124
NORTHWEST QUAD/RUSSELL	KONE	124
NORTHWEST QUAD/TERRY	KONE	124
SOUTH CAMPUS "A" #1	SCHINDLER	118
SOUTH CAMPUS "B" #1	SCHINDLER	118
SOUTH CAMPUS "B" #2	SCHINDLER	118
SOUTH CAMPUS "C" #3 SOUTH CAMPUS "D" #4	SCHINDLER SCHINDLER	118 229
SOUTH CAMPUS "D" #5, KITCHEN	SCHINDLER	229
SOUTH CAMPUS PARK GARAGE	KONE/MCE	328
SOUTH CAMPUS PARK GARAGE	KONE/MCE	328
HILLTOP SUITES	KONE	121
HILLTOP SUITES	KONE	121
TOWER MORGAN HOUSE	KONE	168
CHARTER OAK	TYSSEN	85
CHARTER OAK	TYSSEN	85
CO-OP	KONE	238
CO-OP	KONE	238
INFORMATION TECHNOLOGY	KONE	125
ENGINEERING I	GENERAL	65
ENGINEERING II #1	GENERAL	192
ENGINEERING II #2, UTEB	OTIS	238
ENGINEERING II #3	MONTGOMERY	65
ENGINEERING III	GENERAL	150
EDUCATION, SCHOOL OF	EASTERN	90
BEACH HALL	EASTERN/GENERAL	60
SOCIAL SCIENCES, MONTEITH	MCE	85
SPEECH CENTER	GENERAL SYSTEMAS	60
SHIPPEE HALL #1	OTIS/ELEVATOR SYSTEMS	85

BUILDING NAME	ELEVATOR MANUFACTURER	TANK SIZE (GALLONS)
SHIPPEE HALL #2	OTIS/ELEVATOR SYSTEMS	85
CENTRAL WAREHOUSE	KONE	95
BUSINESS, SCHOOL OF, SOUTH	OTIS	95
BUSINESS, SCHOOL OF, NORTH	OTIS	95
HUMANITIES, ARJONA	MCE	85
BISHOP CENTER, CONT. EDU.	OTIS	90
YOUNG BUILDING	OTIS	217
PARKING GARAGE, NORTH #1	OTIS	210
PARKING GARAGE, NORTH #2	OTIS	210
PARKING GARAGE, NORTH #3	OTIS	210
AGBIOTECH #1	OTIS	120
AGBIOTECH #2	OTIS	216
AGBIOTECH #3	OTIS	125
PUBLIC SAFETY COMPLEX	OTIS	90
FIELD HOUSE #1	OTIS	100
FIELD HOUSE #2	OTIS	100
STUDENT UNION	OTIS	269
STUDENT UNION	OTIS	269
STUDENT UNION	OTIS	269
STUDENT UNION	OTIS	202
WARING	DOVER	80
ALUMNI #1	OTIS	90
ALUMNI #2	OTIS	90
FOOTBALL PRACTICE	OTIS	125
FOOTBALL PRACTICE	OTIS	125
FOOTBALL PRACTICE	OTIS	125
LAKESIDE	OTIS	125
RYAN	OTIS	125
COGEN	OTIS	130
BASKETBALL PRACTICE FACILITY	OTIS	125
BASKETBALL PRACTICE FACILITY	OTIS	125
BASKETBALL PRACTICE FACILITY	OTIS	125
ROWE BUILDING	N/A	217
FAMILY STUDIES BUILDING	N/A	144
WERTH TOWER	N/A	238

Spill Prediction [112.7(b)]

In general, the most likely discharge of oils from hydraulic elevators would occur due to losses of hydraulic fluid within the piston unit or hydraulic lines and would discharge to the floor of the elevator rooms. In most cases, any release would be limited in volume to the capacity of the elevator tank and would be confined to the floors of the elevator rooms and adjacent rooms.

Spill Prevention Measures [112.7(a)(3)(ii)]

The hydraulic oil reservoirs are inspected annually, in accordance with Section 4.1 of this Plan.

Spill Control Measures [112.7(a)(3)(iii)]

There are no floor drains present in any of the first floor or basement elevator rooms. UConn coated the floors on the elevator rooms with epoxy and installed curbing at the doors to contain oil during a potential spill.

Uncontrolled spills and releases will be confined to the floors of the elevator rooms. A spill contractor will be called in to clean-up any significant release of hydraulic oil contained within the building in accordance with Section 7.

In the unlikely event that the release of hydraulic oil escapes the building, it may flow over impervious pavement towards the nearest catch basin or pervious area.

Spill Countermeasures [112.7(a)(3)(iv)]:

Any spills or leaks from the elevator hydraulic reservoirs will be identified, contained to the extent feasible, and will be promptly cleaned up by properly trained UConn Facilities staff, UConn Fire Department, or an outside spill response contractor in accordance with Section 7.0 of this Plan.

3.6 Spill History

According to 40 CFR 112.7(a), a facility which has experienced one or more spill events within twelve months should include a written description of each such spill, corrective action taken, and plans for preventing a recurrence.

According to UConn records, all identified releases can be considered minor spills of petroleum substances (<1,000 gallons in a single discharge or two (2) 42-gallon discharges in a twelve month period) with no known releases to navigable waterways. Please see **Appendix E** for UConn's spill history log.

4.0 INSPECTIONS AND SECURITY

4.1 Inspections, Tests, and Records (40 CFR 112.7(e))

The inspection, evaluations, and testing requirements of the SPCC regulations are intended to prevent, predict, and detect potential integrity or structural issues before they cause a leak, spill, or discharge of oil to navigable waters. Regularly scheduled inspections, evaluations, and testing by qualified personnel

are critical parts of oil discharge prevention. They are conducted not only on containers, but also on associated piping, valves, and appurtenances, and on other equipment and components that could be a source or cause of an oil discharge. UConn must ensure that the required inspections are accomplished and that the appropriate documentation and reports are prepared.

Underground Storage Tanks (USTs)

UConn Storrs conducts and inspects the conditions of underground storage tank systems in accordance with the CT DEEP UST Regulations (22a-449(d)-1 to 22a-449(d)-113) and Petroleum Equipment Institute (PEI) RP900 "Recommended Practices for the Inspection and Maintenance of UST Systems" which includes monthly and annual inspections. The inspections must be completed by an experienced and qualified inspector. The inspector can recommend appropriate repairs to the tank system(s) or increase to the tank inspection frequency as warranted by the findings of the inspections.

Inspections must include the following items:

Inspect	Conditions to Evaluate
Primary tank, interstice, sump and spill container	*Presence of water
Vents/vent risers	Free of obstruction
Tank pad	Cracking and/or spalling
Leak detection systems or other monitoring or warning systems	Proper function
Cathodic protection	Readings of –0.85 volts or lower
Fuel dispenser hoses	Tears, leaks, defects of any kind
Fuel dispenser cabinet interiors	Leaks
Tank gauges and Overfill prevention devices	In place and functioning properly
Security measures	In place, if present
Spill response equipment	Present and fully stocked

^{*}Water found within the sump and/or spill container is inspected for oil sheen or contamination as defined in 40 CFR, Part 110, and that the water complies with all applicable local or state regulations. If the liquid is clean, it is pumped onto the surrounding area. If contamination is present, then the liquid is disposed in a legal and proper manner.

The Oil Pollution Prevention regulations require that inspections and tests be conducted in accordance with written procedures that are developed by the facility or certifying engineer. The annual Underground Storage Tank Inspection Checklist is provided in **Appendix A**. The inspection log sheets must be completed and signed by the person conducting the inspection. The original signed inspection reports are maintained by Environmental Health & Safety. A record of UST inspections and tests, signed

by the appropriate supervisor or inspector, are kept in EHS Environmental Programs electronic files in accordance with CT DEEP UST record keeping requirements.

Motor Pool USTs

The UConn Storrs Campus personnel perform and record daily inventories and weekly reconciliations for the motor fuel USTs at Motor Pool. Each weekly reconciliation includes (1) an assessment of the presence of water, oil use, deliveries, inventory, and any unexplained losses or gains, (2) an assessment whether oil or water is present in the interstitial space of the UST, and (3) confirmation that the interstitial space monitoring system is properly operating. Daily losses or gains exceeding one-half of one percent of the total volumetric capacity of the UST system are considered "abnormal" and must be investigated and reported to the CT DEEP as potential leaks per RCSA Section 22a-449(d)-104(b)(3).

Aboveground Storage Tanks (ASTs)

UConn conducts an inspection and monitoring program following the Steel Tank Institute's (STI) *Standard for Inspection of Aboveground Storage Tanks* [STI- SP001 (January 2018), 6th Edition] with recommended deviations by the professional engineer. Based on the visible and secure locations of the tanks, secondary containment, alarm systems, and the results of prior inspections, UConn Storrs conducts and inspects the condition of aboveground storage tank systems on a monthly basis, except for oil-filled equipment (AST-36 and AST-143) which are inspected on a quarterly basis. At least one of the monthly inspections performed on an annual basis must include all additional, relevant tank elements listed on the STI annual inspection checklist. The inspections must be completed by an experienced and qualified inspector. The inspector can recommend appropriate repairs to the tank system(s) or increase the tank inspection frequency as warranted by the findings of the inspections. Inspections must include the following:

Inspect	Conditions to Evaluate
Exterior surfaces of tanks, pipes, valves, and other equipment (valves and piping, including flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces)	Cracks, areas of wear, corrosion and thinning, leaks, maintenance deficiencies, excessive settlement, separation or swelling of tank insulation
Leak detection systems, cathodic protection monitoring equipment, or other monitoring or warning systems	Proper function
Tank supports and foundations	Structural and foundation weaknesses

Inspect	Conditions to Evaluate
Tank gauges	In place and functioning properly
Condition of secondary containment	*Intact and no fluid
Drain plugs	In place, if necessary as part of the
Security measures (e.g., fill box covers locked)	design, secured and tight
Spill response equipment	Present and fully stocked

^{*}Water found within the sump and/or spill container is inspected for oil sheen or contamination as defined in 40 CFR, Part 110, and that the water complies with all applicable local or state regulations. If the liquid is clean, it is pumped onto the surrounding area. If contamination is present, then the liquid is disposed in a legal and proper manner.

The SPCC regulations require that inspections and tests be conducted in accordance with written procedures that are developed by the facility or certifying engineer. The monthly Aboveground Storage Tank Inspection Checklist is provided in **Appendix A**. The inspection log sheets must be completed and signed by the person conducting the inspection. The original signed inspection logs are maintained in the EHS Environmental Programs electronic files as detailed in Section 1.4. A record of inspections and tests, signed by the appropriate supervisor or inspector, must be kept with the SPCC Plan for a period of three years (40 CFR Section 112.7(e)).

Aboveground Tank Periodic Integrity Testing

In addition to visual inspections of the aboveground bulk oil storage tank systems, bulk storage containers must be tested for integrity whenever material repairs are made. In accordance with STI SP001, the ASTs at the UConn Storrs Campus do not require periodic integrity testing due to their size and construction. Monthly visual inspections will be sufficient in detecting conditions that pose a risk to the environment. Bulk container integrity testing records must be kept for the life of the container. EHS Environmental Programs maintains comparison records of visual and integrity tests. This facility must also conduct integrity and leak testing of buried piping at the time of installation, modification, construction, relocation, or replacement.

Drum Storage

Based on the visible and secure locations of the drums and drum storage, UConn Storrs visually inspects the condition of the drums and drum storage areas on at least a monthly basis. Drums that are found to show signs of leaks, dents, or corrosion, or compromised integrity are replaced immediately. Visual inspections of drum storage area are sufficient and meet SPCC requirements based on their secure locations, secondary containment, and the frequency that UConn personnel manage these oil drums.

The monthly Drum Storage Area Inspection Checklist is provided in Appendix A.

Transformers

The transformers will be informally inspected periodically by UConn Storrs Campus Facilities Operations personnel on a quarterly basis and will be formally inspected by an electrician and outside contractor on an annual basis. Personnel inspecting the transformers look for conditions that pose the potential of a spill to the environment and will conduct preventive maintenance when necessary.

Elevators

Based on the design of the elevator shaft sumps and their capability to contain any oil discharges from the elevator piston system Otis Elevator Company inspects the elevators on an annual basis.

4.2 Security (40 CFR 112.7(g))

The UConn Storrs Campus is staffed on a 24-hour, 7-day per week basis including weekends and holidays by the UConn Police Department. Site buildings are covered with surveillance cameras monitored by UConn Police Department. Service agreements for monitoring fire alarms and building equipment are also in place. In accordance with these agreements, facility call lists are utilized to respond to alarms and equipment malfunctions.

Bulk storage containers are located throughout the UConn Storrs Campus. Aboveground tanks are typically located in secure fenced in areas or within the confines of a building or generator enclosure and/or have locked fill ports. Facility lighting is adequate to assist in the discovery of discharges during hours of darkness and to prevent discharges occurring through acts of vandalism.

Any valve which would allow the direct outward flow of oil from a tank to water or land are effectively blocked either by blank flanges or caps, or they are locked in the closed position. Loading and unloading connections are securely capped when not in use.

Starter controls for oil pumps are located within secured areas where only authorized UConn Storrs Campus personnel have access. Starter controls on oil pumps are maintained in the "off" position when the pumps are in a non-operating or non-standby status.

5.0 OIL HANDLING PROCEDURES

5.1 Tank Car/Truck Loading/Unloading Rack (40 CFR 112.7(h)

The UConn Storrs Campus does not have any tank car/truck loading/unloading racks; therefore, the requirements of 40 CFR 112.7(h) are not applicable.

5.2 Tank Truck Loading/Unloading (40 CFR 112.7(a)(3)(ii))

Tank truck unloading operations take place at most of the tanks at the UConn Storrs Campus.

Building	Capacity (gal)	Delivery Frequency	Transfer Description
Emergency Generator Tanks			
UST-3 Mansfield Apartment Lift Station	600	Minimal,	The UConn-owned
UST-10 Beach Hall	2,000	unless there is	mobile supply truck
UST-13 Biobehavioral #4 Annex	1,500	unplanned	unloads from the
UST-14 Commissary Warehouse	1,000	emergency	parking area, driveway,
UST-16 Eastwood Road Lift Station	600	use.	or roadway nearest to
UST-18 Fenton River well field Pump Station	3,000		tank fill port. Truck
UST-32 Northwood Apartment Lift Station	600		unloading operations
UST-45 WPCF	2,500		are conducted by
AST-38 Gampel Pavilion	500		UConn personnel.
AST-47 IMS/Gant Building	275		
AST-48 Jorgenson	185		
AST-56 South Campus Chiller Plant Generator	1,000		
AST-77 North Garage Generator	200		
AST-130 Public Safety Building	400		
AST-131 Reclaimed Water Facility	1,000		
AST-132 Willimantic well field Pump Station	1,000		
AST-133 Nextel Radio Towers	330		
AST-134 Infirmary Portable Emergency Generator	342		
AST-135 Student Recreational Center/Fieldhouse Fire Pump	150		
AST-140 Edwards Freitas Ice Forum (Ice Rink)	150		
AST-144 High Head Lift Station	1,500		
AST-145 Isolation Farm	209		
AST-147 Gurleyville Lift Station	1,727		
AST-153 Hockey Arena	260		
AST-154 Public Safety Building	600		
AST-35 Taylor Portable	300		Portable generators
AST-126 Electric Mobile Portable	150		filled at Motor Pool
			fueling station.

Heating Fuel Tanks			
UST-46 WPCF	2,500	Automatic	Contractor (please see

UST-35 Plant Science Research	1,000	delivery	additional info below)
UST-36 Plant Science Research	1,000		
UST-40 Spring Hill Isolation Farm	1,000		
UST-41 Spring Hill Isolation Farm	1,000		
AST-55 Mink Barn	330		
AST-59 Plant Science Research	275		
Motor/Equipment Fuel			
UST-29 Motor Pool (Gasoline)	10,000	Automatic	Contractor (please see
UST-28 Motor Pool (ULSD)	10,000	delivery	additional info below)
AST-57 Plant Science Research Barn (ULSD)	275		
AST-152 Farm Services (ULSD)	2,500		
Generator & Heating Fuel Tanks			
UST-20 Central Utility Plant	50,000	Automatic	Contractor (please see
UST-21 Central Utility Plant	50,000	delivery	additional info below)
UST-22 Central Utility Plant	50,000		
UST-23 Central Utility Plant	50,000		
UST-24 Central Utility Plant	50,000		
UST-25 Central Utility Plant	50,000		
UST-15 Dodd Research Center	4,000		
UST-39 Psychology	2,000		
UST-52 Supplemental Utility Plant	30,000		
Other			
AST-50 Motor Pool (Waste Oil)	1,000	Automatic	Contractor (please see
AST-51 Motor Pool (Engine Oil)	275	delivery	additional info below)
AST-127 Motor Pool (Transmission Oil)	275		
AST-142 Motor Pool (Engine Oil)	275		
AST-149 Mobile Supply Fuel Truck	100	Performed on	The UConn-owned mobile
		an as needed	supply truck filled at motor
		basis	pool and unloads to other
			storage tanks at the
			campus.

Tanker unloading operations are conducted by both UConn Facilities Operations and a contracted outside fuel supplier. When tanker unloading operations at Motor Pool, Farm Services and the Central Utility Plant are conducted by outside fuel supplier, delivery personnel must notify UConn personnel prior to start of transfer. A UConn staff member provides access to the tank fill location, verifies the fuel delivery amount, and ensures that there is adequate spill control equipment present in the event of a spill during fueling. In locations where there is a catch basin in close proximity and at the same elevations or downgradient from a fill site, the UConn staff member or driver must place a portable spill dike and/or catch basin drain blocker mat, which will be available with spill kit materials at these fill locations. In the event of a release from the fuel delivery truck or overfilling of the tanks, these devices will aid in preventing spilled fuel oil from entering the storm drainage system. Both the UConn personnel

and the driver inspect tank gauges and fuel levels prior to filling to ensure that the volume available in the tank is greater than the volume of fuel to be transferred. During the transfer of fuel to the storage tanks, the driver conducts continuous inspections of the tank truck and the receiving tank to reduce the potential for spillage and overfilling.

All waste grease tank unloading operations to tanker trucks for disposal are performed by an outside contractor and follow the procedure used for bulk fueling operations.

The following are practices that must be followed during all bulk fueling operations:

General:

- 1. Park vehicle as close as possible to the fill pipe or tank and use the minimum length of hose necessary to complete the connection with no tension on the hose or connectors.
- 2. Verify that the emergency spill containment equipment is fully stocked at a nearby accessible location.
- 3. Verify that the temporary spill containment structures have been installed as required including placing catch basin mats or deploying portable spill dikes retrieved from the spill kit.

Prior to Transfer:

- 1. Secure the loading vehicle prior to transfer operations with physical barriers such as wheel chocks and interlocks. Make sure that the parking brakes of the tank truck are set.
- 2. Determine tank capacity by level indicator or taped measurement and tank gauge chart. Verify that sufficient volume is available in the storage tank for planned delivery amount.
- 3. Only use hoses that are in good condition. Visually check all fuel transfer hoses for leaks and wet spots.
- 4. Keep hose ends tightly capped while moving hoses into position.

During Transfer:

- 1. When transferring oils/liquids, shut off motors or auxiliary or portable pumps when making and breaking hose connections.
- 2. Monitor all hoses and hose couplings for leaks.
- 3. Monitor the liquid level in the receiving tank during filling operations to prevent overflow.
- 4. Do not top off tank. Provide a minimum of 5% free space within the tank to prevent leakage due to thermal expansion.

After Transfer:

- 1. Close all tank and vehicle valves before disconnecting.
- 2. Prior to vehicle departure confirm that all connections and fill lines are disconnected.
- 3. Inspect the outlets for evidence of leakage.
- 4. Make sure that the hoses or other connecting devices are drained, vented, or blown down to remove the remaining fuel before moving them away from their connections.

- 5. Use a drip pan, pail, and/or oil absorbent pads to prevent spillage to ground when breaking a hose connection.
- 6. Cap the end of the hose or other connecting devices before moving them to prevent uncontrolled fuel leakage.
- 7. Soak up any spilled or dripped oil from in or around the fill box and secure the fill box cover.
- 8. Properly dispose of any used clean-up material generated during fuel transfer.

5.3 Facility Transfer Operations Pumping and Facility Process (40 CFR 112.8(d) and 112.12(d))

Requirements that apply to valves, appurtenances, piping, and transfer operations at onshore facilities that handle petroleum oils are described in Section 112.8(d). Similar requirements are described in Section 112.12(d) for piping at onshore facilities that handle animal fats and/or vegetable oils. These provisions of the SPCC rule require that owners and operators of facilities generally protect buried piping against corrosion; cap or blank-flange the terminal connection of piping that is not in service; design pipe supports to minimize abrasion and corrosion and allow for expansion and contraction; regularly inspect all aboveground valves, piping, and appurtenances; and take corrective action when corrosion damage is found. The rule also requires integrity and leak testing of buried piping at the time of installation, modification, construction, relocation, or replacement. Finally, the rule requires warning all vehicles entering the facility to ensure that they will not endanger aboveground piping (or other oil transfer operations). Facility transfer operations are limited to the conveyance of oil from the fill ports to the associated tanks and from the tanks to the associated fuel-burning equipment (boilers or generators). Unusual conditions, leaks, or other problems with piping and valves will be documented during the monthly visual tank inspections and immediately corrected. Fuel transfer piping servicing these ASTs is located in such a manner that damage due to vehicular traffic is unlikely.

Aboveground piping and valves associated with boiler and generator operations at the facility are visually inspected on a weekly basis. Unusual conditions, leaks, or other problems with piping and valves would be documented in the facility's boiler log maintained by personnel at the facility. In addition, the piping is in highly visible areas where a fuel leak would be seen by facility personnel during routine operations.

Transfers in association with drums are primarily manual. Unusual conditions, leaks, or other problems will be discovered immediately.

5.4 Drum Loading/Unloading

Activities involving drum loading and unloading are performed at UConn Storrs Campus and it is UConn's

policy that such activities be conducted in accordance with the following general procedures and practices, as applicable:

- 1. Drum covers are secured and tightened prior to moving.
- 2. Surrounding floor is clean and dry prior to removing drums from pallets or placing drums on pallets.
- 3. Ramps and proper tools (i.e. dollies, forklifts) are used to lift drums from top of pallets onto ground level (or vice versa).
- 4. No tools that could puncture or perforate the drum are used during drum movement.
- 5. Catch basins, floor drains and drainage pathways are protected with booms and/or drain cover/mats during drum loading/unloading activities.

6.0 PERSONNEL TRAINING (40 CFR 112.2(f))

UConn's EHS Environmental Programs is responsible for properly instructing Storrs oil-handling personnel at least once a year. Training is provided annually on oil discharge prevention, control, and emergency response. UConn personnel who are responsible for accompanying the fuel supply vendor during fueling operations, and the regular inspection and maintenance of the tank systems should be trained in the tank loading procedures, the use of the spill containment/response equipment, and the proper spill notification and reporting procedures. UConn personnel should also be familiar with this SPCC Plan to ensure that in the event of a spill, they are capable of following the appropriate procedures for spill response and reporting. SPCC training should be conducted for the above-identified personnel, whenever new personnel are assigned the above responsibilities.

Records of all SPCC training and briefings shall be maintained by UConn Facilities Operations and EHS – Environmental Programs to document compliance with these requirements. A copy of example training, and log sheets are included in **Appendix B**.

7.0 SPILL RESPONSE (40 CFR 112.7(a))

7.1 Overview

The UConn Storrs Campus Fire Department is the primary emergency response provider and responds to oil spills, regardless of quantity, 24 hours a day. If a major oil release occurs at the facility, the UConn Storrs Campus Fire Department would contact one of several spill response contractors in accordance with the UConn Storrs Campus Hazardous Waste Contingency Plan, a copy of which is maintained at the Fire Department and at EHS – Environmental Programs. Trained Storrs Campus Facilities Operations and Fire Department personnel may respond to small leaks or spills that do not pose a significant risk to health or safety and can be cleaned up easily.

7.2 Reporting a Discharge

For any spill that occurs at the UConn Storrs Campus, The Fire Department, Office of Environmental Policy Department and Environmental Health and Safety Department should be notified. The contact information is below:

Name/Department	Title	Phone Number
UConn Fire Department	Central Dispatch	911
Paul Ferri	Manager – EHS	Office: 860-486-9295
Environmental Health & Safety Department	Environmental Programs	Cell: 860-573-7842
Terri Dominguez	Director of Environmental	Office: 860-486-0981
Environmental Health & Safety	Health & Safety	Cell: 860-234-3514
Department		

Additionally, a copy of the Public Safety/EHS after hours communication decision chart is included in **Appendix C**.

The following information should be provided when reporting a spill/leak:

- Time of discharge
- Injury to personnel
- Nature of the spill or leak including source and cause
- Materials involved
- Location of the spill or leak
- Amount and extent of the spill or leak, the approximate amount spilled, and the direction the liquid flow is moving
- Actions being taken to stop, remove, and mitigate the effects of the discharge

Names of other individuals and/or organizations who have also been contacted

7.3 Spill Control Equipment

Emergency spill control and response equipment is available at the following locations:

- Motor Pool
- Central Utility Plant
- Farm Services
- Public Safety Building (Fire/Police Department)
- Facilities Shop
- Water Pollution Control Facility
- Main Accumulation Area
- All Dining Services locations
- Facilities Operations Fueling Vehicle (portable kit)

Spill kits are available to contain small spills from the tanks and tanker trucks during unloading operations. The spill kits are inspected monthly and replenished as needed. The following is a list of spill control equipment:

- Speedi-Dry (or ShopDri Floor Sweep)
- Oil Sorbent Booms
- Oil Sorbent Pads
- Protective Gloves
- Safety Glasses Goggles
- Catch Basin Drain Blocker Mat
- Disposable bags

7.4 Control Release of Oil

The Facilities Manager, or designee, shall fully evaluate the spill event and determine whether the spill may be addressed using properly trained facility staff and spill response materials or whether outside assistance is necessary.

If the spill is of a known oil product (e.g., ULSD, diesel fuel, gasoline, etc.), the oil handling personnel identifying the release has been trained on the use of the spill containment equipment (i.e., attended annual discharge prevention briefings per Section 6.0), and the spill can be controlled at the time of the release without the employee endangering themself or any other person in any way, then the individual shall take immediate action to control the release. If the spill is of a chemical or an unknown substance, the individual identifying the release shall alert the individuals in the area, restrict access to the area of the spill, and contact the UConn Fire Department for further evaluation and response actions.

For a spill or leak that is small enough to be absorbed, neutralized or otherwise controlled at the time of release by employees in the immediate release area or by maintenance personnel, and does not pose an adverse exposure hazard to employees, the spill will be handled in the following manner:

- a. Make sure all uninvolved persons are removed from the hazard area. Workers involved in the cleanup shall put on protective clothing and equipment (e.g., gloves, safety glasses).
- b. If flammable vapors can be generated, remove all ignition sources, and use spark- and explosion-proof equipment and clothing in containment and cleanup.
- c. If possible, try to stop the leak.
- d. Use absorbent pads, booms, earth, sandbags, sand, and other inert materials to contain, divert, neutralize, and clean up the spill. If spilled material reaches a storm sewer, try to stop the flow from the source by using diking, booms, mats, absorbent pads, sand, earth, sandbags, etc.

7.5 **Emergency Response**

For spills or leaks that cannot be controlled by facility resources, or for events beyond the capability of UConn personnel, the following procedures must be followed.

- a. Call emergency response including UConn Fire Department and UConn Police Department for all spills. If any personnel are injured, request ambulance service.
- b. Contact the Facilities Manager.
- c. Contact EHS Environmental Programs.
- d. Contact one of the private emergency response contractors listed in **Appendix D** and ask them to dispatch emergency personnel to the site to take appropriate action.
- e. Contact the proper authorities to report the spill or release as indicated in Section 7.7 and 7.8.

7.6 Disposal of Clean-up Material

- a. Place all containment and cleanup materials in appropriately labeled drums or other suitable container and hold in a secure location for proper disposal.
- b. Place all recovered liquid wastes in appropriately labeled drums and hold in a secure location for removal to an approved disposal facility.
- c. Contact UConn Environmental Health & Safety (860-486-3613) to arrange for proper disposal of waste generated during cleanup.
- d. Following cleanup, all emergency equipment and spill containment equipment shall be returned to ready status (restocked).

7.7 <u>Discharge Notification</u>

The Spill Coordinator will be responsible for completing necessary spill reporting (oral and/or written) to the appropriate regulatory authority.

Federal Spill Reporting

In the event that a spill of oil has reached navigable waters in harmful quantities, as defined in Section

1.0 of this document and in accordance with federal regulations (40 CFR Section 110.6), the Federal National Response Center (NRC) must be immediately notified.

National Response Center (NRC) 24 Hour #: (800) 424-8802

When contacting the NRC, the following information should be provided:

- Time, location and source of the spill,
- Type and quantity of material spilled,
- Cause and circumstances of the spill,
- Hazards associated with the spill,
- Personal injuries,
- Corrective action taken or planned to be taken,
- Name and telephone number of individual reporting the spill, and
- Any additional pertinent information.

The United States Environmental Protection Agency (EPA) Region I Response Center should be contacted immediately for any spill that reaches navigable waters (per 40 CFR 110.6) at the following number:

U.S. EPA Region I Response Center 24 Hour #: (617) 223-7265 Toll Free #: 888-372-7341

In addition to the above requirements, within 60 days a report shall be filed with the US EPA if either of the following criteria applies to the spill (per 40 CFR Section 112.4):

- a) more than 1,000 gallons of oil were discharged into or upon the navigable waters of the United States or adjoining shorelines in a single spill event, or
- b) more than 42 gallons of oil were discharged in each of two discharges in harmful quantities, into or upon the navigable waters of the United States or adjoining shorelines occurring within any 12-month period. Note that the 12-month period is a rolling period. This means that each discharge described herein triggers the start of a new 12-month period.

Should this facility have an event that falls under this provision, UConn EHS – Environmental Programs will prepare and submit the required report to the U.S. EPA Regional Administrator, within 60 days from the time the facility becomes subject to this provision. The report shall be addressed as follows.

United States Environmental Protection Agency
Region 1
5 Post Office Square
Suite 100
Boston, MA, 02109-3912

Copies of the report provided to US EPA will be kept on file with UConn EHS – Environmental Programs and with the UConn Facilities Operations office.

EPA requires the following information to be detailed in the oil spill report:

- Name and location of facility
- Names(s) of the owner or operator of the facility
- Maximum storage/handling capacity of the facility and normal daily throughput
- Description of the facility (including maps, flow diagrams, and topographical maps)
- The cause(s) of such discharge (including a failure analysis of the system or subsystem in which the failure occurred)
- Exact type and quantity of oil spilled
- The corrective actions and/or countermeasures taken (including a description of equipment repairs and/or replacements)
- Additional preventive measures taken or contemplated to minimize the possibility of recurrence, and
- Any other information as requested the U.S. EPA Regional Administrator

A copy of the US EPA Oil Spill Report Form is also included in **Appendix F**.

Connecticut DEEP Spill Reporting

In addition to the federal reporting requirements, Connecticut DEEP recently issued release reporting regulations (RCSA 22a-450-1 to 22a-450-6, effective March 4, 2022), that require spills or releases of oil or petroleum at "reportable quantities" must be reported to CT DEEP with some exceptions. Depending on the quantity of oil released, location of release (e.g. to secondary containment, to wetland or waters of the state, to ground, etc.) and other applicable criteria (e.g., time to contain, mitigate, or remove the release), spills must initially be reported to CT DEEP verbally **with one hour** and in some cases, follow-up written reporting is required. The release reporting regulations provide some exceptions to reporting, including:

- Spills contained within secondary containment that are less than 100 pounds or 15 gallons, do not
 involve a UST or PCB product, do not create an emergency, and are cleaned within 2 hours of
 discovery.
- Spills of oil or petroleum products less than 5 gallons which are fully removed or mitigated within
 2 hours of detection and do not cause an impact to waters or the environment.
- Spills of non-petroleum products less than 10 pounds or 1.5 gallons which are fully removed or mitigated within 2 hours of detection and do not cause an impact to waters or the environment.

A flow chart showing the reportable quantities and Connecticut DEEP release reporting requirements is

included in Appendix F. The complete Connecticut DEEP release reporting regulations are located here:

https://portal.ct.gov/-/media/DEEP/emergency_response_spill_prevention/RRR-Final-Published-Reg.pdf

All reportable spills shall be reported within 1 hour of detection to:

Connecticut Department of Energy & Environmental Protection

Oil and Chemical Spill Response Division

Phone: (860) 424-3338

Toll Free: 1-866-337-7745

24-Hour #: (860) 424-3333

As an example of information to collect for documenting a spill, a copy of DEEP's Report of Petroleum or

Chemical Product Discharge, Spillage or Release is included Appendix F. Only if requested by CT DEEP, a

follow-up report must be submitted with the specific information requested and submitted withing sixty

(60) days, unless a different schedule is specified. Copies of any reports provided to CT DEEP will be kept

on file with the UConn EHS - Environmental Programs office and with the UConn Facilities Operations

office.

Additional environmental hazard reporting may be required to comply with Connecticut Public Act (PA)

98-134. In general, the CT DEEP is notified when a determination is made that there is an environmental

hazard above specific levels or concentrations involving contamination. UConn EHS – Environmental


Programs will review the additional Connecticut spill reporting requirements on a case-by-case basis.

FIGURES


Figure 1 Site Location Map

Figure 2 Storrs Campus Overview Map

Figures 2-1 to 2-53 Storrs Campus SPCC Site Plans




CDM Smith 1 in = 2,000 ft 0 1,000 2,000 Feet **Figure 1 - Site Location**UConn Storrs Campus
Storrs, CT





Tank ID	Building/Container	Figure Number
	Aboveground Storage Tanks (ASTs)	
AST-35	Planning Design and Construction Warehouse	2-15
AST-36	Engineering/Castleman	2-28
AST-38	Gampel Pavilion	2-36
AST-46	IMS Building - 4th Floor	2-22
AST-47	IMS Building - Loading Dock	2-22
AST-48	Jorgenson	2-28
AST-50	Motor Pool	2-15
AST-51	Motor Pool	2-15
AST-53	Psychology	2-32
AST-55	Mink Barn	2-1
AST-56	South Campus Chiller	2-43
AST-57	Plant Science/Agronomy	2-52
AST-59	Plant Science/Agronomy	2-52
AST-63	Putnam Refectory Dining	2-35
AST-64	Student Union - Bistro	2-28
AST-65	McConaughy Dining	2-16
AST-66	Whitney Dining	2-25
AST-67	Gelfenbien (Towers) Dining	2-13
AST-68	NW Dining Hall	2-16
AST-69	Shippee Dining	2-33
AST-70	Buckley Dining	2-33
AST-72	McMahon Dining	2-42
AST-73	South Campus Dining	2-37
AST-76	WPCF	2-15
AST-77	Next to North Garage	2-27
AST-80	CUP	2-23
AST-81	CUP	2-23
AST-82	CUP	2-23
AST-02	Student Union, Union Street Café	2-31
AST-124	Planning Design and Construction Warehouse	2-15
AST-120 AST-127	Motor Pool	2-15
AST-127 AST-130	Public Safety Building	2-15
AST-131	Reclaimed Water Facility	2-20
AST-132	Willimantic Well Field	2-11
AST-133	Nextel Radio Tower	2-12
AST-134	Health Services	2-23
AST-135	Fieldhouse	2-31
AST-138	Student Union, Fire & Wok	2-31
AST-139	Student Union, One Plate Two Plates	2-31
AST-140	Ice Rink	2-49
AST-142	Motor Pool	2-15
AST-143	Engineering/Castleman	2-28
AST-144	High Head Lift Station	2-3
AST-145	Isolation Farm	2-53
AST-147	Gurleyville Lift Station	2-19
AST-148	Willimantic Well Field	2-11
AST-149	Mobile Supply Fuel Truck	2-21
AST-150	Supplemental Utility Plant	2-26
AST-151	Supplemental Utility Plant	2-26
AST-152	Farm Services	2-9
AST-153	Hockey Arena	2-48
AST-154	Public Safety Building	2-22


Tank ID	Building/Container	Figure Number	
	Underground Storage Tanks (USTs)		
UST-3	Mansfield Apartment Lift Station	2-50	
UST-10	Beach Hall	2-24	
UST-13	Biology #4 - Horsebarn Hill	2-9	
UST-14	Commissary	2-25	
UST-15	Dodd Research Center	2-32	
UST-16	Eastwood Lift Station	2-51	
UST-18	Fenton Well Field	2-5	
UST-20	CUP	2-23	
UST-21	CUP	2-23	
UST-22	CUP	2-23	
UST-23	CUP	2-23	
UST-24	CUP	2-23	
UST-25	CUP	2-23	
UST-28	Outside Motor Pool	2-15	
UST-29	Outside Motor Pool	2-15	
UST-32	Northwood Apartment Lift Station	2-34	
UST-35	Plant Science	2-52	
UST-36	Plant Science	2-52	
UST-39	Psychology Building	2-32	
UST-40	Isolation Farm	2-53	
UST-41	Isolation Farm	2-53	
UST-45	WPCF	2-15	
UST-46	WPCF	2-15	
UST-52	Supplemental Utility Plant	2-26	
Drum Storage Areas			
D-1	Motor Pool	2-15	
D-2	Sludge Pump Bldg/Garage at WPCF	2-15	
D-3	SHT Bldg at WPCF	2-15	
D-4	Planning Design and Construction Warehouse	2-15	
D-5	Farm Services	2-9	
D-6	Plant Science - Lab Area	2-52	
D-7	Plant Science - Workshop Area	2-52	



























































































































































APPENDIX A

MONTHLY OIL STORAGE INSPECTION CHECKLISTS

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-35, Taylor Mobile	Date:			
Tank Location: Portable, Stored at Planning Design	Inspector	••		
and Construction Warehouse		·		
Tank Capacity/Contents: 300-gallon ULSD				
ltem		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	er?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?			<u> </u>	<u> </u>
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	nt?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	mage?			X
3.2 Tank Liquid level gauge readable and in good condition?		T		
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				Х
4.2 No cracking or spalling of concrete pad or ring wall?		T		X
4.3 Tank supports in satisfactory conditions?		T		
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				X
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?		Ţ		
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
				ı
				ļ

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-36	Date:			
Tank Location: Engineering/Castleman	Inspector:			
Tank Capacity/Contents: 135-gallon hydraulic oil				
Tank Supacity/Somenia. 100-ganon nyaraano on				
Item		Status		
1.0 Tank Containment		YES	NO	l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	er?	I ILO	NO	IN//
1.2 No debris or fire hazard in containment?	51 :	 		
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?		1		
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmer	at2			
3.0 Tank Attachments or Appurtenances	it:			
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	maga?			
3.2 Tank Liquid level gauge readable and in good condition?	mager			X
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?		 		
4.5 Grounding strap secured and in good condition?		 		
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging? 6.2 No evidence of shell/head corrosion or cracking?		<u> </u>		
6.3 No standing water on tank top?		 		
7.0 Tank Piping				
	aiam?			
7.1 Piping and connections are tight and fully engaged, no sign of wear or corro	ISION?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation? Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-38	Date:			
Tank Location: Gampel Pavilion	Inspector:			
Tank Capacity/Contents: 500-gallon ULSD				
Turn Supusity/Sometics: 500 gailer 5255				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
<u> </u>				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-46 – Day Tank	Date:			
Tank Location: IMS Building – 4th Floor	Inspector:			
Tank Capacity/Contents: 275-gallon ULSD				
Turn Supusity/Somerics. 278 gailer 8288				
		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	er?	i i		
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmer	nt?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	mage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?		i i		
4.2 No cracking or spalling of concrete pad or ring wall?		İ		
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corro	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
, , ,				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-47	Date:			
Tank Location: IMS Building – Loading Dock	Inspector:			
Tank Capacity/Contents: 275-gallon ULSD				
Turk Supacity/Someries. 275-ganon Sees				
Item		Status		
1.0 Tank Containment		YES	NO	l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?	120		1
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?	nago.			
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				<u> </u>
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				<u> </u>
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions	JIO11.			
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				<u> </u>
Comments (if any above status is NO, explain here).				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-48	Date:			
Tank Location: Jorgenson	Inspector:			
Tank Capacity/Contents: 185-gallon ULSD				
Tank Capacity/Contents. 165-gailion 0135				
Item	14	24-4		
1.0 Tank Containment		Status	NO	N1/A
	-2	YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained 1.2 No debris or fire hazard in containment?	1?			
1.3 Drain valves operable and in a closed position?				-
1.4 Containment egress pathways clear and gates/doors operable?	+			-
1.5 Containment Structure in satisfactory condition?	+			
2.0 Leak Detection				
	10			
2.1 No visible signs of leakage around the tank, piping or secondary containmen	it?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?	\rightarrow			
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?	\rightarrow			
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist			
AST Information			
Tank ID: AST-50	Date:		
Tank Location: Motor Pool	Inspector:		
Tank Conscitu/Contents: 4 000 collar wests all	<u> </u>		
Tank Capacity/Contents: 1,000-gallon waste oil			
и	lour		
Item	Status		1 21/2
1.0 Tank Containment	YES	S NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	7?		+
1.2 No debris or fire hazard in containment?			+
1.3 Drain valves operable and in a closed position?			+
1.4 Containment egress pathways clear and gates/doors operable?			+
1.5 Containment Structure in satisfactory condition?			
2.0 Leak Detection			
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?		
3.0 Tank Attachments or Appurtenances			
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?		X
3.2 Tank Liquid level gauge readable and in good condition?			
3.3 Check all tank openings are properly sealed?			
4.0 Tank Foundation and Supports			
4.1 No evidence of tank settlement or foundation washout?			
4.2 No cracking or spalling of concrete pad or ring wall?			
4.3 Tank supports in satisfactory conditions?			
4.4 Water able to drain away from tank?			
4.5 Grounding strap secured and in good condition?			
5.0 Tank/Piping External Coating			
5.1 No evidence of paint failure?			
6.0 Tank Shell/Heads			
6.1 No noticeable shell/head distortions, buckling, denting or bulging?			
6.2 No evidence of shell/head corrosion or cracking?			
6.3 No standing water on tank top?			
7.0 Tank Piping			
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	ion?		
8.0 Other Conditions			
8.1 No other conditions that should be addressed for continued safe operation?			T
Comments (if any above status is NO, explain here):			
			ļ

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-51	Date:			
Tank Location: Motor Pool	Inspector:			
Tank Capacity/Contents: 275-gallon engine oil				
Talik Capacity/Contents. 275-gallon engine oil				
Item		Status		
1.0 Tank Containment		YES	NO	l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	r2	ILO	NO	I IV/A
1.2 No debris or fire hazard in containment?	,ı :			
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	rt2			
3.0 Tank Attachments or Appurtenances	iti			
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	2000			
3.2 Tank Liquid level gauge readable and in good condition?	nager			X
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				1
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging? 6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
	nia m O			
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	SION?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation? Comments (if any above status is NO, explain here):				L

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-53	Date:			
Tank Location: Psychology – day tank	Inspector:			
Tank Capacity/Contents: 100-gallon ULSD				
Tank Supusity/Someths: 100-gallon SESB				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?	Ŭ			
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				i
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				i
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
online (if any above status is ive, explain here).				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-55	Date:			
Tank Location: Mink Barn	Inspector:			
Tank Capacity/Contents: 330-gallon ULSD				
Talik Capacity/Contents. 330-gailon 013D				
Item	lo ₄ ,	4		
1.0 Tank Containment		itus	NO	NI/A
		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe 1.2 No debris or fire hazard in containment?	1 !			
1.3 Drain valves operable and in a closed position?	<u></u>			
1.4 Containment egress pathways clear and gates/doors operable?	<u></u>			
1.5 Containment Structure in satisfactory condition?		-		
2.0 Leak Detection				
	10			
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-56	Date:			
Tank Location: South Campus Chiller	Inspector:			
Tank Capacity/Contents: 1,000-gallon ULSD				
Tank Capacity/Contents. 1,000-gailon CLOD				
Item		Status		
1.0 Tank Containment		YES	NO	l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	r2	TLO	NO	IN//
1.2 No debris or fire hazard in containment?	1.			
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	ut2			
3.0 Tank Attachments or Appurtenances	it:			
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	2000			
3.2 Tank Liquid level gauge readable and in good condition?	nage :			X
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				-
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging? 6.2 No evidence of shell/head corrosion or cracking?				-
6.3 No standing water on tank top?				
7.0 Tank Piping				
	nia n O			
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	SION?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation? Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-57	Date:			
Tank Location: Plant Science	Inspector:			
Tank Capacity/Contents: 275-gallon ULSD				
Tarin Supusity/ Somether Ero gamen Sees				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
				ļ

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-59	Date:			
Tank Location: Plant Science	Inspector:			
Tank Capacity/Contents: 275-gallon ULSD				
Turk Supacity/Someries: 275-ganon Sees				
Item		Status		
1.0 Tank Containment		YES	NO	l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	er?			10,71
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmer	nt?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	mage?			X
3.2 Tank Liquid level gauge readable and in good condition?	nago.			
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
Commonto (il uni) aboro otatao io ito, explani nolo,i				

AST Monthly Inspection Checklist				
AST Information				
	Date:			
Tank Location: Putnam Refectory Dining	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Tank Supucity/Someths: 200-gailion kitorion grease				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	ſ?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
	Date:			
Tank Location: Student Union - Bistro	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
g. out				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-65	Date:			
Tank Location: McConaughy Dining	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-66	Date:			
	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Tank Capacity/Contents. 200-gailon kitchen grease				
Item	la	24-4		
1.0 Tank Containment	Įš	Status	NO	N1/A
	-2	YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container 1.2 No debris or fire hazard in containment?	1 ?			
1.3 Drain valves operable and in a closed position?				-
1.4 Containment egress pathways clear and gates/doors operable?		-		-
1.5 Containment Structure in satisfactory condition?				-
•				
2.0 Leak Detection	10			
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):	-			

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-67	Date:			•
Tank Location: Gelfenbien (Towers) Dining	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-68	Date:			
	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Tank Capacity/Contents: 200-gailion kitchen grease				
Item		lC4a4a		
1.0 Tank Containment		Status	NO	T 1/4
	- -2	YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container 1.2 No debris or fire hazard in containment?	1 ?			<u> </u>
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
·				
2.0 Leak Detection	10			
2.1 No visible signs of leakage around the tank, piping or secondary containment	ť?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				_
4.2 No cracking or spalling of concrete pad or ring wall?				<u> </u>
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				<u> </u>
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				<u> </u>
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				ļ
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-69	Date:			
	Inspector:			
Tank Capacity/Contents: 150-gallon kitchen grease				
Tank Capacity/Contents. 150-gailon kitchen grease				
Item	los	4		
1.0 Tank Containment		atus	NO	N1/A
		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container 1.2 No debris or fire hazard in containment?	?			
1.3 Drain valves operable and in a closed position?	<u> </u>			
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
	10			
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-70	Date:			
	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Tank Capacity/Contents. 200-gailon kitchen grease				
Item	1	Ctatus		
1.0 Tank Containment		Status	NO	I NI/A
	-2	YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container 1.2 No debris or fire hazard in containment?				<u> </u>
1.3 Drain valves operable and in a closed position?	<u></u>			
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?	-			
•				
2.0 Leak Detection	10			
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				_
4.2 No cracking or spalling of concrete pad or ring wall?				<u> </u>
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				<u> </u>
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				<u> </u>
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				<u> </u>
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	ion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-72	Date:			
	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Tank Capacity/Contents: 200-gailon kitchen grease				
Item	1	Ctatus		
1.0 Tank Containment		Status	NO	L 1/4
	-2	YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container 1.2 No debris or fire hazard in containment?	1 ?			<u> </u>
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
•				
2.0 Leak Detection	10			
2.1 No visible signs of leakage around the tank, piping or secondary containment	ť?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				<u> </u>
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				<u> </u>
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				<u> </u>
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
	Date:			
Tank Location: South Campus Dining	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
gainer Alternation 200 gainer Alternation groups				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-76	Date:			
Tank Location: WPCF	Inspector:			
Tank Capacity/Contents: 80-gallon ULSD				
Tarin Capacity/ Contented Co. Galleri C. C. C.				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	r?		-	
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?	g			7.
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
Commonto (il uny uzovo ciutae le rie, explum listo).				

AST Monthly Inspection Checklist				
AST Information				
	Date:			
Tank Location: North Garage	Inspector:			
Tank Capacity/Contents: 200-gallon ULSD				
Tank Supacity/Someths: 200-gailon SEOD				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	ſ?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-80	Date:			
Tank Location: Central Utility Plant	Inspector:			
Tank Capacity/Contents: 150-gallon ULSD				
Turn Supusity/Sometics: 100 gailer Seeb				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?		i		1
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?		i		1
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-81	Date:			
Tank Location: Central Utility Plant	Inspector:			
Tank Capacity/Contents: 150-gallon ULSD				
Tank Supacity/Someths: 100-gailon SEOD				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?	*			
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-82	Date:			
Tank Location: Central Utility Plant	Inspector:			
Tank Capacity/Contents: 275-gallon ULSD				
Turn Supusity/Sometics: 270 gailer Seeb				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?		i		1
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?		i		1
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
	Date:			
Tank Location: Student Union, Union Street Cafe	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Tank Supucity/Someths: 200-gailion kitorion grease				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?	<u> </u>			
3.3 Check all tank openings are properly sealed?				İ
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				İ
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				İ
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	ion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				•
, and the same of				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-126, Electric Mobile	Date:			
Tank Location: Varies, stored at Planning, Design and	Inspector			
Construction Warehouse				
Tank Capacity/Contents: 150-gallon ULSD				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	er?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmer	nt?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	mage?	i		Х
3.2 Tank Liquid level gauge readable and in good condition?		ĺ		
3.3 Check all tank openings are properly sealed?		1		
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?		1		X
4.2 No cracking or spalling of concrete pad or ring wall?		1		X
4.3 Tank supports in satisfactory conditions?		1		
4.4 Water able to drain away from tank?				-
4.5 Grounding strap secured and in good condition?				X
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads		_		
6.1 No noticeable shell/head distortions, buckling, denting or bulging? 6.2 No evidence of shell/head corrosion or cracking?		-		
6.3 No standing water on tank top?				-
		_		
7.0 Tank Piping	. 0			
7.1 Piping and connections are tight and fully engaged, no sign of wear or corro	sion?	_		
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AOTH (III (' OI II' (
AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-127	Date:			
Tank Location: Motor Pool	Inspector:			
Tank Capacity/Contents: 275-gallon transmission oil				
Tank Supusity/Soficins. 275-gailon transmission on				
Item	Ie.	tatus		
1.0 Tank Containment	100	YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r2	IEO	NO	IN/A
1.2 No debris or fire hazard in containment?	1 5			
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
·	-			
2.0 Leak Detection	10			
2.1 No visible signs of leakage around the tank, piping or secondary containmen	ť?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?	i			
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?	$\overline{}$			
Comments (if any above status is NO, explain here):				
ooniments (ii any above status is No, explain here).				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-130	Date:			
Tank Location: Public Safety Building	Inspector:			
Tank Capacity/Contents: 400-gallon ULSD				
Tank Supusity/Someths: 400-gallon SESB				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-131	Date:			
Tank Location: Reclaimed Water Facility	Inspector:			
Tank Capacity/Contents: 1,000-gallon ULSD				
Tarik Gapaoky/Goritomo. 1,000 ganon GEGB				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				1
Comments (if any above status is NO, explain here):				•

AST Monthly Inspection Checklist			
AST Information			
	Date:		
Tank Location: Willimantic Well Field	Inspector:		
Tank Capacity/Contents: 1,000-gallon ULSD			
Tarik Gapaoky/Goritonio. 1,000 ganon GEGB			
Item	Stat	us	
1.0 Tank Containment		ES NO	l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container			
1.2 No debris or fire hazard in containment?			1
1.3 Drain valves operable and in a closed position?			1
1.4 Containment egress pathways clear and gates/doors operable?			
1.5 Containment Structure in satisfactory condition?			
2.0 Leak Detection			
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?		
3.0 Tank Attachments or Appurtenances			
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?		X
3.2 Tank Liquid level gauge readable and in good condition?	lago.		
3.3 Check all tank openings are properly sealed?	<u> </u>		
4.0 Tank Foundation and Supports			
4.1 No evidence of tank settlement or foundation washout?			
4.2 No cracking or spalling of concrete pad or ring wall?	 		1
4.3 Tank supports in satisfactory conditions?			1
4.4 Water able to drain away from tank?			
4.5 Grounding strap secured and in good condition?			
5.0 Tank/Piping External Coating			
5.1 No evidence of paint failure?			
6.0 Tank Shell/Heads			
6.1 No noticeable shell/head distortions, buckling, denting or bulging?			
6.2 No evidence of shell/head corrosion or cracking?			1
6.3 No standing water on tank top?			
7.0 Tank Piping			
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?		
8.0 Other Conditions			
8.1 No other conditions that should be addressed for continued safe operation?			
Comments (if any above status is NO, explain here):			

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-133	Date:			
Tank Location: Nextel Radio Tower	Inspector:			
Tank Capacity/Contents: 330-gallon ULSD				
Tank Capacity/Contents. 550-gailon OLGD				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?	i		İ
1.2 No debris or fire hazard in containment?	i			İ
1.3 Drain valves operable and in a closed position?	i	İ		
1.4 Containment egress pathways clear and gates/doors operable?	i	İ		
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?	inage i			
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?	1			
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				1

AOTM - with his larger and have only and the state of			
AST Monthly Inspection Checklist			
AST Information			
Tank ID: AST-134	Date:		
Tank Location: Health Services	Inspector:		
Tank Capacity/Contents: 342-gallon ULSD			
- ann outputty, contents of a gamen of a			
Item	Statu	ıs	
1.0 Tank Containment	YE		l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained		1 110	14//
1.2 No debris or fire hazard in containment?	' 		+
1.3 Drain valves operable and in a closed position?			+
1.4 Containment egress pathways clear and gates/doors operable?			1
1.5 Containment Structure in satisfactory condition?			+
2.0 Leak Detection			
1 11 11111	+2		_
2.1 No visible signs of leakage around the tank, piping or secondary containmen	l f		
3.0 Tank Attachments or Appurtenances			
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?		X
3.2 Tank Liquid level gauge readable and in good condition?			_
3.3 Check all tank openings are properly sealed?			
4.0 Tank Foundation and Supports			
4.1 No evidence of tank settlement or foundation washout?			X
4.2 No cracking or spalling of concrete pad or ring wall?			X
4.3 Tank supports in satisfactory conditions?			
4.4 Water able to drain away from tank?			
4.5 Grounding strap secured and in good condition?			X
5.0 Tank/Piping External Coating			
5.1 No evidence of paint failure?			
6.0 Tank Shell/Heads			
6.1 No noticeable shell/head distortions, buckling, denting or bulging?			
6.2 No evidence of shell/head corrosion or cracking?			
6.3 No standing water on tank top?			
7.0 Tank Piping			
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?		
8.0 Other Conditions			
8.1 No other conditions that should be addressed for continued safe operation?			
Comments (if any above status is NO, explain here):	-	<u> </u>	

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-135	Date:			
Tank Location: Fieldhouse	Inspector:			
Tank Capacity/Contents: 150-gallon ULSD				
Tank Supacity/Soments: 100-gallon SEOD				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	r?	i	-	
1.2 No debris or fire hazard in containment?		i i		
1.3 Drain valves operable and in a closed position?		i i		
1.4 Containment egress pathways clear and gates/doors operable?		İ		
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	ıt?	i i		
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?	<u> </u>	i		
3.3 Check all tank openings are properly sealed?		i i		
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?		i		
4.2 No cracking or spalling of concrete pad or ring wall?		i		
4.3 Tank supports in satisfactory conditions?		i i		
4.4 Water able to drain away from tank?		i i		
4.5 Grounding strap secured and in good condition?		i i		
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?		i i		
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?		i		
6.2 No evidence of shell/head corrosion or cracking?		i i		
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?		i		
Comments (if any above status is NO, explain here):		•		

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-138	Date:			
Tank Location: Student Union, Fire & Wok	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
Tarin Capacity/ Contained 200 gailer Michell groups				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			İ
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-139	Date:			
Tank Location: Student Union, One Plate, Two Plates	Inspector:			
Tank Capacity/Contents: 200-gallon kitchen grease				
gailon kitohon grouss				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?		.,,,	
1.2 No debris or fire hazard in containment?		i		
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):		-		

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-140	Date:			
Tank Location: Ice Rink	Inspector:			
Tank Capacity/Contents: 150-gallon ULSD				
Tank Supucity/Someths: 100-gallon SEOD				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-142	Date:			
Tank Location: Motor Pool	Inspector:			
Tank Capacity/Contents: 275-gallon engine oil				
Tank Capacity/Contents. 270-gailon engine oii				
Item	I c	4-4		
1.0 Tank Containment		tatus	NO	N1/A
	-2	YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container 1.2 No debris or fire hazard in containment?	?	-		
1.3 Drain valves operable and in a closed position?		+		-
1.4 Containment egress pathways clear and gates/doors operable?		-		-
1.5 Containment Structure in satisfactory condition?	+	+		
2.0 Leak Detection				
1 11 11111	10			
2.1 No visible signs of leakage around the tank, piping or secondary containment	1?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?	_			
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?	<u> </u>			
4.3 Tank supports in satisfactory conditions?		+		
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-143	Date:			
Tank Location: Engineering/Castleman – new tank	Inspector:			
Tank Capacity/Contents: 250-gallon hydraulic oil				
Turn Supusity Scritteries 200 gaillori Hydraulio Sii				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-144	Date:			•
Tank Location: High Head Lift Station	Inspector:			
Tank Capacity/Contents: 1,500-gallon ULSD				
Tank Supacity/Sontones: 1,000-ganon Seob				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-145	Date:			
Tank Location: Isolation Farm	Inspector:			
Tank Capacity/Contents: 209-gallon ULSD				
Turk Supacity/Soments: 200-ganon Sees				
Item		Status		
1.0 Tank Containment		YES	NO	l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	er?			10,71
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmer	nt?			
3.0 Tank Attachments or Appurtenances	т.			
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	mage?			X
3.2 Tank Liquid level gauge readable and in good condition?	nago.			
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
online (if any above status is ite; explain here).				

AST Monthly Inspection Checklist				
AST Information				
	Date:			
Tank Location: Gurleyville Lift Station	Inspector:			
Tank Capacity/Contents: 1,727-gallon ULSD				
gailon ocos				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	ion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):		•		
<u> </u>				

AST Monthly Inspection Checklist				
AST Information				
	Doto			
	Date: Inspector:			
	mapector.			
Tank Capacity/Contents: 323-gallon ULSD				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				<u> </u>
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containment	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dam	nage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-149	Date:			
Tank Location: Mobile Supply Fuel Truck	Inspector:			
		•		
Tank Capacity/Contents: 100-gallon ULSD				
ltem		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill container	r?	TES	NO	IN/A
1.2 No debris or fire hazard in containment?	I !	1		1
1.3 Drain valves operable and in a closed position?		1		1
1.4 Containment egress pathways clear and gates/doors operable?		1		
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
	+2			
2.1 No visible signs of leakage around the tank, piping or secondary containmen	l?			
3.0 Tank Attachments or Appurtenances	2222			V
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan 3.2 Tank Liquid level gauge readable and in good condition?	nage ?			Х
		1		
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports 4.1 No evidence of tank settlement or foundation washout?				V
4.1 No evidence of tank settlement of foundation washout? 4.2 No cracking or spalling of concrete pad or ring wall?				X
				X
4.3 Tank supports in satisfactory conditions?				_ ^
4.4 Water able to drain away from tank? 4.5 Grounding strap secured and in good condition?				X
				^
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure? 6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?		-		
6.2 No evidence of shell/head corrosion or cracking?		1		-
6.3 No standing water on tank top?				
7.0 Tank Piping	·:0			
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				<u> </u>
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-150	Date:			
Tank Location: Supplemental Utility Plant Day Tank	Inspector:			
Tank Capacity/Contents: 300-gallon ULSD				
Tarin Capacity/ Contented Coo gailer C202				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	r?	1		7,171
1.2 No debris or fire hazard in containment?		i		
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmer	nt?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	mage?			X
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?		<u> </u>		
Comments (if any above status is NO, explain here):				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-151	Date:			
Tank Location: Supplemental Utility Plant Day Tank	Inspector:	1		
Tank Capacity/Contents: 300-gallon ULSD				
Turk Supusity/Softishes. Soo gallon SESS				
		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	er?	i		i
1.2 No debris or fire hazard in containment?		İ		
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmer	nt?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	mage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?		i i		
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?		İ		
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?		İ		
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corro	sion?	Ī		
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?		Ī		
Comments (if any above status is NO, explain here):				

ACT Manthly Incorporation Obsolution				
AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-152	Date:			
Tank Location: Farm Services Fuel Tank	Inspector:			
Tank Capacity/Contents: 2,500-gallon ULSD				
Item		Status		
1.0 Tank Containment		YES	NO	l N/A
1.1 No water in primary tank, secondary containment, interstice, or spill containe	r?		110	1 1/7 1
1.2 No debris or fire hazard in containment?	-			
1.3 Drain valves operable and in a closed position?				†
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				1
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	ıt?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dar	mage?			X
3.2 Tank Liquid level gauge readable and in good condition?	nago.			
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				1
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions	31011:			
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				
Comments (if any above status is NO, explain here).				

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-153	Date:			
Tank Location: Hockey Arena Emergency Generator	Inspector:			
Tank Capacity/Contents: 260-gallon ULSD				
Turn Supusity/Someries. 200 gamen Seas				
 Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?	120	110	14// (
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?	<u> </u>			1
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				İ
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):		•		

AST Monthly Inspection Checklist				
AST Information				
Tank ID: AST-154	Date:			
Tank Location: Public Safety Emergency Generator	Inspector:			
Tank Capacity/Contents: 600-gallon ULSD				
<u> </u>				
Item		Status		
1.0 Tank Containment		YES	NO	N/A
1.1 No water in primary tank, secondary containment, interstice, or spill contained	r?			
1.2 No debris or fire hazard in containment?				
1.3 Drain valves operable and in a closed position?				
1.4 Containment egress pathways clear and gates/doors operable?				
1.5 Containment Structure in satisfactory condition?				
2.0 Leak Detection				
2.1 No visible signs of leakage around the tank, piping or secondary containmen	t?			
3.0 Tank Attachments or Appurtenances				
3.1 Ladder and platform structure secure with no sign of severe corrosion or dan	nage?			Х
3.2 Tank Liquid level gauge readable and in good condition?				
3.3 Check all tank openings are properly sealed?				
4.0 Tank Foundation and Supports				
4.1 No evidence of tank settlement or foundation washout?				
4.2 No cracking or spalling of concrete pad or ring wall?				
4.3 Tank supports in satisfactory conditions?				
4.4 Water able to drain away from tank?				
4.5 Grounding strap secured and in good condition?				
5.0 Tank/Piping External Coating				
5.1 No evidence of paint failure?				
6.0 Tank Shell/Heads				
6.1 No noticeable shell/head distortions, buckling, denting or bulging?				
6.2 No evidence of shell/head corrosion or cracking?				
6.3 No standing water on tank top?				
7.0 Tank Piping				
7.1 Piping and connections are tight and fully engaged, no sign of wear or corros	sion?			
8.0 Other Conditions				
8.1 No other conditions that should be addressed for continued safe operation?				
Comments (if any above status is NO, explain here):				

(Keys needed)

Date:	(Keys needed)			
UST Monthly Insp	pection Checklist (PEI RP900)			
	ction Checklist is based off PEI RP900 Inspection Form to accommodat	te CT DEEF	Regulation	os:
tem		Status	7.05	
Leak Detection Reco	rd Kooning	Otatas		
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A	ILO	INO	14/7
Automatic Tank	,			
	Passing tank test report printed and properly filed			х
Gauge (ATG) Continuous Interstitial				
	Sensor status report printed and properly filed			х
Monthly Pining Look				
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory	This menth's inventory analyzed, last menth's results passed and			
	This month's inventory analyzed; last month's results passed and			х
Reconciliation (SIR)	available for inspection			
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			х
Manual Groundwater	NA/-IIII II II			
(GWM) or Soil-Vapor	Wells sampled and results pass			Х
Monitoring (SVM)	Ot14			
Manual Interstitial	Steel tank: interstitial space checked and found dry Fiberglass tank: interstital space checked and found dry			X
Monitoring for Tanks	Fiberglass tank: Interstital space checked and found dry Fiberglass tank: level of monitoring fluid within normal range			X
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			X
	Steel and liberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial	Touls ton assess increased and no liquid found			
Monitoring for Piping	Tank-top sump inspected and no liquid found			Х
(MIMP)		\/=0	110	
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
Sumps	Piping sump free of product/liquid and is in good condition			Х
	Dispenser sump free of product/liquid and is in good condition			Х
	Sump sensors are correctly situated at bottom of sump			Х
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			Х
	Standard drop tube smooth, no ragged edges, in good condition			х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			x
	edge of the fill pipe			_ ^
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind			Х
Dispenser cabinents ir	nterior is clean; free of leaks, wear or corrosion			х
Stage I Vapor Recove	ery	YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			
T Daint (D)	cracked or chipped			X
Two-Point (Dual	No dirt, trash, water or product			х
Point) Vapor	No cracks, bulges or holes			Х
Recovery	Vapor recovery cap present, seals tightly			х
	Poppet of vapor recovery adaptor seals tightly			
Transfer Areas		YES	NO	N/A
Releases have been re	eported and cleaned in accordance with applicable requirements			X
Observation and Mor		YES	NO	N/A
	r is properly identified and secured	120	110	X
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months	120	110	
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			X
Cathodic Protection	hours each month			х
DEFICIENCIES/COM				
DEI ICILINGILS/ COIVI	WEIVIO.			

Tank ID: (#10) Beach Hall [2,000-gal Diesel]

UST Monthly Insp	pection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommoda	te CT DEEF	Regulation	s:
Item		Status		
Leak Detection Reco	rd Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	• •			
Automatic Tank				
Gauge (ATG)	Passing tank test report printed and properly filed			Х
Continuous Interstitial				
Monitoring (CIM)	Sensor status report printed and properly filed			Х
Monthly Piping Leak				
Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			Х
Statistical Inventory	This month's inventory analyzed; last month's results passed and			
Reconciliation (SIR)	available for inspection			×
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			×
Manual Groundwater				
	Wells sampled and results pass			x
Monitoring (SVM)	Wells sumpled and results pass			1 ^
	Steel tank: interstitial space checked and found dry		<u> </u>	Х
Manual Interstitial	Fiberglass tank: interstital space checked and found dry			 ^
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			X
Manual Intersitial	Cicci and liberglass tarks, vacadin level is within tolerance			 ^
Monitoring for Piping	Tank-top sump inspected and no liquid found			v
(MIMP)	Trank-top sump inspected and no liquid lound			Х
. ,		VEC	NO	NI/A
All Tanks	TAIL	YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			<u> </u>
0	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			Х
0 111 0 1 1	Sump sensors are correctly situated at bottom of sump			Х
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			Х
	Standard drop tube smooth, no ragged edges, in good condition			х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			x
	edge of the fill pipe			^
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			х
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind			х
Dispenser cabinents in	nterior is clean; free of leaks, wear or corrosion			х
Stage I Vapor Recove	ery	YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			
T Deint /Dl	cracked or chipped			Х
Two-Point (Dual	No dirt, trash, water or product			х
Point) Vapor	No cracks, bulges or holes			х
Recovery	Vapor recovery cap present, seals tightly			х
	Poppet of vapor recovery adaptor seals tightly			
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			Х
Observation and Mor		YES	NO	N/A
	r is properly identified and secured			X
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months			X
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			
Cathodic Protection	hours each month			х
DEFICIENCIES/COM				
	<u></u>			

Tank ID: [#13] BIO#4 [1,500- gal DIESEL]

UST Monthly Insp	pection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommoda	te CT DEEP	Regulation	is:
Item		Status		
Leak Detection Reco	rd Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			,
Gauge (ATG)				Х
Continuous Interstitial	Sensor status report printed and properly filed			х
Monitoring (CIM)	Consor status report printed and properly med			^
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory	This month's inventory analyzed; last month's results passed and			
Reconciliation (SIR)	available for inspection			Х
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			x
Manual Groundwater				
(GWM) or Soil-Vapor	Wells sampled and results pass			х
Monitoring (SVM)				
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: interstital space checked and found dry			Х
(MIMT)	Fiberglass tank: level of monitoring fluid within normal range			Х
	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial Monitoring for Piping	Tank-top sump inspected and no liquid found			х
(MIMP) All Tanks		VEC	NO	NI/A
	All	YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			1
Cumpo	Piping sump free of product/liquid and is in good condition Dispenser sump free of product/liquid and is in good condition			
Sumps	Sump sensors are correctly situated at bottom of sump			Х
Spill-Containment	Spill-Containment manhole in good condition	 		1
Manhole	Drain valve in spill-containment manhole in good condition			х
Walliole	Standard drop tube smooth, no ragged edges, in good condition			_ ^
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			
Brop rubo	edge of the fill pipe			х
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind			Х
	nterior is clean; free of leaks, wear or corrosion			х
Stage I Vapor Recove		YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			
Two Doint / Duol	cracked or chipped			Х
Two-Point (Dual Point) Vapor	No dirt, trash, water or product			х
	No cracks, bulges or holes			х
Recovery	Vapor recovery cap present, seals tightly			Х
	Poppet of vapor recovery adaptor seals tightly			Х
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			Х
Observation and Mor		YES	NO	N/A
	r is properly identified and secured			Х
Corrosion Protection		YES	NO	N/A
Impressed-Current	Record volt and amp readings, consistent with prior months			Х
Cathodic Protection	Record hour meter reading (if present). Readings increases by 700 hours each month			х
DEFICIENCIES:				

Tank ID:	#14 Commissary	[DIESEL]	
Inchester:			

UST Monthly Insp	UST Monthly Inspection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommodat	te CT DEEP	Regulation	s:
Item		Status		
Leak Detection Reco	rd Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			
Gauge (ATG)	Passing tank test report printed and properly filed			Х
Continuous Interstitial	Sensor status report printed and properly filed			v
Monitoring (CIM)	Serisor status report printed and properly filed			Х
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			х
Test (MPLT)				^
Statistical Inventory	This month's inventory analyzed; last month's results passed and			х
Reconciliation (SIR)	available for inspection			
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			х
Manual Groundwater				
	Wells sampled and results pass			х
Monitoring (SVM)	Wells sampled and results pass			^
	Steel tank: interstitial space checked and found dry			Х
Manual Interstitial	Fiberglass tank: interstital space checked and found dry			X
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			Х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial	,			
Monitoring for Piping	Tank-top sump inspected and no liquid found			Х
(MIMP)				
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			,
Sumps	Piping sump free of product/liquid and is in good condition			
	Dispenser sump free of product/liquid and is in good condition			Х
	Sump sensors are correctly situated at bottom of sump			X
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			Х
	Standard drop tube smooth, no ragged edges, in good condition			Х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			
	edge of the fill pipe			Х
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			Х
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
Dispenser hoses are f	ree of tears, leaks, holes, kinks, crimps or defects of any kind			Х
	nterior is clean; free of leaks, wear or corrosion			Х
Stage I Vapor Recove		YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			
	cracked or chipped			Х
Two-Point (Dual	No dirt, trash, water or product			Х
Point) Vapor	No cracks, bulges or holes			Х
Recovery	Vapor recovery cap present, seals tightly			Х
	Poppet of vapor recovery adaptor seals tightly			х
Transfer Areas	, , , , , , , , , , , , , , , , , , , ,	YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			X
Observation and Mor		YES	NO	N/A
	r is properly identified and secured			X
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months			X
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			
Cathodic Protection	hours each month			Х
DEFICIENCIES:				

Tank ID: #15 Dodd Archive [4,000-gallon DIESEL]

UST Monthly Insp	pection Checklist (PEI RP900)			
	ction Checklist is based off PEI RP900 Inspection Form to accommoda	-	Regulation	is:
Item		Status		
Leak Detection Reco				
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			х
Gauge (ATG)				
Continuous Interstitial Monitoring (CIM)	Sensor status report printed and properly filed			х
Monthly Piping Leak				
Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory	This month's inventory analyzed; last month's results passed and			
Reconciliation (SIR)	available for inspection			Х
, ,				
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			Х
Manual Groundwater				
(GWM) or Soil-Vapor	Wells sampled and results pass			х
Monitoring (SVM)				
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
	Fiberglass tank: interstital space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial				
Monitoring for Piping	Tank-top sump inspected and no liquid found			х
(MIMP)				
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
0.000 20.000000	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			х
	Sump sensors are correctly situated at bottom of sump			
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition		!]
IVIAITITOIE	Standard drop tube smooth, no ragged edges, in good condition			
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			
Drop rube				х
T 1 0 0 0 0 0 0	edge of the fill pipe			
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			Х
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind			Х
	nterior is clean; free of leaks, wear or corrosion			Х
Stage I Vapor Recove	ery	YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			х
Two-Point (Dual	cracked or chipped			^
	No dirt, trash, water or product			х
Point) Vapor Recovery	No cracks, bulges or holes			Х
Recovery	Vapor recovery cap present, seals tightly			х
	Poppet of vapor recovery adaptor seals tightly			Х
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			X
Observation and Mo		YES	NO	N/A
	r is properly identified and secured	1		1
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months	1	110	X
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			^
Cathodic Protection	hours each month			х
DEFICIENCIES/COM				
DET TOTE I VOICE OF COM	<u> </u>			

Tank ID: #16 Eastwood Lift Station [600- gallon DIESEL]

Monthly Inspe	pection Checklist (PEI RP900) ction Checklist is based off PEI RP900 Inspection Form to accommoda	te CT DEEP	Regulation	s:	
tem					
eak Detection Reco	rd Keepina	Status			
ank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A	
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A				
Automatic Tank		i			
Gauge (ATG)	Passing tank test report printed and properly filed			х	
Continuous Interstitial					
Monitoring (CIM)	Sensor status report printed and properly filed				
Monthly Piping Leak					
Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			Х	
Statistical Inventory	This month's inventory analyzed; last month's results passed and				
Reconciliation (SIR)	available for inspection			Х	
· · · · · · · · · · · · · · · · · · ·					
nventory Control (IC)	Inventory reconciled and within the company and regulatory standard			х	
Manual Groundwater					
GWM) or Soil-Vapor	Wells sampled and results pass			×	
Monitoring (SVM)	Twens sampled and results pass			^	
Monitoring (3 vivi)	Stool tank: interstitial anges shocked and found dry				
Manual Interstitial	Steel tank: interstitial space checked and found dry Fiberglass tank: interstital space checked and found dry			X	
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range				
(MIMT)				X	
	Steel and fiberglass tanks, vacuum level is within tolerance			Х	
Manual Intersitial					
Monitoring for Piping	Tank-top sump inspected and no liquid found			X	
(MIMP)					
III Tanks		YES	NO	N/A	
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank				
	Piping sump free of product/liquid and is in good condition				
Sumps	Dispenser sump free of product/liquid and is in good condition			х	
	Sump sensors are correctly situated at bottom of sump			х	
Spill-Containment	Spill-Containment manhole in good condition				
Manhole	Drain valve in spill-containment manhole in good condition				
	Standard drop tube smooth, no ragged edges, in good condition			х	
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top				
'	edge of the fill pipe			Х	
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			х	
Check for Water	No water present in tank			, , , ,	
Tank Vents	Vent cap present, vent pipe solidly supported and vertical				
Dispenser	vent dap present, vent pipe solidly supported and vertical	YFS	NO	N/A	
	was of tooks lanks balos kinks original an defeate of anythind	TES	NO		
	ree of tears, leaks, holes, kinks, crimps or defects of any kind			X	
	nterior is clean; free of leaks, wear or corrosion	\/50	110	X	
tage I Vapor Recove	•	YES	NO	N/A	
	Cover present, colored orange, seated firmly at grade, not broken,			x	
Two-Point (Dual	cracked or chipped			,	
Point) Vapor	No dirt, trash, water or product			Х	
Recovery	No cracks, bulges or holes			Х	
recovery	Vapor recovery cap present, seals tightly			Х	
	Poppet of vapor recovery adaptor seals tightly			Х	
ransfer Areas		YES	NO	N/A	
Releases have been r	eported and cleaned in accordance with applicable requirements			Х	
bservation and Mo		YES	NO	N/A	
	r is properly identified and secured	Ī		1	
orrosion Protection		YES	NO	N/A	
	Record volt and amp readings, consistent with prior months	1,20	110		
mpressed-Current	Record hour meter reading (if present). Readings increases by 700			X	
	Interest industries reading (if present). Readings increases by 700			х	
Cathodic Protection	hours each month				

Tank ID: [#18] Fenton River

Inspector:

Date:				
UST Monthly Insp	ection Checklist (PEI RP900)			
	ction Checklist is based off PEI RP900 Inspection Form to accommoda	te CT DEEP	Regulation	s:
tem	tion oncomist to success on the street map content of the street map c	Status	r togulation	
Leak Detection Recor	d Kaanina	Otatao		
Tank Leak Detection	·	YES	NO	N/A
	ATG, CIM, SIR, IC, GWM, SVM Type: ATG CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A	ILO	140	TV//
Piping Leak Detection	CIIVI, IVIPLI, SIR, GVVIVI, SVIVI, IVIIIVII I I YPG. IVIA			
Automatic Tank	Passing tank test report printed and properly filed			х
Continuous Interstitial				
Continuous Interstitial	Sensor status report printed and properly filed			х
Monitoring (CIM)				
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			х
Test (MPLT)				
-	This month's inventory analyzed; last month's results passed and			х
Reconciliation (SIR)	available for inspection			
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			x
, , ,				
Manual Groundwater				
, , ,	Wells sampled and results pass			х
Monitoring (SVM)				
Manual Interstitial	Steel tank: interstitial space checked and found dry	<u> </u>		
NA :4 :	Fiberglass tank: interstital space checked and found dry			Х
(NAINAT)	Fiberglass tank: level of monitoring fluid within normal range			X
	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial				
0 , 0 ,	Tank-top sump inspected and no liquid found			х
(MIMP)				
All Tanks		YES	NO	N/A
	All covers present, in good condition, seated firmly on correct tank			
	Piping sump free of product/liquid and is in good condition	[
	Dispenser sump free of product/liquid and is in good condition			х
	Sump sensors are correctly situated at bottom of sump			<u> </u>
	Spill-Containment manhole in good condition			
	Drain valve in spill-containment manhole in good condition			Γ
	Standard drop tube smooth, no ragged edges, in good condition			
	Top edge of coaxial drop tube smooth, round, slightly below the top			T v
	edge of the fill pipe			X
	Tank gauge stick can be clearly read, is not warped or broken			
	No water present in tank			
	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
	ee of tears, leaks, holes, kinks, crimps or defects of any kind			
	terior is clean; free of leaks, wear or corrosion	 	i	
Stage I Vapor Recover	·	YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,		1.0	
	cracked or chipped			х
Two-Point (Dual	No dirt, trash, water or product			x
Point) Vapor	No cracks, bulges or holes			X
	Vapor recovery cap present, seals tightly			i
	Poppet of vapor recovery adaptor seals tightly			X
Transfer Areas	Popper of Vapor recovery adaptor scale lightly	VES	NO	
	in the second of	YES	NO	N/A
	eported and cleaned in accordance with applicable requirements	1/50	110	X NI/A
Observation and Mon		YES	NO	N/A
	is properly identified and secured			X
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months			Х
Cathodic Protection	Record hour meter reading (if present). Readings increases by 700			х
· Showing Projection				^
DEFICIENCIES/COMM	hours each month			

Tank ID:	[#20]	Heating Plant- Tank#1	(50k-gal Diesel)
Inspector:			

Date:				
UST Monthly Insp	pection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommoda	te CT DEEP	Regulation	s:
Item		Status	-	
Leak Detection Reco	rd Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank				
Gauge (ATG)	Passing tank test report printed and properly filed			Х
Continuous Interstitial	Sensor status report printed and properly filed			
Monitoring (CIM)	Sensor status report printed and property filed			
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			x
Test (MPLT)	assing piping leak-test report printed/documented and properly liled			^
Statistical Inventory	This month's inventory analyzed; last month's results passed and			x
Reconciliation (SIR)	available for inspection			^
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			x
inventory control (10)	inventory reconciled and within the company and regulatory standard			^
Manual Groundwater				
	Wells sampled and results pass			Х
Monitoring (SVM)				
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: interstital space checked and found dry			Х
(MIMT)	Fiberglass tank: level of monitoring fluid within normal range			Х
	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial				
Monitoring for Piping	Tank-top sump inspected and no liquid found			Х
(MIMP)				
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			Х
0 111 0	Sump sensors are correctly situated at bottom of sump			Х
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			
D T. I	Standard drop tube smooth, no ragged edges, in good condition			Х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			х
T 10 0011	edge of the fill pipe			
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			
Check for Water Tank Vents	No water present in tank			
	Vent cap present, vent pipe solidly supported and vertical	\/F0	NO	N1/A
Dispenser		YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind			X
	nterior is clean; free of leaks, wear or corrosion	\/F0	NO	X
Stage I Vapor Recove	·	YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			х
Two-Point (Dual	cracked or chipped			
Point) Vapor	No dirt, trash, water or product			Х
Recovery	No cracks, bulges or holes			Х
·	Vapor recovery cap present, seals tightly			Х
Tuenefeu Aussa	Poppet of vapor recovery adaptor seals tightly	\/F0	NO	X
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements)/E0	110	X
Observation and Mor		YES	NO	N/A
	r is properly identified and secured	\/50	NO	X
Corrosion Protection		YES	NO	N/A
Impressed-Current	Record volt and amp readings, consistent with prior months			Х
Cathodic Protection	Record hour meter reading (if present). Readings increases by 700			х
	hours each month			
DEFICIENCIES/COM	IVIEIV I S.			

Tank ID: [#21] Heating Plant-Tank#2 (50k-gal Diesel)

Inspector:

Date:	and the second of the second o			
	pection Checklist (PEI RP900)			
	ction Checklist is based off PEI RP900 Inspection Form to accommodat	_	Regulation	is:
tem		Status		-
Leak Detection Reco		VE0	NO	N1/A
Fank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			х
Gauge (ATG)	i massing			
Continuous Interstitial	Sensor status report printed and properly filed			
Monitoring (CIM)	1 1 1 2			
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			х
Test (MPLT)				
Statistical Inventory	This month's inventory analyzed; last month's results passed and			x
Reconciliation (SIR)	available for inspection			
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			x
	involtory recontained and realist are company and a series			,
Manual Groundwater				
(GWM) or Soil-Vapor	Wells sampled and results pass			х
Monitoring (SVM)				
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: interstital space checked and found dry			Х
~	Fiberglass tank: level of monitoring fluid within normal range			Х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial				
Monitoring for Piping	Tank-top sump inspected and no liquid found			х
(MIMP)				
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
01440 20.0. 00.0.	Piping sump free of product/liquid and is in good condition			†
Sumps	Dispenser sump free of product/liquid and is in good condition			Х
	Sump sensors are correctly situated at bottom of sump			X
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition	 		
Marinos	Standard drop tube smooth, no ragged edges, in good condition			
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			X
Diop Tube				х
T!: Oan Otiols	edge of the fill pipe			
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken	<u> </u>		
Check for Water	No water present in tank	<u> </u>		
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			21/2
Dispenser		YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind			Х
<u> </u>	nterior is clean; free of leaks, wear or corrosion			Х
Stage I Vapor Recove	-	YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			
Two Point (Dual	cracked or chipped			Х
Two-Point (Dual	No dirt, trash, water or product			Х
Point) Vapor	No cracks, bulges or holes			х
Recovery	Vapor recovery cap present, seals tightly			х
	Poppet of vapor recovery adaptor seals tightly			Х
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			X
Observation and Mor		YES	NO	N/A
	r is properly identified and secured	ILO	NO	•
Corrosion Protection		YES	NO	N/A
Corrosion Frotection		TES	INO	_
Impressed-Current	Record volt and amp readings, consistent with prior months			Х
	Record hour meter reading (if present). Readings increases by 700			х
Cathodic Protection				
DEFICIENCIES/COM	hours each month			

Tank ID: [#22] Heating Plant-Tank#3 (50k-gal Diesel)

Inspector:

		te CT DEEP Status	Regulation	ıs:
Item Leak Detection Record Tank Leak Detection	d Keeping	_	Regulation	is:
Leak Detection Record Tank Leak Detection		Status		
Tank Leak Detection				
Piping Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	-			
Gauge (ATG)	Passing tank test report printed and properly filed			Х
Continuous Interstitial	Sensor status report printed and properly filed			
Monitoring (CIM)	Sensor status report printed and property filed			
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			x
Test (MPLT)				_ ^
_	This month's inventory analyzed; last month's results passed and			x
Reconciliation (SIR)	available for inspection			
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			x
	Trontory recentation and main the company and regulatory candidate			^
Manual Groundwater				
` '	Wells sampled and results pass			X
Monitoring (SVM)				
	Steel tank: interstitial space checked and found dry			Х
Manitaring for Toples	Fiberglass tank: interstital space checked and found dry			Х
(NAINAT)	Fiberglass tank: level of monitoring fluid within normal range			Х
	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial	Touls tou assess increased and no limited formal			
0 1 0	Tank-top sump inspected and no liquid found			Х
(MIMP) All Tanks		VEO	NO	N1/A
	All appears we agent in good as whiting acceted firms by an approach tour	YES	NO	N/A
	All covers present, in good condition, seated firmly on correct tank Piping sump free of product/liquid and is in good condition			-
L	Dispenser sump free of product/liquid and is in good condition			
	Sump sensors are correctly situated at bottom of sump			X
	Spill-Containment manhole in good condition			Х
	Drain valve in spill-containment manhole in good condition			1
	Standard drop tube smooth, no ragged edges, in good condition			Х
	Top edge of coaxial drop tube smooth, round, slightly below the top			 ^
	edge of the fill pipe			x
	Tank gauge stick can be clearly read, is not warped or broken			
	No water present in tank			
	Vent cap present, vent pipe solidly supported and vertical			1
Dispenser	vont dap procesn, vent pipe condly supported and vented	YES	NO	N/A
	ee of tears, leaks, holes, kinks, crimps or defects of any kind	TLO	140	X
	terior is clean; free of leaks, wear or corrosion			X
Stage I Vapor Recover		YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,	120	140	14/7
	cracked or chipped			x
I wo-Point (Duai	No dirt, trash, water or product			Х
Point) Vapor	No cracks, bulges or holes			X
Pacovary L	Vapor recovery cap present, seals tightly			X
_	Poppet of vapor recovery adaptor seals tightly			X
Transfer Areas	11	YES	NO	N/A
	ported and cleaned in accordance with applicable requirements	, , , ,	110	X
IL VEIDAGES HAVE DEELITE.		YES	NO	N/A
		120	110	-
Observation and Moni				X
Observation and Moni Observation well cover	is properly identified and secured	YES	NO	N/A
Observation and Moni Observation well cover Corrosion Protection	is properly identified and secured	YES	NO	N/A
Observation and Moni Observation well cover Corrosion Protection Impressed-Current	is properly identified and secured Record volt and amp readings, consistent with prior months	YES	NO	
Observation and Moni Observation well cover Corrosion Protection Impressed-Current	is properly identified and secured	YES	NO	N/A

Tank ID:	[#23]	Heating Plant- Tank#4	(50k-gal Diesel)
Inspector:			

UST Monthly Insp	pection Checklist (PEI RP900)			
	ction Checklist is based off PEI RP900 Inspection Form to accommodate		[,] Regulation	s:
Item		Status		
Leak Detection Record Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Gauge (ATG)	Passing tank test report printed and properly filed			х
Continuous Interstitial Monitoring (CIM)	Sensor status report printed and properly filed			
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory Reconciliation (SIR)	This month's inventory analyzed; last month's results passed and available for inspection			х
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			х
Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM)	Wells sampled and results pass			х
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: interstital space checked and found dry			X
(MIMT)	Fiberglass tank: level of monitoring fluid within normal range			X
Manual Intersitial	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Monitoring for Piping (MIMP)	Tank-top sump inspected and no liquid found			х
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
Sumps	Piping sump free of product/liquid and is in good condition Dispenser sump free of product/liquid and is in good condition			Х
	Sump sensors are correctly situated at bottom of sump			Х
	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			
Drop Tube	Standard drop tube smooth, no ragged edges, in good condition Top edge of coaxial drop tube smooth, round, slightly below the top			x x
Tank Cauga Stick	edge of the fill pipe Tank gauge stick can be clearly read, is not warped or broken			
Tank Gauge Stick	No water present in tank	<u> </u>	1	<u> </u>
Check for Water Tank Vents	Vent cap present, vent pipe solidly supported and vertical	<u> </u>		
	vent cap present, vent pipe solidly supported and ventical	YES	NO	NI/A
Dispenser boses are fr	ree of tears, leaks, holes, kinks, crimps or defects of any kind	YES	NO	N/A
	ree of tears, leaks, noies, kinks, crimps or defects of any kind nterior is clean; free of leaks, wear or corrosion			X
•		VES	NO	X N/A
Stage I Vapor Recove	Cover present, colored orange, seated firmly at grade, not broken,	YES	NO NO	N/A
Two-Point (Dual	cracked or chipped No dirt, trash, water or product			X
Point) Vapor	No cracks, bulges or holes			X
Recovery	Vapor recovery cap present, seals tightly			X
	Poppet of vapor recovery adaptor seals tightly			X
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			X
Observation and Mor		YES	NO	N/A
	r is properly identified and secured			X
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months			Х
Cathodic Protection	Record hour meter reading (if present). Readings increases by 700 hours each month			х
DEFICIENCIES/COM	MENTS:			

Tank ID:	[#24]	Heating Plant- Tank#5	(50k-gal Diesel)
Inspector:			

Item Leak Detection Record Keep Tank Leak Detection Piping Leak Detection Automatic Tank Gauge (ATG) Continuous Interstitial Monitoring (CIM) Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Spill-Containment Manhole Drain va Standa Drop Tube Tank Gauge Stick Tank ga Check for Water CII Passing Pass	ATG, CIM, SIR, IC, GWM, SVM M, MPLT, SIR, GWM, SVM, MIMP Type: N/A g tank test report printed and properly filed status report printed and properly filed g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard	YES YES	NO NO	N/A x x x x x x x x x x x x x
Tank Leak Detection Piping Leak Detection Automatic Tank Gauge (ATG) Continuous Interstitial Monitoring (CIM) Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Check for Water CIM Passing Passi	ATG, CIM, SIR, IC, GWM, SVM M, MPLT, SIR, GWM, SVM, MIMP Type: N/A g tank test report printed and properly filed status report printed and properly filed g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES		x x x x x x x x x x x x
Tank Leak Detection Piping Leak Detection Automatic Tank Gauge (ATG) Continuous Interstitial Monitoring (CIM) Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Inventory Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Check for Water Passing Testing Sensor Passing This mo availab Rassing Sensor Passing Sensor Rassing Sensor Passing Sensor Rassing Sensor Passing Sensor Passing Sensor Passing This mo availab Rassing Fassi	ATG, CIM, SIR, IC, GWM, SVM M, MPLT, SIR, GWM, SVM, MIMP Type: N/A g tank test report printed and properly filed status report printed and properly filed g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank			x x x x x x x x x x x x
Piping Leak Detection Automatic Tank Gauge (ATG) Continuous Interstitial Monitoring (CIM) Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Inventory Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Tank ga Check for Water Passing Tanson Passing This mo availab This mo availab Sensor Passing Tansing Sensor Passing This mo availab Steel ta Fibergla Fibergla Fibergla Steel at Fibergla Fibergla Fibergla Steel at Fibergla Fib	M, MPLT, SIR, GWM, SVM, MIMP g tank test report printed and properly filed status report printed and properly filed g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry less tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank			x x x x x x x x x x x x
Automatic Tank Gauge (ATG) Continuous Interstitial Monitoring (CIM) Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Tank ga Check for Water Passing Sensor Passing Rassing Passing Sensor Passing Passing Sensor Passing Passing Sensor Passing Fishery availab Wells s Fibergla Fi	g tank test report printed and properly filed status report printed and properly filed g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry lass tank: interstital space checked and found dry lass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	x x x x x x x x x
Gauge (ATG) Continuous Interstitial Monitoring (CIM) Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All cover Sumps Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Tank gauge Stick Check for Water Tensor Passing Passing Passing Sensor Passing Passing Passing Fishery availab Wells s Steel ta Fibergla Fib	status report printed and properly filed g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry leass tank: interstitial space checked and found dry leass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found leas present, in good condition, seated firmly on correct tank	YES	NO	x x x x x x x x x
Continuous Interstitial Monitoring (CIM) Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All cover Sumps Spill-Containment Manhole Drain valued Standa Drop Tube Tank Gauge Stick Tank gare Check for Water	status report printed and properly filed g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry leass tank: interstitial space checked and found dry leass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found leas present, in good condition, seated firmly on correct tank	YES	NO	x x x x x x x x x
Continuous Interstitial Monitoring (CIM) Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All cover Sumps Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Tank gage Check for Water Testing Passing Passing Passing Steel ta Fibergla Fiberg	g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry leass tank: interstitial space checked and found dry leass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	x x x x x x x x x x
Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Spill-Containment Manhole Drain va Standa Drop Tube Tank Gauge Stick Tank ga Check for Water Passing Passing Rassing Passing This ma availab Steel ta Fibergla Fibe	g piping leak-test report printed/documented and properly filed onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry leass tank: interstitial space checked and found dry leass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	x x x x x x x x x x
Monthly Piping Leak Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Tank ga Check for Water This mo availab Inventor Wells s Steel ta Fibergla F	onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry lass tank: interstital space checked and found dry lass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	x x x x x x x x x x
Test (MPLT) Statistical Inventory Reconciliation (SIR) Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Check for Water This monavallable Top edicate available Tavailable Top edicate available Top edicate available Tank manual Interstitial Fibergla	onth's inventory analyzed; last month's results passed and le for inspection ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry lass tank: interstital space checked and found dry lass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	x x x x x x x x x x
Statistical Inventory Reconciliation (SIR) Inventory Control (IC) In	ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry ass tank: interstital space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance by sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	X X X X X X X
Reconciliation (SIR) availab Inventory Control (IC) Inventor Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All covers Piping Sumps Sumps Dispension Sumps Spill-Containment Manhole Drain via Standa Drop Tube Tank Gauge Stick Tank garenteed Tank Gauge	ry reconciled and within the company and regulatory standard ampled and results pass ink: interstitial space checked and found dry ass tank: interstital space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance by sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	X X X X X X X
Inventory Control (IC) Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All cover Pipings Sumps Dispension Sumps Spill-Containment Manhole Drain via Standa Drop Tube Tank Gauge Stick Tank garden Check for Water No water	ampled and results pass ink: interstitial space checked and found dry ass tank: interstitial space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance by sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	X X X X X
Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Check for Water Wells s Steel ta Fibergla Fiberg	ampled and results pass ink: interstitial space checked and found dry ass tank: interstital space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance by sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	X X X X X
(GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All cover Piping Sumps Sumps Dispension Sumps Spill-Containment Manhole Drain virus Drop Tube Tank Gauge Stick Tank garden Sumps Tank Gauge Stick Tank garden Sumps Check for Water No water	ank: interstitial space checked and found dry ass tank: interstital space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance ap sump inspected and no liquid found ars present, in good condition, seated firmly on correct tank	YES	NO	X X X X
(GWM) or Soil-Vapor Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All cover Piping Sumps Sumps Dispension Sumps Spill-Containment Manhole Drain virus Drop Tube Tank Gauge Stick Tank garden Sumps Tank Gauge Stick Tank garden Sumps Check for Water No water	ank: interstitial space checked and found dry ass tank: interstital space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance ap sump inspected and no liquid found ars present, in good condition, seated firmly on correct tank	YES	NO	x x x x
Monitoring (SVM) Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All covers Piping Sumps Dispensions Sumps Spill-Containment Manhole Drain v. Drop Tube Standa Tank Gauge Stick Tank gar Check for Water Standa	ank: interstitial space checked and found dry ass tank: interstital space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance ap sump inspected and no liquid found ars present, in good condition, seated firmly on correct tank	YES	NO	x x x x
Manual Interstitial Monitoring for Tanks (MIMT) Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Check for Water Stiber Is Fibergla	ass tank: interstital space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance ap sump inspected and no liquid found ars present, in good condition, seated firmly on correct tank	YES	NO	x x x
Monitoring for Tanks (MIMT) Fibergla Fibergla Steel an Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Sumps Spill-Containment Manhole Drop Tube Tank Gauge Stick Tank ga Check for Water Fibergla Fi	ass tank: interstital space checked and found dry ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance ap sump inspected and no liquid found ars present, in good condition, seated firmly on correct tank	YES	NO	x x x
Monitoring for Tanks (MIMT) Steel at Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Sumps Spill-Containment Manhole Drain vi Standa Drop Tube Tank Gauge Stick Check for Water Manual Intersitial Tank-to Fibergla Fiber	ass tank: level of monitoring fluid within normal range and fiberglass tanks, vacuum level is within tolerance ap sump inspected and no liquid found are present, in good condition, seated firmly on correct tank	YES	NO	x x
(MIMT) Steel at Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers Sumps Sumps Spill-Containment Manhole Drain vi Standa Drop Tube Tank Gauge Stick Check for Water No wate	ond fiberglass tanks, vacuum level is within tolerance op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	x
Manual Intersitial Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All covers Piping Sumps Dispens Sumps Spill-Containment Manhole Drain vis Standa Drop Tube Top edgedge of Tank Gauge Stick Tank gar	op sump inspected and no liquid found ers present, in good condition, seated firmly on correct tank	YES	NO	х
Monitoring for Piping (MIMP) All Tanks Grade-Level Covers All covers Sumps Dispension Sumps Sumps Spill-Containment Manhole Drain vibration Drop Tube Tank Gauge Stick Tank garenteed Tank	ers present, in good condition, seated firmly on correct tank	YES	NO	
(MIMP) All Tanks Grade-Level Covers All covers Sumps Dispense Sumps Spill-Containment Manhole Drain views Drop Tube Tank Gauge Stick Tank garenteed To the Contain Gauge Stick Tank garenteed To the Contain Gauge Stick Tank garenteed Tank Gauge Stick Tank	ers present, in good condition, seated firmly on correct tank	YES	NO	
All Tanks Grade-Level Covers All covers Sumps Dispensions Sumps Spill-Containment Spill-Containment Manhole Drain views Drop Tube Tank Gauge Stick Tank garenteed Tank Gauge Stick		YES	NO	Ν/Δ
Grade-Level Covers All covers Sumps Dispensions Sump s Spill-Containment Spill-Co Manhole Drain vi Standa Drop Tube Top edge of Tank Gauge Stick Tank gauge Stick No water		YES	NO	N/A
Sumps Dispension Sump s Spill-Containment Spill-Co Manhole Drain vi Standa Drop Tube Top edge of Tank Gauge Stick Tank gar Check for Water No water				14/7
Sumps Dispens Sump s Spill-Containment Manhole Drain vi Standa Drop Tube Tank Gauge Stick Check for Water Dispens Spill-Co Spill-Co Spill-Co Spill-Co Spill-Co Spill-Co Spill-Co Spill-Co Spill-Co Standa Top ed edge of Tank Gauge Stick No water	sump free of product/liquid and is in good condition			
Sump s Spill-Containment Spill-Co Manhole Drain v Standa Drop Tube Top edge of Tank Gauge Stick Tank ga Check for Water No wate				
Spill-Containment Spill-Containment Manhole Drain volume Standa Top edge of Tank Gauge Stick Tank garantee Check for Water No water	ser sump free of product/liquid and is in good condition			х
Manhole Drain v. Standa Drop Tube Top edge of Tank Gauge Stick Tank gauge Stick No water	ensors are correctly situated at bottom of sump			х
Drop Tube Top edge of Tank Gauge Stick Tank gauge Stick Check for Water No wate	ontainment manhole in good condition			
Drop Tube Top edge of Tank Gauge Stick Tank gauge Stick Check for Water No wate	alve in spill-containment manhole in good condition			
Drop Tube Top edge of Tank Gauge Stick Tank ga Check for Water No wate	rd drop tube smooth, no ragged edges, in good condition			Х
edge of Tank Gauge Stick Tank ga Check for Water No wate	ge of coaxial drop tube smooth, round, slightly below the top			
Tank Gauge Stick Tank ga Check for Water No water	the fill pipe			X
Check for Water No water	auge stick can be clearly read, is not warped or broken	1		1
	er present in tank	1		1
Tank vonto vont oc	p present, vent pipe solidly supported and vertical	1		+
Dispenser	p process, vericipies serially supported and vertical	YES	NO	N/A
	ars, leaks, holes, kinks, crimps or defects of any kind	ILS	INO	1
	clean; free of leaks, wear or corrosion			X
	clean, free or leaks, wear or corrosion	VEC	NO	X
Stage I Vapor Recovery		YES	NO	N/A
·	present, colored orange, seated firmly at grade, not broken,			x
	d or chipped			
Point) Vapor IVO dirt,	trash, water or product			X
Possyon/	cks, bulges or holes			Х
vaporr	ecovery cap present, seals tightly			Х
Poppet	of vapor recovery adaptor seals tightly			Х
Transfer Areas		YES	NO	N/A
Releases have been reported	and cleaned in accordance with applicable requirements			Х
Observation and Monitoring		YES	NO	N/A
Observation well cover is prop				Х
Corrosion Protection			NO	N/A
Record		YES		
Impressed-Current Record	erly identified and secured	YES		X
Lainooic Profection T	erly identified and secured volt and amp readings, consistent with prior months	YES		Х
DEFICIENCIES/COMMENTS	erly identified and secured	YES		x

Tank ID:	[#25]	Heating Plant- Tank#6	(50k-gal Diesel)

Inspector:

Date:				
UST Monthly Insp	pection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommoda	te CT DEEF	Regulation	s:
Item		Status		
Leak Detection Reco	rd Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Descion to detect on a trainted and arranged filed			
Gauge (ATG)	Passing tank test report printed and properly filed			Х
Continuous Interstitial	Consequently, we next writed and wromenly filed	i		
Monitoring (CIM)	Sensor status report printed and properly filed			
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			v
Test (MPLT)	rassing piping leak-lest report printed/documented and properly filed			Х
Statistical Inventory	This month's inventory analyzed; last month's results passed and			v
Reconciliation (SIR)	available for inspection			Х
Inventory Central (IC)	Inventory reconciled and within the company and regulatory standard			, , , , , , , , , , , , , , , , , , ,
inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			Х
Manual Groundwater				
(GWM) or Soil-Vapor	Wells sampled and results pass			x
Monitoring (SVM)				
Manual Interstitial	Steel tank: interstitial space checked and found dry	ì		Х
	Fiberglass tank: interstital space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			Х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial				
Monitoring for Piping	Tank-top sump inspected and no liquid found			х
(MIMP)				
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			х
	Sump sensors are correctly situated at bottom of sump			Х
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			
	Standard drop tube smooth, no ragged edges, in good condition			Х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			,,
	edge of the fill pipe			Х
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
Dispenser hoses are f	ree of tears, leaks, holes, kinks, crimps or defects of any kind			Х
Dispenser cabinents in	nterior is clean; free of leaks, wear or corrosion			Х
Stage I Vapor Recove	ery	YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			
Two Doint (Dual	cracked or chipped			Х
Two-Point (Dual	No dirt, trash, water or product			х
Point) Vapor	No cracks, bulges or holes			х
Recovery	Vapor recovery cap present, seals tightly			х
	Poppet of vapor recovery adaptor seals tightly			Х
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			Х
Observation and Mor	•	YES	NO	N/A
	r is properly identified and secured			X
Corrosion Protection	· · · ·	YES	NO	N/A
	Record volt and amp readings, consistent with prior months			X
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			
Cathodic Protection	hours each month			Х
DEFICIENCIES/COM	MENTS:			

Tank ID: [#28] Motor Pool - 10,000-gal [GASOLINE] Inspector: Date:

	ction Checklist is based off PEI RP900 Inspection Form to accommoda		Regulation	S.
tem		Status		
eak Detection Reco				
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			×
Gauge (ATG)	adding tark toot report printed and properly med			_ ^
Continuous Interstitial Monitoring (CIM)	Sensor status report printed and properly filed			
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory Reconciliation (SIR)	This month's inventory analyzed; last month's results passed and available for inspection			х
nventory Control (IC)	Inventory reconciled and within the company and regulatory standard			х
M 10 11				
Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM)	Wells sampled and results pass			х
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
	Fiberglass tank: interstital space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			Х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			х
Manual Intersitial Monitoring for Piping (MIMP)	Tank-top sump inspected and no liquid found			х
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank	i i		
Orado-Lever Govers	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition	i		
'	Sump sensors are correctly situated at bottom of sump			i i
Spill-Containment	Spill-Containment manhole in good condition			<u> </u>
Manhole	Drain valve in spill-containment manhole in good condition			†
	Standard drop tube smooth, no ragged edges, in good condition			х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			
Diop rubo	edge of the fill pipe			
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken	l		
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser	vent cap present, vent pipe solidly supported and vertical	YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind	TES	NO	IN//-
	nterior is clean; free of leaks, wear or corrosion			
Stage I Vapor Recove		YES	NO	N/A
blage i vapor Recovi	•	TES	NO	IN/F
	Cover present, colored orange, seated firmly at grade, not broken,			
Two-Point (Dual	cracked or chipped No dirt, trash, water or product			<u> </u>
Point) Vapor				
Recovery	No cracks, bulges or holes	<u> </u>		<u> </u>
·	Vapor recovery cap present, seals tightly			
	Poppet of vapor recovery adaptor seals tightly	\/= -		
Transfer Areas		YES	NO	N/A
Releases have been reported and cleaned in accordance with applicable requirements				Х
Observation and Mo		YES	NO	N/A
	r is properly identified and secured			
Corrosion Protection		YES	NO	N/A
mpressed-Current	Record volt and amp readings, consistent with prior months			Х
mprosseu-ourrent	Record hour meter reading (if present). Readings increases by 700			

Tank ID: [# 29] Motor Pool - 10,000-gal [DIESEL]

UST Monthly Insp	pection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommodat	te CT DEEF	Regulation	is:
Item		Status		
Leak Detection Reco	rd Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			v
Gauge (ATG)	assing tank test report printed and properly med			Х
Continuous Interstitial	Sensor status report printed and properly filed			
Monitoring (CIM)	ones, status report printed and property med			
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			x
Test (MPLT)				
Statistical Inventory	This month's inventory analyzed; last month's results passed and			x
Reconciliation (SIR)	available for inspection			
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			
Manual Groundwater				
	Wells sampled and results pass			x
Monitoring (SVM)	' '			
	Steel tank: interstitial space checked and found dry			Х
Manual Interstitial	Fiberglass tank: interstital space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			х
Manual Intersitial				
Monitoring for Piping	Tank-top sump inspected and no liquid found			×
(MIMP)				
All Tanks		YES	NO	N/A
	All covers present, in good condition, seated firmly on correct tank			
0.000 20.00 00.00	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			
'	Sump sensors are correctly situated at bottom of sump			
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			
	Standard drop tube smooth, no ragged edges, in good condition			
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			
2.06.000	edge of the fill pipe			
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			<u> </u>
Check for Water	No water present in tank		! 	
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			†
Dispenser	Train dup produit, vant pipe deliary dupported and vertical	YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind	120	110	1 11//-1
	nterior is clean; free of leaks, wear or corrosion			
Stage I Vapor Recove		YES	NO	N/A
Clage I Vapol Recove	Cover present, colored orange, seated firmly at grade, not broken,	ILO	I	I IV/A
	cracked or chipped			х
Two-Point (Dual	No dirt, trash, water or product			. v
Point) Vapor	No cracks, bulges or holes			X
Recovery	Vapor recovery cap present, seals tightly			X
	Poppet of vapor recovery adaptor seals tightly			X
Transfer Areas	i oppor or vapor receivery adaptor seals lightly	YES	NO	N/A
Releases have been reported and cleaned in accordance with applicable requirements		TES	INO	
Observation and Mor		YES	NIO	N/A
	r is properly identified and secured	IES	NO	IN/A
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months	ILO	NO	
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			X
Cathodic Protection	hours each month			х
DEFICIENCIES:	IIIOUIS GAGITIIOIIIII			
DEI TOILIVOIES.				

Tank ID: [#32] Northwood Lift Station [DIESEL]

UST Monthly Insp	pection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommodat	te CT DEEF	Regulation	IS:
Item		Status		
Leak Detection Reco	rd Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			v
Gauge (ATG)	assing tank test report printed and properly med			Х
Continuous Interstitial	Sensor status report printed and properly filed			
Monitoring (CIM)	ones, status report printed and property med			
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			x
Test (MPLT)				
Statistical Inventory	This month's inventory analyzed; last month's results passed and			x
Reconciliation (SIR)	available for inspection			
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			x
Manual Groundwater				
	Wells sampled and results pass			x
Monitoring (SVM)	' '			
	Steel tank: interstitial space checked and found dry			Х
Manual Interstitial	Fiberglass tank: interstital space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			х
Manual Intersitial	_			
Monitoring for Piping	Tank-top sump inspected and no liquid found			×
(MIMP)				
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			1
	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			Х
'	Sump sensors are correctly situated at bottom of sump			х
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			
	Standard drop tube smooth, no ragged edges, in good condition			х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			
2.34 . 3 3	edge of the fill pipe			x
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			х
Check for Water	No water present in tank			, , ,
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser	· · · · · · · · · · · · · · · · · · ·	YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind	120	110	X
	nterior is clean; free of leaks, wear or corrosion			X
Stage I Vapor Recove		YES	NO	N/A
Jugo Fupor Necove	Cover present, colored orange, seated firmly at grade, not broken,	123		14/7
	cracked or chipped			х
Two-Point (Dual	No dirt, trash, water or product			х
Point) Vapor	No cracks, bulges or holes			X
Recovery	Vapor recovery cap present, seals tightly			X
	Poppet of vapor recovery adaptor seals tightly			X
Transfer Areas	- opportor rapor rosovory adaptor socio agritty	YES	NO	N/A
Releases have been reported and cleaned in accordance with applicable requirements		120	110	X
Observation and Mor		YES	NO	N/A
	r is properly identified and secured	ILO	INO .	TN//A
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months	ILO	110	
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			X
Cathodic Protection	hours each month			х
DEFICIENCIES:	niodro odon monut			
DEI TOILIVOILS.				

Tank ID: [#35] Plant Science [ULSD]

Inspector:

Date: UST Monthly Inspection Checklist (PEI RP900) Monthly Inspection Checklist is based off PEI RP900 Inspection Form to accommodate CT DEEP Regulations: Status Leak Detection Record Keeping ATG, CIM, SIR, IC, GWM, SVM Type: ATG YES NO N/A Tank Leak Detection Piping Leak Detection CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A Automatic Tank Passing tank test report printed and properly filed Х Gauge (ATG) Continuous Interstitial Sensor status report printed and properly filed Monitoring (CIM) Monthly Piping Leak Passing piping leak-test report printed/documented and properly filed Х Test (MPLT) Statistical Inventory This month's inventory analyzed; last month's results passed and Х Reconciliation (SIR) available for inspection Inventory reconciled and within the company and regulatory standard Inventory Control (IC) Manual Groundwater Wells sampled and results pass (GWM) or Soil-Vapor Х Monitoring (SVM) Steel tank: interstitial space checked and found dry Х Manual Interstitial Fiberglass tank: interstital space checked and found dry Х Monitoring for Tanks Fiberglass tank: level of monitoring fluid within normal range Х (MIMT) Steel and fiberglass tanks, vacuum level is within tolerance Х Manual Intersitial Monitoring for Piping Tank-top sump inspected and no liquid found Х (MIMP) All Tanks YES NO N/A All covers present, in good condition, seated firmly on correct tank Grade-Level Covers Piping sump free of product/liquid and is in good condition Sumps Dispenser sump free of product/liquid and is in good condition Х Sump sensors are correctly situated at bottom of sump Х Spill-Containment manhole in good condition Spill-Containment Drain valve in spill-containment manhole in good condition Manhole Standard drop tube smooth, no ragged edges, in good condition Х **Drop Tube** Top edge of coaxial drop tube smooth, round, slightly below the top Х edge of the fill pipe Tank gauge stick can be clearly read, is not warped or broken Tank Gauge Stick х Check for Water No water present in tank Tank Vents Vent cap present, vent pipe solidly supported and vertical YES Dispenser NO N/A Dispenser hoses are free of tears, leaks, holes, kinks, crimps or defects of any kind Х Dispenser cabinents interior is clean; free of leaks, wear or corrosion Х YES NO N/A Stage I Vapor Recovery Cover present, colored orange, seated firmly at grade, not broken, Х cracked or chipped Two-Point (Dual No dirt, trash, water or product Х Point) Vapor No cracks, bulges or holes Х Recovery Vapor recovery cap present, seals tightly Х Poppet of vapor recovery adaptor seals tightly Х Transfer Areas YES NO N/A Releases have been reported and cleaned in accordance with applicable requirements Х **Observation and Monitoring Wells** YES NO N/A Observation well cover is properly identified and secured **Corrosion Protection** YES NO N/A Record volt and amp readings, consistent with prior months Impressed-Current

Record hour meter reading (if present). Readings increases by 700

Х

DEFICIENCIES:

Cathodic Protection

hours each month

Tank ID: [#36] Plant Science [ULSD]

Inspector: Date: UST Monthly Inspection Checklist (PEI RP900)

Item Leak Detection Reco Tank Leak Detection Piping Leak Detection Automatic Tank Gauge (ATG)	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	Status	regulation	15.
Leak Detection Reco Tank Leak Detection Piping Leak Detection Automatic Tank Gauge (ATG)	ATG, CIM, SIR, IC, GWM, SVM Type: ATG			
Tank Leak Detection Piping Leak Detection Automatic Tank Gauge (ATG)	ATG, CIM, SIR, IC, GWM, SVM Type: ATG			4/
Piping Leak Detection Automatic Tank Gauge (ATG)	• •	I YES I	NO	N/A
Automatic Tank Gauge (ATG)	TIVE IN CANNING SOUND IN THE TABLE IN A			
Gauge (ATG)				
	Passing tank test report printed and properly filed			х
Continuous Interstitial				
	Sensor status report printed and properly filed	l ,	ĺ	
Monthly Pining Leak				
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			х
Test (MPLT)				
Statistical Inventory	This month's inventory analyzed; last month's results passed and			x
Reconciliation (SIR)	available for inspection			
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			x
, ,				
Manual Groundwater				
(GWM) or Soil-Vapor	Wells sampled and results pass			Х
Monitoring (SVM)				
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: interstital space checked and found dry			Х
(MIMT)	Fiberglass tank: level of monitoring fluid within normal range			Х
	Steel and fiberglass tanks, vacuum level is within tolerance			х
Manual Intersitial				
Monitoring for Piping	Tank-top sump inspected and no liquid found			х
(MIMP)				
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
Orado Esta. Ca.	Piping sump free of product/liquid and is in good condition	 		+
Sumps	Dispenser sump free of product/liquid and is in good condition			х
Campo	Sump sensors are correctly situated at bottom of sump			X
Spill-Containment	Spill-Containment manhole in good condition			, , , , , , , , , , , , , , , , , , ,
·	Drain valve in spill-containment manhole in good condition	 		+
Manhole				
	Standard drop tube smooth, no ragged edges, in good condition			X
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			x
	edge of the fill pipe			
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			Х
Check for Water	No water present in tank	<u> </u>	Γ <u></u>	
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind			X
	nterior is clean; free of leaks, wear or corrosion			X
Stage I Vapor Recove	·	YES	NO	N/A
Stage I Vapor 11555	Cover present, colored orange, seated firmly at grade, not broken,	120	110	1 7/1
	cracked or chipped			х
Two-Point (Dual	No dirt, trash, water or product			
Point) Vapor				X
Recovery	No cracks, bulges or holes			X
	Vapor recovery cap present, seals tightly			Х
	Poppet of vapor recovery adaptor seals tightly	YES		Х
			NO	N/A
Transfer Areas	Releases have been reported and cleaned in accordance with applicable requirements			Х
Releases have been re				
Releases have been re Observation and Mor	nitoring Wells	YES	NO	N/A
Releases have been re Observation and Mor		YES	NO	N/A
Releases have been re Observation and Mor	nitoring Wells r is properly identified and secured	YES YES	NO NO	N/A N/A
Releases have been re Observation and Mor Observation well cover Corrosion Protection	nitoring Wells r is properly identified and secured			N/A
Releases have been re Observation and Mor Observation well cove Corrosion Protection Impressed-Current	r is properly identified and secured Record volt and amp readings, consistent with prior months			N/A x
Releases have been re Observation and Mor Observation well cover Corrosion Protection	nitoring Wells r is properly identified and secured			N/A

Tank ID: **[#39] Psychology** [3,000-gal DIESEL]

Inspector: Date:

	pection Checklist (PEI RP900)	(- OT DEED	. D ! - ! '	
	ction Checklist is based off PEI RP900 Inspection Form to accommodate		Regulation	is:
tem	ud Kaanina	Status		
eak Detection Reco		VEC	NO	N1/A
Fank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			x
Gauge (ATG)				
Continuous Interstitial	Sensor status report printed and properly filed			x
Monitoring (CIM)				
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory Reconciliation (SIR)	This month's inventory analyzed; last month's results passed and available for inspection			х
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			х
Manual Groundwater				
(GWM) or Soil-Vapor	Wells sampled and results pass			x
Monitoring (SVM)	TVOID Sumpled and results pass			^
	Steel tank: interstitial space checked and found dry			Х
Manual Interstitial	Fiberglass tank: interstital space checked and found dry			X
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			X
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			×
Manual Intersitial	Contains in the second contains of the second contains to the seco			 ^
Monitoring for Piping (MIMP)	Tank-top sump inspected and no liquid found			х
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			Х
	Sump sensors are correctly situated at bottom of sump			х
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			х
	Standard drop tube smooth, no ragged edges, in good condition			х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			
2.56 . 3.55	edge of the fill pipe			X
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			х
Check for Water	No water present in tank			<u> </u>
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
	vent dap present, vent pipe solidly supported and ventical	YES	NO	N/A
Dispenser	ree of tears, leaks, holes, kinks, crimps or defects of any kind	TES	NO	
	nterior is clean; free of leaks, wear or corrosion			X
		VEC	NO	X NI/A
Stage I Vapor Recov		YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			x
Two-Point (Dual	cracked or chipped			
Point) Vapor	No dirt, trash, water or product			X
Recovery	No cracks, bulges or holes			Х
	Vapor recovery cap present, seals tightly			Х
	Poppet of vapor recovery adaptor seals tightly			Х
		YES	NO	N/A
		TES		
Releases have been r	eported and cleaned in accordance with applicable requirements	TES		Х
Releases have been r Observation and Mo	nitoring Wells	YES	NO	Х
Releases have been r Observation and Mo		YES x		Х
Releases have been r Observation and Mo Observation well cove	nitoring Wells r is properly identified and secured	YES		X N/A
Releases have been r Observation and Mo Observation well cove Corrosion Protection	nitoring Wells r is properly identified and secured	YES x	NO	X N/A
Observation and Mo	nitoring Wells r is properly identified and secured	YES x	NO	X N/A N/A

Tank ID: [#40] Isolation Farm [ULSD]

Inspector: Date:

UUI MUULLIIV IIIUM	ection Checklist (PEI RP900)			
	ction Checklist is based off PEI RP900 Inspection Form to accommodat	te CT DEEF	Regulation	ns:
em	7000 0100 mat 10 0000 011 = 11 m 000 map 0 11 m	Status	7.03	<u>. </u>
eak Detection Recor	rd Keeping			
Γank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank				.,
Gauge (ATG)	Passing tank test report printed and properly filed			Х
Continuous Interstitial	Sensor status report printed and properly filed			
Monitoring (CIM)	Sensor status report printed and property med			
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory	This month's inventory analyzed; last month's results passed and			
•	available for inspection			х
, ,	Inventory reconciled and within the company and regulatory standard			х
Manual Groundwater				
(GWM) or Soil-Vapor	Wells sampled and results pass			х
Monitoring (SVM)				
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
M::	Fiberglass tank: interstital space checked and found dry			х
(NAINAT)	Fiberglass tank: level of monitoring fluid within normal range			х
· · ·	Steel and fiberglass tanks, vacuum level is within tolerance			х
Manual Intersitial Monitoring for Piping (MIMP)	Tank-top sump inspected and no liquid found			x
All Tanks		YES	NO	N/A
	All covers present, in good condition, seated firmly on correct tank	YES	NO	IN/A
	Piping sump free of product/liquid and is in good condition	 		1
Sumps	Dispenser sump free of product/liquid and is in good condition			
Sumps	Sump sensors are correctly situated at bottom of sump			X
Spill-Containment	Spill-Containment manhole in good condition			X
Manhole	Drain valve in spill-containment manhole in good condition	 	<u> </u> 	-
IVIALILIOIE	Standard drop tube smooth, no ragged edges, in good condition			- v
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			X
-	edge of the fill pipe			х
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			х
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
Dispenser hoses are fr	ree of tears, leaks, holes, kinks, crimps or defects of any kind			Х
<u> </u>	nterior is clean; free of leaks, wear or corrosion			Х
Stage I Vapor Recove	·	YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			×
	cracked or chipped			^
Point) Vapor	No dirt, trash, water or product			х
Recovery	No cracks, bulges or holes			Х
•	Vapor recovery cap present, seals tightly			х
	Poppet of vapor recovery adaptor seals tightly			Х
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			Х
Observation and Mon		YES	NO	N/A
Observation well cover	r is properly identified and secured	7/20	110	21/0
		YES	NO	N/A
Corrosion Protection				X
Corrosion Protection	Record volt and amp readings, consistent with prior months			 ^
Corrosion Protection Impressed-Current Cathodic Protection	Record volt and amp readings, consistent with prior months Record hour meter reading (if present). Readings increases by 700 hours each month			x

Tank ID: [#41] Isolation Farm [ULSD]

Inspector:

Date: UST Monthly Inspection Checklist (PEI RP900) Monthly Inspection Checklist is based off PEI RP900 Inspection Form to accommodate CT DEEP Regulations: Status Leak Detection Record Keeping ATG, CIM, SIR, IC, GWM, SVM Type: ATG YES NO N/A Tank Leak Detection Piping Leak Detection CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A Automatic Tank Passing tank test report printed and properly filed Х Gauge (ATG) Continuous Interstitial Sensor status report printed and properly filed Monitoring (CIM) Monthly Piping Leak Passing piping leak-test report printed/documented and properly filed Х Test (MPLT) Statistical Inventory This month's inventory analyzed; last month's results passed and Х Reconciliation (SIR) available for inspection Inventory reconciled and within the company and regulatory standard Inventory Control (IC) Manual Groundwater Wells sampled and results pass (GWM) or Soil-Vapor Х Monitoring (SVM) Steel tank: interstitial space checked and found dry Х Manual Interstitial Fiberglass tank: interstital space checked and found dry Х Monitoring for Tanks Fiberglass tank: level of monitoring fluid within normal range Х (MIMT) Steel and fiberglass tanks, vacuum level is within tolerance Х Manual Intersitial Monitoring for Piping Tank-top sump inspected and no liquid found Х (MIMP) All Tanks YES NO N/A All covers present, in good condition, seated firmly on correct tank Grade-Level Covers Piping sump free of product/liquid and is in good condition Sumps Dispenser sump free of product/liquid and is in good condition Х Sump sensors are correctly situated at bottom of sump Х Spill-Containment manhole in good condition Spill-Containment Drain valve in spill-containment manhole in good condition Manhole Standard drop tube smooth, no ragged edges, in good condition Х **Drop Tube** Top edge of coaxial drop tube smooth, round, slightly below the top Х edge of the fill pipe Tank gauge stick can be clearly read, is not warped or broken Tank Gauge Stick х Check for Water No water present in tank Tank Vents Vent cap present, vent pipe solidly supported and vertical YES Dispenser NO N/A Dispenser hoses are free of tears, leaks, holes, kinks, crimps or defects of any kind Х Dispenser cabinents interior is clean; free of leaks, wear or corrosion Х YES NO N/A Stage I Vapor Recovery Cover present, colored orange, seated firmly at grade, not broken, Х cracked or chipped Two-Point (Dual No dirt, trash, water or product Х Point) Vapor No cracks, bulges or holes Х Recovery Vapor recovery cap present, seals tightly Х Poppet of vapor recovery adaptor seals tightly Х Transfer Areas YES NO N/A Releases have been reported and cleaned in accordance with applicable requirements Х **Observation and Monitoring Wells** YES NO N/A Observation well cover is properly identified and secured **Corrosion Protection** YES NO N/A Record volt and amp readings, consistent with prior months Impressed-Current Record hour meter reading (if present). Readings increases by 700 Cathodic Protection Х hours each month **DEFICIENCIES:**

Tank ID: [#45] Wastewater-Head [DIESEL] Inspector: Date:

UST Monthly Insp	pection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommodat	te CT DEEP	Regulation	s:
Item		Status		
Leak Detection Reco	rd Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Passing tank test report printed and properly filed			
Gauge (ATG)	Passing tank test report printed and properly filed			Х
Continuous Interstitial	Sensor status report printed and properly filed			v
Monitoring (CIM)	Status report printed and properly filed			Х
Monthly Piping Leak	Passing piping leak-test report printed/documented and properly filed			v
Test (MPLT)				Х
Statistical Inventory	This month's inventory analyzed; last month's results passed and			х
Reconciliation (SIR)	available for inspection			^
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			х
Manual Groundwater				
	Wells sampled and results pass			х
Monitoring (SVM)	Tivelis sampled and results pass			^
	Steel tank: interstitial space checked and found dry			Х
Manual Interstitial	Fiberglass tank: interstital space checked and found dry			X
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			Х
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial	,			
Monitoring for Piping	Tank-top sump inspected and no liquid found			Х
(MIMP)				
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			1 3/1 2
0.440 2010.0010.0	Piping sump free of product/liquid and is in good condition			
	Dispenser sump free of product/liquid and is in good condition			Х
	Sump sensors are correctly situated at bottom of sump			
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			
	Standard drop tube smooth, no ragged edges, in good condition			
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			
	edge of the fill pipe			Х
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
Dispenser hoses are f	ree of tears, leaks, holes, kinks, crimps or defects of any kind			X
	nterior is clean; free of leaks, wear or corrosion			X
Stage I Vapor Recove		YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			
-	cracked or chipped			Х
Two-Point (Dual	No dirt, trash, water or product			Х
Point) Vapor	No cracks, bulges or holes			Х
Recovery	Vapor recovery cap present, seals tightly			Х
	Poppet of vapor recovery adaptor seals tightly			Х
Transfer Areas	,	YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			Х
Observation and Mor		YES	NO	N/A
	r is properly identified and secured			X
Corrosion Protection		YES	NO	N/A
	Record volt and amp readings, consistent with prior months			X
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			
Cathodic Protection	hours each month			Х
DEFICIENCIES:				
I				

Tank ID: Wastewater- Control [#2 HEATING OIL]

Inspector:
Date:

•	pection Checklist (PEI RP900)			
Monthly Inspe	ction Checklist is based off PEI RP900 Inspection Form to accommoda	te CT DEEP	Regulation	ns:
ltem		Status		
Leak Detection Reco				
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank Gauge (ATG)	Passing tank test report printed and properly filed			х
Continuous Interstitial Monitoring (CIM)	Sensor status report printed and properly filed			х
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory Reconciliation (SIR)	This month's inventory analyzed; last month's results passed and available for inspection			х
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			х
Manual Groundwater				
(GWM) or Soil-Vapor Monitoring (SVM)	Wells sampled and results pass			х
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: interstital space checked and found dry			Х
(MIMT)	Fiberglass tank: level of monitoring fluid within normal range			Х
. ,	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial Monitoring for Piping (MIMP)	Tank-top sump inspected and no liquid found			х
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			Х
	Sump sensors are correctly situated at bottom of sump			
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			
	Standard drop tube smooth, no ragged edges, in good condition			Х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top edge of the fill pipe			х
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			
Check for Water	No water present in tank	1		
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser	vent cap present, vent pipe solidly supported and vertical	YES	NO	NI/A
	roo of toors, looks, holos, kinks, arimns or defeats of any kind	TES	NO	N/A
	ree of tears, leaks, holes, kinks, crimps or defects of any kind nterior is clean; free of leaks, wear or corrosion			X
Stage I Vapor Recove		YES	NO	
Stage i vapor Recovi	Cover present, colored orange, seated firmly at grade, not broken,	TES	INO	N/A x
Two-Point (Dual	cracked or chipped			
Point) Vapor	No dirt, trash, water or product			Х
Recovery	No cracks, bulges or holes			Х
•	Vapor recovery cap present, seals tightly			X
T	Poppet of vapor recovery adaptor seals tightly	\/F0	NO	X
Transfer Areas	onorted and cleaned in accordance with applicable requirements	YES	NO	N/A
	eported and cleaned in accordance with applicable requirements	VEO	NO	X NI/A
Observation and Mor		YES	NO	N/A
Corrosion Protection	r is properly identified and secured	VEC	NO	X NI/A
Corrosion Protection		YES	NO	N/A
Impressed-Current Cathodic Protection	Record volt and amp readings, consistent with prior months Record hour meter reading (if present). Readings increases by 700 hours each month			X
DEFICIENCIES:	production and the state of the			

Tank ID:	[#52]	Supplemental Utility Plant	(30k-gal Diesel)
Inspector:			

Date:

	ction Checklist is based off PEI RP900 Inspection Form to accommoda	IC OT DELT	rtogulation	<u>s.</u>
tem		Status		
Leak Detection Reco				
Γank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type: ATG	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type: N/A			
Automatic Tank	Descine tout test report printed and preparity filed			
Gauge (ATG)	Passing tank test report printed and properly filed			X
Continuous Interstitial	Sensor status report printed and properly filed			
Monitoring (CIM)	Sensor status report printed and property filed			
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			х
Statistical Inventory	This month's inventory analyzed; last month's results passed and			
Reconciliation (SIR)	available for inspection			X
nventory Control (IC)	Inventory reconciled and within the company and regulatory standard			Х
Manual Groundwater				
(GWM) or Soil-Vapor	Wells sampled and results pass			x
Monitoring (SVM)	Vivolio dallipiod dila rodallo pado			^
	Steel tank: interstitial space checked and found dry			X
Manual Interstitial	Fiberglass tank: interstital space checked and found dry			X
Monitoring for Tanks	Fiberglass tank: level of monitoring fluid within normal range			X
(MIMT)	Steel and fiberglass tanks, vacuum level is within tolerance			i
Manual Intersitial	Oteel and liberglass tarks, vacuum level is within tolerance			X
	Tank ton aumn inapacted and no liquid found			.,
Monitoring for Piping	Tank-top sump inspected and no liquid found			X
(MIMP)		1/50	110	21/2
All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
_	Piping sump free of product/liquid and is in good condition			
Sumps	Dispenser sump free of product/liquid and is in good condition			Х
	Sump sensors are correctly situated at bottom of sump			Х
Spill-Containment	Spill-Containment manhole in good condition			
Manhole	Drain valve in spill-containment manhole in good condition			
	Standard drop tube smooth, no ragged edges, in good condition			Х
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top			.,
	edge of the fill pipe			X
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
Dispenser		YES	NO	N/A
•	ree of tears, leaks, holes, kinks, crimps or defects of any kind			X
	terior is clean; free of leaks, wear or corrosion			X
Stage I Vapor Recov		YES	NO	N/A
Jiage i vapoi Recov	Cover present, colored orange, seated firmly at grade, not broken,	123	NO	IN/A
				x
Two-Point (Dual	cracked or chipped			
Point) Vapor	No dirt, trash, water or product			X
Recovery	No cracks, bulges or holes			Х
,	Vapor recovery cap present, seals tightly			Х
	Poppet of vapor recovery adaptor seals tightly			X
Transfer Areas		YES	NO	N/A
	eported and cleaned in accordance with applicable requirements			х
Observation and Mo		YES	NO	N/A
Observation well cove	r is properly identified and secured			Х
Corrosion Protection	1	YES	NO	N/A
	Record volt and amp readings, consistent with prior months			Х
mpressed-Current Cathodic Protection	Record hour meter reading (if present). Readings increases by 700			
	, , , , , , , , , , , , , , , , , , , ,	-		Х

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 03 - Mansfield Apartment Lift Station Date:			
Inspector:	<u> </u>			
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			Х
	safe wiring in good condition			^
All STP E	Mechanical line-leak detector properly vented, vent tube not kinked			X
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
All STP	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			^
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			X
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
	piping are not in contact with soil or are cathodically protected			, ,
No STP Sump	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			_ ^
	system only)			X
STD in Sumn	Entire interstitial space under pressure or vacuum (closed piping			
STP in Sump	system only)			X
	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
All STP No STP Sump STP in Sump RP900 8.6 - Other Tar Other Tank-Top Sump (Same	all bolts present, handles and lift mechanism in good condition			
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
011 - 1 -	Alarm sounds when pressure or vacuum is released (closed piping			.,
	system only)			X
	Entire interstitial space under pressure or vacuum (closed piping			
Procedure as STP	system only)			X
Sump)	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			x
(Same Procedure as	Entire interstitial space under pressure or vacuum (closed piping			
` STP Sump)	system only)			x
1,	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Man	ihole	YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
470.44	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area		YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow			1 477 1
Drop Tube	diffuser present)			
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			.,
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	N/A
D T 1 01 1 "	Valve moves freely and operates according to manufacturer's			
Drop Tube Shutoff	specifications			X
(Flapper Valve)	Valve installed at proper height			Х
	Ball float can be removed and inspected			Х
Dell Fleet Velve	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
	Alarm sounds at the proper product level			
RP900 8.11 - Leak De	etection	YES	NO	N/A
	Console has no active warnings or alarms	Х		1
	Alarm history shows no recurring leak alarms	X		
ATC Comments	Verify in-tank leak-detection tests are being completed			Х
ATG Console	Verify correct set-up parameters for the in-tank test			Х
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			Х
	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			Х
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			
	"Wet" tank leak-detection liquid depth within proper range			
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms		<u></u>	
	If pressurized piping has been tested in the last year, review the			V
Line Tightness	results and verify that the test passed			X
Testing	If suction piping has been tested within the last three years, review			
	the results and verify that the test passed			X
	Below grade piping operates at less than atmospheric pressure			
Under Pump Check	Below grade piping slopes continuously back to the tank			
Valve (Suction)	There is only one check valve, and it is located as close as			
	practicable to the suction pump		<u> </u>	
_			_	

RP900 8.11 - Leak D	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			_ ^
Continuous Soil-	Sensing device calibrated and tested			X
Vapor Monitoring	Ochsing device camprated and tested			^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi		YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			x
CP	years and test passed			
	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscell	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Consider of deprical even of mean tanke to level, the digital carte ordere			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			x
Collection Points				^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			x
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			Х
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Di		YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			x
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			l x
All Dispensers	manufacturer's specifications			
	Piping in good condition			X
	Stage II piping functional or else capped and sealed at elevation			X
5	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			X
Sumps	or water or are cathodically protected			
Diamana ana Mith	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
<u> </u>	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump			Х
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump			
	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-			Х
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system			X X X
Piping Interstitial Space	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump			X X X
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system			X X X

UST Monthly Insp	pection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 10 - Beach Hall Date:			
Inspector:				
Item		Status		
RP900 7.4		YES	NO	N/A
Daily Inspections	Complete daily checklist and compare to previously completed daily checklists			Х
RP900 7.5 - Leak Det	ection Record Keeping			
Tank Leak Detection	ATG, CIM, SIR, IC, GWM, SVM Type:	YES	NO	N/A
Piping Leak Detection	CIM, MPLT, SIR, GWM, SVM, MIMP Type:			
Automatic Tank Gauge (ATG)	Passing tank test report printed and properly filed			Х
Continuous Interstitial Monitoring (CIM)	Sensor status report printed and properly filed			X
Monthly Piping Leak Test (MPLT)	Passing piping leak-test report printed/documented and properly filed			Х
Statistical Inventory Reconciliation (SIR)	This month's inventory analyzed; last month's results passed and available for inspection			Х
Inventory Control (IC)	Inventory reconciled and within the company and regulatory standard			Х
Manual Groundwater (GWM) or Soil-Vapor Monitoring (SVM)	Wells sampled and results pass			Х
Manual Interstitial	Steel tank: interstitial space checked and found dry			Х
Monitoring for Tanks	Fiberglass tank: interstital space checked and found dry			Х
(MIMT)	Fiberglass tank: level of monitoring fluid within normal range			Х
. ,	Steel and fiberglass tanks, vacuum level is within tolerance			Х
Manual Intersitial Monitoring for Piping (MIMP)	Tank-top sump inspected and no liquid found			x
RP900 7.6 - All Tanks		YES	NO	N/A
Grade-Level Covers	All covers present, in good condition, seated firmly on correct tank			
Spill-Containment Manhole	Drain valve in spill-containment manhole in good condition			
	Standard drop tube smooth, no ragged edges, in good condition			
Drop Tube	Top edge of coaxial drop tube smooth, round, slightly below the top edge of the fill pipe			Х
Tank Gauge Stick	Tank gauge stick can be clearly read, is not warped or broken			X
Check for Water	No water present in tank			
Tank Vents	Vent cap present, vent pipe solidly supported and vertical			
RP900 7.7 - Stage I V		YES	NO	N/A
	Cover present, colored orange, seated firmly at grade, not broken,			X
Two-Point (Dual	cracked or chipped			
Point) Vapor	No dirt, trash, water or product			X
Recovery	No cracks, bulges or holes			X
	Vapor recovery cap present, seals tightly			X
DD000 7.0 O	Poppet of vapor recovery adaptor seals tightly	\/F0	l No	X
	ion and Monitoring Wells	YES	NO	N/A
RP900 7.9 - Corrosio	r is properly identified and secured	YES	NO	X N/A
1.9 - COHOSIO	Record volt and amp readings, consistent with prior months	150	NO	X X
Impressed-Current	Record hour meter reading (if present). Readings increases by 700			
Cathodic Protection	hours each month			X

UST Annual Insp	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 13 - Bio #4 Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate	\(\pi = 0	110	21/2
RP900 8.5 - Submers	sible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
	safe wiring in good condition			
	Mechanical line-leak detector properly vented, vent tube not kinked or twisted			X
	Mechanical line-leak detector passes 3.0 gph test			Х
All STP E	Electronic line-leak detector passes 3.0 gph test			X
7 (11 0 11	Flexible connector not twisted, kinked, or bent beyond			
	manufacturer's specifications			X
	Submersible pump and visible piping and fittings show no signs of			· ·
	leakage			X
	Piping in good condition			Х
No CTD Comes	Submersible pump head, flex connector(s) and other metal product			V
No STP Sump	piping are not in contact with soil or are cathodically protected			Х
No STP Sump	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			X
CTD in Comen	system only) Entire interstitial space under pressure or vacuum (closed piping			
STP in Sump	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Ton	Alarm sounds when pressure or vacuum is released (closed piping			X
Sump (Same	system only)			
Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			X
Sump)	system only) Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			l x l
	Entire interstitial space under pressure or vacuum (closed piping			
` STP Sump)	system only)			Х
1 /	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Mar		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14/7 (
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			<u> </u>
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
DD000 0 0 Fill Amer	ATG probe cap and manhole cover	\/F0	NO	N1/A
RP900 8.9 - Fill Area		YES	NO	N/A
Drop Tube	Drop tube extends to within 6 inches of the tank bottom (if no flow			
2.5p . a.s.	diffuser present)			
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			l x l
	tightly			
RP900 8.10 - Overfill		YES	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			
(Flapper Valve)	specifications			
(i iappei vaive)	Valve installed at proper height			
	Ball float can be removed and inspected			X
Ball-Float Valve	Cage intact, ball in good condition, moves freely, seats firmly;			X
Dall-1 loat valve	breather hole open			^
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
	Alarm sounds at the proper product level			
RP900 8.11 - Leak De	etection	YES	NO	N/A
	Console has no active warnings or alarms	İ		
	Alarm history shows no recurring leak alarms			
4700	Verify in-tank leak-detection tests are being completed			Х
ATG Console	Verify correct set-up parameters for the in-tank test			Х
	Verify correct set-up parameters for electronic line-leak detector			Х
	Verify piping leak-detection tests are being completed			Х
	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			Х
Wormoning	"Wet" tank leak-detection liquid depth within proper range			X
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Defection Mountain	If pressurized piping has been tested in the last year, review the			
Line Tightness	results and verify that the test passed			Х
-				
Testing	If suction piping has been tested within the last three years, review			Х
	the results and verify that the test passed			
Under Division Object	Below grade piping operates at less than atmospheric pressure			
Under Pump Check	Below grade piping slopes continuously back to the tank			
	There is an harmonic about a substitute of the s	ı		
Valve (Suction)	There is only one check valve, and it is located as close as practicable to the suction pump			

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			^
Continuous Soil-	Sensing device calibrated and tested			l x
Vapor Monitoring	densing device camprated and tested			
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi	ion Protection	YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			l x
CP	years and test passed			
G	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			Х
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or conholt over or near tanks is level, no significant cracks			
Pavement	Concrete or asphalt over or near tanks is level, no significant cracks	<u></u>	<u></u>	
Stage II Liquid-	Can in good condition fits tightly, little or no liquid in bottom			Х
Collection Points	Cap in good condition, fits tightly, little or no liquid in bottom			^
Ctage II Teeting	Verify that Stage II testing has been conducted and test results are			Х
Stage II Testing	passing			^
Site Diagram	Site diagram accurately reflects the site conditions			X
RP900 8.14 - Initial Fuel Dispenser Inspection		YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Di	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			V
	safe wiring in good condition			X
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			X
	Piping in good condition			X
	Stage II piping functional or else capped and sealed at elevation			Х
	lower than the fuel dispenser island			^
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			X
Sumps	or water or are cathodically protected			^
	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump			Х
Piping Interstitial	Piping interstitial space closed to the sump			X
Space	Sensor present in the fuel-dispenser sump with closed double-			
	walled piping system			X
D: 0	Sump sensor properly mounted at the bottom of the sump			X
Dispenser Sump	Electronic sensor tested and functional			X
Sensors	Mechanical float sensor free to move and properly adjusted			X
	encies Here:			

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 14 - Commissary Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
	safe wiring in good condition			
	Mechanical line-leak detector properly vented, vent tube not kinked			X
	or twisted			
All STP	Mechanical line-leak detector passes 3.0 gph test			X
	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			X
	Piping in good condition			
No STP Sump	Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected			X
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			V
- · · · · · · · · · · · · · · · · · · ·	system only)			X
	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			V
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			X
Sump (Same	system only)			7.
Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			X
Sump)	system only)			\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \
, ,	Sump sensor properly mounted at the bottom of the sump Sensor tested and functional			X
				X
	Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			
a	an solic prosent, namico ana int medianism in good condition		l	

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			V
All Other Sumps	system only)			Х
(Same Procedure as				Х
STP Sump)	system only)			^
31F Sump)	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			Х
	all bolts present, handles and lift mechanism in good condition			^
RP900 8.8 - ATG Mar		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			Х
	Wire splices sealed and wire in good condition			Х
	Junction box and conduit sealed, in good condition			X
ATG Manhole	Probe and floats in good condition, both floats present and move			
AT S WATHOUT	freely			X
	Verify operation of water- and product-level warnings and alarms			Х
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			Х
RP900 8.9 - Fill Area		YES	NO	N/A
Drop Tube	Drop tube extends to within 6 inches of the tank bottom (if no flow			
Втор тако	diffuser present)			
Vapor-Recovery	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			l x
	tightly	\/=0	110	
RP900 8.10 - Overfill		YES	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications			V
	Valve installed at proper height			X
	Ball float can be removed and inspected			
Ball-Float Valve	Cage intact, ball in good condition, moves freely, seats firmly;			X
	breather hole open			Х
	Installed at proper height			
Over will Alama	Alarm mounted near fills, clearly labeled Alarm is functional			X
Overfill Alarm				
RP900 8.11 - Leak De	Alarm sounds at the proper product level	YES	NO	X
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			X
	Alarm history shows no recurring leak alarms			
ATG Console	Verify in-tank leak-detection tests are being completed			X
	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			X
	Tank interstitial access is present			X
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			X
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			X
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			X
Detection Monitor	or alarms			
Line Till	If pressurized piping has been tested in the last year, review the			X
Line Tightness	results and verify that the test passed			
Testing	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
Under Pump Check	Below grade piping operates at less than atmospheric pressure Below grade piping slopes continuously back to the tank			X
	IBEIOW GRADE DIDING SIGNES CONTINUOUSLY DACK TO THE TANK			. X

Valve (Suction)	There is only one check valve, and it is located as close as		V
	practicable to the suction pump		^

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			_ ^
Continuous Soil-	Sensing device calibrated and tested			l x
Vapor Monitoring	Ochanig device camprated and tested			_ ^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi	on Protection	YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			l x
CP	years and test passed			_ ^
OF .	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or apphalt ever or near tanks is level, no significant cracks			
Pavement	Concrete or asphalt over or near tanks is level, no significant cracks			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			X
Collection Points	Cap in good condition, his lightly, little of no liquid in bottom			^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			X
Stage if resting	passing			
Site Diagram	Site diagram accurately reflects the site conditions			X
RP900 8.14 - Initial F	RP900 8.14 - Initial Fuel Dispenser Inspection		NO	N/A
Initial Dispenser	All dispenser components are clean and dry			
Inspection	If fuel-dispenser sump is present, sump is dry			
RP900 8.15 - Fuel Dis	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			
	Piping in good condition			
	Stage II piping functional or else capped and sealed at elevation			
	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			
Dispensers With	Sump free of trash, debris, and used filters			
Sumps	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump			
Piping Interstitial	Piping interstitial space closed to the sump			
Space	Sensor present in the fuel-dispenser sump with closed double-			
	walled piping system			
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			
Sensors	Electronic sensor tested and functional			
06113013	Mechanical float sensor free to move and properly adjusted			
Describe any Deficie	encies Here:			

UST Annual Inspection Checklist (PEI RP900)				
UST Information				
Tank ID:	UST 15 - Dodd Archive Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate	\/=0	110	21/2
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
All STP	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
	safe wiring in good condition			
	Mechanical line-leak detector properly vented, vent tube not kinked or twisted			X
	Mechanical line-leak detector passes 3.0 gph test			Х
	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			
	manufacturer's specifications			X
	Submersible pump and visible piping and fittings show no signs of			· ·
	leakage			X
	Piping in good condition			Х
No CTD Curer	Submersible pump head, flex connector(s) and other metal product			V
	piping are not in contact with soil or are cathodically protected			Х
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping system only)			X
CTD in Cump	Entire interstitial space under pressure or vacuum (closed piping			
STP in Sump	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			X
Sump (Same Procedure as STP Sump)	system only) Entire interstitial space under pressure or vacuum (closed piping			
	, , , , , , , , , , , , , , , , , , , ,			X
	system only) Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			X
	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Mar		YES	NO	N/A
111 000 010 711 0 11141	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14// (
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	p p	YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow	120	110	14//
Drop Tube	diffuser present)			
=	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	N/A
	Valve moves freely and operates according to manufacturer's			
Drop Tube Shutoff	specifications			
(Flapper Valve)	Valve installed at proper height			
	Ball float can be removed and inspected			Х
Ball-Float Valve	Cage intact, ball in good condition, moves freely, seats firmly;			
Dali-Fluat valve	breather hole open			X
	Installed at proper height			Х
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
	Alarm sounds at the proper product level			
RP900 8.11 - Leak De	etection	YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATG Console	Verify in-tank leak-detection tests are being completed			
ATO COURSULE	Verify correct set-up parameters for the in-tank test			
	Verify correct set-up parameters for electronic line-leak detector			Х
	Verify piping leak-detection tests are being completed			Х
	Tank interstitial access is present			
Continuous Interstitial	,			Х
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			
	"Wet" tank leak-detection liquid depth within proper range			
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
	If pressurized piping has been tested in the last year, review the			l x
Line Tightness	results and verify that the test passed			_ ^
Testing	If suction piping has been tested within the last three years, review			l x
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			X
Under Pump Check	Below grade piping slopes continuously back to the tank			Х
Valve (Suction)	There is only one check valve, and it is located as close as			X
	practicable to the suction pump			

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			^
Continuous Soil-	Sensing device calibrated and tested			l x
Vapor Monitoring	densing device camprated and tested			
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi	ion Protection	YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			l x
CP	years and test passed			
G	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			Х
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or conholt over or near tanks is level, no significant cracks			
Pavement	Concrete or asphalt over or near tanks is level, no significant cracks	<u></u>	<u></u>	
Stage II Liquid-	Can in good condition fits tightly, little or no liquid in bottom			Х
Collection Points	Cap in good condition, fits tightly, little or no liquid in bottom			^
Ctage II Teeting	Verify that Stage II testing has been conducted and test results are			Х
Stage II Testing	passing			^
Site Diagram	Site diagram accurately reflects the site conditions			X
RP900 8.14 - Initial Fuel Dispenser Inspection		YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Di	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			V
	safe wiring in good condition			X
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			X
	Piping in good condition			X
	Stage II piping functional or else capped and sealed at elevation			Х
	lower than the fuel dispenser island			^
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			X
Sumps	or water or are cathodically protected			^
	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump			Х
Piping Interstitial	Piping interstitial space closed to the sump			X
Space	Sensor present in the fuel-dispenser sump with closed double-			
	walled piping system			X
D: 0	Sump sensor properly mounted at the bottom of the sump			X
Dispenser Sump	Electronic sensor tested and functional			X
Sensors	Mechanical float sensor free to move and properly adjusted			X
	encies Here:			

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 16 - Eastwood Road Lift Station Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
All STP	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			X
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			X
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
·	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			_ ^
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
OTT III Guillip	system only)			X
	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	N/A
	Any water or product removed and disposed of properly	i i		
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			Х
Sump (Same	system only)			^
Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			Х
Sump)	system only)			^
Guilip)	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	imps	YES	NO	N/A
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			
(Same Procedure as	Entire interstitial space under pressure or vacuum (closed piping			
` STP Sump)	system only)			
. ,	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			
RP900 8.8 - ATG Mar	•	YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	,	YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow	ILO	140	14// (
Drop Tube	diffuser present)			
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	N/A
	Valve moves freely and operates according to manufacturer's	ILO	140	IN//A
Drop Tube Shutoff	specifications			
(Flapper Valve)	Valve installed at proper height			
	Ball float can be removed and inspected			X
	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			Λ
Overfill Alarm	Alarm is functional			
Overnii / tidiiii	Alarm sounds at the proper product level			
RP900 8.11 - Leak De	1 1 1	YES	NO	N/A
KF900 6.11 - Leak De	Console has no active warnings or alarms	TEO	NO	I IN/A
	Alarm history shows no recurring leak alarms			
	Verify in-tank leak-detection tests are being completed			X
ATG Console	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			X
-	Tank interstitial access is present			
Continuous Interstitial	·			V
	"Wet" tank sensor functional, reinstalled at bottom of tank			X
Monitoring				
Electronic Leek	"Wet" tank leak-detection liquid depth within proper range Leak-monitoring console is operational and has no active warnings			
Electronic Leak-	leak-monitoring console is operational and has no active warnings or alarms			
Detection Monitor				
Line Tightness	If pressurized piping has been tested in the last year, review the			X
Line Tightness	results and verify that the test passed			
Testing	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
Under Dump Chaste	Below grade piping operates at less than atmospheric pressure			
Under Pump Check	Below grade piping slopes continuously back to the tank			<u> </u>
Valve (Suction)	There is only one check valve, and it is located as close as			
	practicable to the suction pump			I

RP900 8.11 - Leak D	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			_ ^
Continuous Soil-	Sensing device calibrated and tested			X
Vapor Monitoring	Ochsing device camprated and tested			^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi		YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			x
CP	years and test passed			
	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscell	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Consider of deprical even of mean tanke to level, the digital carte ordere			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			x
Collection Points				^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			x
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			Х
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Di		YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			x
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			l x
All Dispensers	manufacturer's specifications			
	Piping in good condition			X
	Stage II piping functional or else capped and sealed at elevation			X
5	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			X
Sumps	or water or are cathodically protected			
Diamana ana Mith	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
· ·				
<u> </u>	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump			Х
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump			
	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-			Х
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system			X X X
Piping Interstitial Space	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump			X X X
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system			X X X

UST Annual Inspection Checklist (PEI RP900)				
UST Information				
Tank ID:	UST 18 - Fenton River Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
All STP	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			l x
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications Submersible pump and visible piping and fittings show no signs of			
	, , , , , , , , , , , , , , , , , , , ,			X
	leakage Piping in good condition			X
	Submersible pump head, flex connector(s) and other metal product			_ ^
No STP Sump	piping are not in contact with soil or are cathodically protected			X
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			V
	system only)			X
	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			X
	all bolts present, handles and lift mechanism in good condition			^
RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			X
Sump (Same Procedure as STP	system only)			
	Entire interstitial space under pressure or vacuum (closed piping			X
Sump)	system only)			
, ,	Sump sensor properly mounted at the bottom of the sump Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			
	Jan pons present, nanules and intinechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as	Entire interstitial space under pressure or vacuum (closed piping			
STP Sump)	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Man	hole	YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
ATG Manhole	Probe and floats in good condition, both floats present and move			
ATG MAIIIULE	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area		YES	NO	N/A
Drop Tube	Drop tube extends to within 6 inches of the tank bottom (if no flow			X
Втор таво	diffuser present)			^
Vapor-Recovery	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			X
	tightly	\		
RP900 8.10 - Overfill		YES	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications			
,,	Valve installed at proper height Ball float can be removed and inspected			X
	Cage intact, ball in good condition, moves freely, seats firmly;			X
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
Overnii Alaini	Alarm sounds at the proper product level			
RP900 8.11 - Leak De		YES	NO	N/A
10 300 0.11 - Leak De	Console has no active warnings or alarms	TEG	NO	IN/A
	Alarm history shows no recurring leak alarms			
	Verify in-tank leak-detection tests are being completed			
ATG Console	Verify correct set-up parameters for the in-tank test			
	Verify correct set-up parameters for electronic line-leak detector			Х
	Verify piping leak-detection tests are being completed			X
	Tank interstitial access is present			
Continuous Interstitial				
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			Х
	"Wet" tank leak-detection liquid depth within proper range			X
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
	If pressurized piping has been tested in the last year, review the			
Line Tightness Testing	results and verify that the test passed			X
	If suction piping has been tested within the last three years, review			
	the results and verify that the test passed			X
Under Pump Check Valve (Suction)	Below grade piping operates at less than atmospheric pressure			
	Below grade piping slopes continuously back to the tank			
	There is only one check valve, and it is located as close as			V
·	practicable to the suction pump			X

Tank Tightness fl a tank test has been conducted within the last five years, review the results and verify that the test passed Continuous Soil-Vapor Monitoring Continuous Groundwater Monitoring Sensing device calibrated and tested	RP900 8.11 - Leak Do	etection Continued	YES	NO	N/A
Vapor Monitoring Continuous Groundwater Monitoring RP900 8.12 - Corrosion Protection Galvanic CP Galvanic CP Impressed Current CP Tank Lining Fassed Current CP Tank Lining Concrete or asphalt over or near tanks is level, no significant cracks Pavement Stage II Liquid- Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Fassed Components in contact with soil or water has been conducted within the past three years and that the test passed No exposed wires Concrete or asphalt over or near tanks is level, no significant cracks Pavement Stage II Liquid- Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Diagram Fassed Site Diagram Site	-				Х
Sensing device tested Monitoring RP900 8.12 - Corrosion Protection Verify that CP testing of all metallic components in contact with soil or water has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and test passed No exposed wires Lining inspected as required and in good condition X		Sensing device calibrated and tested			Х
RP900 8.12 - Corrosion Protection	Groundwater	Sensing device tested			×
Galvanic CP or water has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and test passed Services and test passed Verify that CP testing has been conducted within the past three years and test passed Services S		on Protection	YES	NO	N/A
wars and test passed No exposed wires Tank Lining Tank Pad & Pavement Stage II Liquid- Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Dispenser Inspection Initial Dispenser Inspection All Dispensers Without All Dispensers Without All Dispenser New All Dispenser Inspecti	Galvanic CP	or water has been conducted within the past three years and that			
RP900 8.13 - Miscellaneous		years and test passed			
Tank Pad & Pavement Stage II Liquid-Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Diagram Conserved Properties of Passing Site Diagram Site Diagram Site diagram accurately reflects the site conditions Initial Dispenser Inspection Inspection If fuel-dispenser sump is present, sump is dry RP900 8.14 - Initial Fuel Dispenser Inspection Inspection If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers Sump is present, sump is dry All Dispensers All Dispensers All Dispensers Piping in good condition Piping in good condition Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Dispensers With Sumps Piping in fere of trash, debris, and used filters All Dispensers With Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space open to the sump Piping Interstitial space open to the sump Sensors Dispensers Sump Sensors Sump sensor resent in the fuel-dispenser sump with closed double- welled piping system Dispensers Sump Sensors Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional	Tank Lining	Lining inspected as required and in good condition			Х
Stage II Liquid- Collection Points Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stite Diagram Site diagram accurately reflects the site conditions X RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser Inspection If fuel-dispenser sump is present, sump is dry X RP900 8.15 - Fuel Dispenser Inspection All Dispensers Inspection All Dispenser Inspection All Dispensers Stage Wiring in good condition Flexible connector not twisted, kinked, or bent beyond Flexible connector not twisted, kinked, or bent beyond Flexible connector not twisted, kinked, or bent beyond Manufacturer's specifications Piping in good condition Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Dispensers With Sump Fee of trash, debris, and used filters Any water removed and disposed of properly X Sump is free of trash, debris, and used filters Piping Interstitial Space Piping interstitial space copen to the sump Piping interstitial space closed to the sump Sensors Sump sensor properly mounted at the bottom of the sump X Sump sensor properly mounted at the bottom of the sump X Sump sensor properly mounted at the bottom of the sump X Sump sensor properly mounted at the bottom of the sump X Sump sensor properly mounted at the bottom of the sump X Electronic sensor tested and functional	RP900 8.13 - Miscella	aneous	YES	NO	N/A
Collection Points Cap in good condition, illist signify, little of no liquid in button X	Pavement	Concrete or asphalt over or near tanks is level, no significant cracks			
Site Diagram Site diagram accurately reflects the site conditions X RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser Inspection Initial Dispenser Inspection All dispenser components are clean and dry If fuel-dispenser sump is present, sump is dry X RP900 8.15 - Fuel Dispenser Inspection All Dispensers Without Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island All Dispensers Without Blex connectors and other metallic piping are not in contact with soil or water or are cathodically protected Any water removed and disposed of properly X Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured All Dispensers Sump Piping Interstitial space open to the sump All Dispenser Sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Sensors All Dispenser Sump Sump All Dispenser Sump Sump All Dispenser Sump All Dispenser Sump All Dispenser Sump All Dispenser Sump All Di					Х
RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser Inspection All dispenser components are clean and dry If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers All Dispensers Piping in good condition Dispensers Without Sumps Dispensers With Sumps Piping in good condition Dispensers With Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping interstitial Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump Piping interstitial space closed to the sump Dispenser Sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor tested and functional	Stage II Testing	passing			Х
Initial Dispenser Inspection If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers Without Stage II piping functional or else capped and sealed at elevation In Dispenser Suith All Dispensers Without Stage II piping functional or else capped and sealed at elevation In Dispensers With All Dispensers With All Dispensers With Stage II piping functional or else capped and sealed at elevation All Dispensers With Stage II piping are not in contact with soil or water or are cathodically protected Any water removed and disposed of properly All Dispensers With Sumps free of trash, debris, and used filters All Dispensers With All Dispensers With All Dispensers With All Dispensers With All Dispensers With All Dispensers With All Dispenser Sump All Dispenser S		,			Х
Inspection If fuel-dispenser sump is present, sump is dry X RP900 8.15 - Fuel Dispenser Inspection YES NO N/A			YES	NO	
RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Without Sumps Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Sumps All Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser Island All Dispensers Without Disp	·				
All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Without Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Any water or are cathodically protected Any water removed and disposed of properly Dispensers With Sumps Any water removed and disposed of properly Sump is free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional					
All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Piping in good condition Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Any water or are cathodically protected Any water removed and disposed of properly Dispensers With Sumps Sumps Any water removed and disposed of properly Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional	RP900 8.15 - Fuel Dis	•	YES	NO	N/A
All Dispensers manufacturer's specifications		safe wiring in good condition			Х
Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Dispensers With Sumps Dispensers With Sumps Dispensers With Sumps Dispensers With Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space open to the sump Piping Interstitial Space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Sensors Stage II piping functional or else capped and sealed at elevation X X X X X X X X X X X X X	All Dispensers	·			
Dispensers Without Sumps Flex connectors and other metallic piping are not in contact with soil or water or are cathodically protected X					X
Sumps or water or are cathodically protected Any water removed and disposed of properly Sump free of trash, debris, and used filters Sumps Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional					Х
Dispensers With Sump free of trash, debris, and used filters Sumps Sump is free of cracks, holes, bulges, or other defects X Penetration fittings intact and secured X Piping Interstitial Space Piping interstitial space open to the sump X Piping interstitial space closed to the sump X Sensor present in the fuel-dispenser sump with closed double- walled piping system Sump sensor properly mounted at the bottom of the sump X Electronic sensor tested and functional X X X X X X X X X X X X X X X X X X X	•	1			Х
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured X Piping Interstitial Piping Interstitial Piping interstitial space open to the sump X Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump X Sump sensor tested and functional X X X X X X X X X X X X X X X X X X X		Any water removed and disposed of properly			Х
Penetration fittings intact and secured Piping Interstitial space open to the sump X Piping Interstitial space open to the sump Space Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X X X X X Electronic sensor tested and functional	Dispensers With	Sump free of trash, debris, and used filters			Х
Piping Interstitial space open to the sump Space Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X X X X Electronic sensor tested and functional	Sumps	Sump is free of cracks, holes, bulges, or other defects			Х
Piping Interstitial Space Closed to the sump Space Sensor present in the fuel-dispenser sump with closed double-walled piping system Dispenser Sump Sensors Piping interstitial space closed to the sump X X X Electronic sensor tested and functional X X		Penetration fittings intact and secured			Х
Space Sensor present in the fuel-dispenser sump with closed double- walled piping system Sump sensor properly mounted at the bottom of the sump Sensors Electronic sensor tested and functional X	Piping Interstitial	Piping interstitial space open to the sump			
Walled piping system Sump sensor properly mounted at the bottom of the sump Sensors Valued piping system Sump sensor properly mounted at the bottom of the sump X X X X X X X X X X X X X		_ · · · · ·			X
Dispenser Sump Sensors Electronic sensor tested and functional X	Space				Х
Sensors Electronic sensor tested and functional X	Diamans Com-				Х
Mechanical float sensor free to move and properly adjusted X					Х
	Sensors	Mechanical float sensor free to move and properly adjusted			Х

UST Annual Inspection Checklist (PEI RP900)				
UST Information				
Tank ID:	UST 20 - Heating Plant #1 Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate	\/=0	110	21/2
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
	safe wiring in good condition			
	Mechanical line-leak detector properly vented, vent tube not kinked or twisted			X
	Mechanical line-leak detector passes 3.0 gph test			Х
All STP	Electronic line-leak detector passes 3.0 gph test			X
7 111 011	Flexible connector not twisted, kinked, or bent beyond			
	manufacturer's specifications			X
	Submersible pump and visible piping and fittings show no signs of			V
	leakage			X
	Piping in good condition			Х
No CTD Cump	Submersible pump head, flex connector(s) and other metal product			Х
No STP Sump	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
311 III Suilip	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			V
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly			Х
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top Sump (Same Procedure as STP Sump)	Alarm sounds when pressure or vacuum is released (closed piping			X
	system only) Entire interstitial space under pressure or vacuum (closed piping			
	, , , , , , , , , , , , , , , , , , , ,			X
	system only) Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			.,
All Other Sumps	system only)			X
(Same Procedure as	Entire interstitial space under pressure or vacuum (closed piping			V
STP Sump)	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			V
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Man	hole	YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
ATC Manhala	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area		YES	NO	N/A
Drop Tube	Drop tube extends to within 6 inches of the tank bottom (if no flow			Х
	diffuser present)			^
Vapor-Recovery	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			X
	tightly			
RP900 8.10 - Overfill		YES	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications			
	Valve installed at proper height			X
	Ball float can be removed and inspected			Х
Ball-Float Valve	Cage intact, ball in good condition, moves freely, seats firmly;			X
	breather hole open			
	Installed at proper height			Х
Overfill Alarm	Alarm mounted near fills, clearly labeled Alarm is functional			-
Overiiii Alarm	Alarm is functional Alarm sounds at the proper product level			
DD000 0 44 - Look D		YES	NO	NI/A
RP900 8.11 - Leak De		1 ES	NO	N/A
	Console has no active warnings or alarms Alarm history shows no recurring leak alarms			
	<u> </u>			
ATG Console	Verify in-tank leak-detection tests are being completed			X
	Verify correct set up parameters for the in-tank test			X
	Verify piping leak detection tests are being completed			X
	Verify piping leak-detection tests are being completed Tank interstitial access is present			
Continuous Interstitial				-
Monitoring	"Wet" tank sensor functional, reinstalled at bottom or tank			X
wormorning	"Wet" tank sensor functional, reinstalled in proper position "Wet" tank leak-detection liquid depth within proper range			X
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Defection Mount	If pressurized piping has been tested in the last year, review the			
Line Tightness Testing	results and verify that the test passed			Х
	If suction piping has been tested within the last three years, review			
	the results and verify that the test passed			Х
	Below grade piping operates at less than atmospheric pressure			X
Under Pump Check	Below grade piping slopes continuously back to the tank			X
Valve (Suction)	There is only one check valve, and it is located as close as			^
	practicable to the suction pump			X
	practicable to the education pump			

Tank Tightness fl a tank test has been conducted within the last five years, review the results and verify that the test passed Continuous Soil-Vapor Monitoring Continuous Groundwater Monitoring Sensing device calibrated and tested	RP900 8.11 - Leak Do	etection Continued	YES	NO	N/A
Vapor Monitoring Continuous Groundwater Monitoring RP900 8.12 - Corrosion Protection Galvanic CP Galvanic CP Impressed Current CP Tank Lining Fassed Current CP Tank Lining Concrete or asphalt over or near tanks is level, no significant cracks Pavement Stage II Liquid- Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Fassed Components in contact with soil or water has been conducted within the past three years and that the test passed No exposed wires Concrete or asphalt over or near tanks is level, no significant cracks Pavement Stage II Liquid- Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Diagram Fassed Site Diagram Site	-				Х
Sensing device tested Monitoring RP900 8.12 - Corrosion Protection Verify that CP testing of all metallic components in contact with soil or water has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and test passed No exposed wires Lining inspected as required and in good condition X		Sensing device calibrated and tested			Х
RP900 8.12 - Corrosion Protection	Groundwater	Sensing device tested			×
Galvanic CP or water has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and test passed Services and test passed Verify that CP testing has been conducted within the past three years and test passed Services S		on Protection	YES	NO	N/A
wars and test passed No exposed wires Tank Lining Tank Pad & Pavement Stage II Liquid- Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Dispenser Inspection Initial Dispenser Inspection All Dispensers Without All Dispensers Without All Dispenser New All Dispenser Inspecti	Galvanic CP	or water has been conducted within the past three years and that			
RP900 8.13 - Miscellaneous		years and test passed			
Tank Pad & Pavement Stage II Liquid-Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Diagram Conserved Properties of Passing Site Diagram Site Diagram Site diagram accurately reflects the site conditions Initial Dispenser Inspection Inspection If fuel-dispenser sump is present, sump is dry RP900 8.14 - Initial Fuel Dispenser Inspection Inspection If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers Sump is present, sump is dry All Dispensers All Dispensers All Dispensers Piping in good condition Piping in good condition Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Dispensers With Sumps Piping in fere of trash, debris, and used filters All Dispensers With Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space open to the sump Piping Interstitial space open to the sump Sensors Dispensers Sump Sensors Sump sensor resent in the fuel-dispenser sump with closed double- welled piping system Dispensers Sump Sensors Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional X Sump sensor reseated and functional	Tank Lining	Lining inspected as required and in good condition			Х
Stage II Liquid- Collection Points Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stage II Testing Stite Diagram Site diagram accurately reflects the site conditions X RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser Inspection If fuel-dispenser sump is present, sump is dry X RP900 8.15 - Fuel Dispenser Inspection All Dispensers Inspection All Dispenser Inspection All Dispensers Stage Wiring in good condition Flexible connector not twisted, kinked, or bent beyond Flexible connector not twisted, kinked, or bent beyond Flexible connector not twisted, kinked, or bent beyond Manufacturer's specifications Piping in good condition Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Dispensers With Sump Fee of trash, debris, and used filters Any water removed and disposed of properly X Sump is free of trash, debris, and used filters Piping Interstitial Space Piping interstitial space copen to the sump Piping interstitial space closed to the sump Sensors Sump sensor properly mounted at the bottom of the sump X Sump sensor properly mounted at the bottom of the sump X Sump sensor properly mounted at the bottom of the sump X Sump sensor properly mounted at the bottom of the sump X Sump sensor properly mounted at the bottom of the sump X Electronic sensor tested and functional	RP900 8.13 - Miscella	aneous	YES	NO	N/A
Collection Points Cap in good condition, illist signify, little of no liquid in button X	Pavement	Concrete or asphalt over or near tanks is level, no significant cracks			
Site Diagram Site diagram accurately reflects the site conditions X RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser Inspection Initial Dispenser Inspection All dispenser components are clean and dry If fuel-dispenser sump is present, sump is dry X RP900 8.15 - Fuel Dispenser Inspection All Dispensers Without Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island All Dispensers Without Blex connectors and other metallic piping are not in contact with soil or water or are cathodically protected Any water removed and disposed of properly X Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured All Dispensers Sump Piping Interstitial space open to the sump All Dispenser Sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Sensors All Dispenser Sump Sump All Dispenser Sump Sump All Dispenser Sump All Dispenser Sump All Dispenser Sump All Dispenser Sump All Di					Х
RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser Inspection All dispenser components are clean and dry If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers All Dispensers Piping in good condition Dispensers Without Sumps Dispensers With Sumps Piping in good condition Dispensers With Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping in good condition Dispensers Without Sumps Piping interstitial Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump Piping interstitial space closed to the sump Dispenser Sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor tested and functional	Stage II Testing	passing			Х
Initial Dispenser Inspection If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers Without Stage II piping functional or else capped and sealed at elevation In Dispenser Suith All Dispensers Without Stage II piping functional or else capped and sealed at elevation In Dispensers With All Dispensers With All Dispensers With Stage II piping functional or else capped and sealed at elevation All Dispensers With Stage II piping are not in contact with soil or water or are cathodically protected Any water removed and disposed of properly All Dispensers With Sumps free of trash, debris, and used filters All Dispensers With All Dispensers With All Dispensers With All Dispensers With All Dispensers With All Dispensers With All Dispenser Sump All Dispenser S		,			Х
Inspection If fuel-dispenser sump is present, sump is dry X RP900 8.15 - Fuel Dispenser Inspection YES NO N/A			YES	NO	
RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Without Sumps Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Sumps All Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Sumps All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser island All Dispensers Without Dispenser Island All Dispensers Without Disp	·				
All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Without Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Any water or are cathodically protected Any water removed and disposed of properly Dispensers With Sumps Any water removed and disposed of properly Sump is free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional					
All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Piping in good condition Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Any water or are cathodically protected Any water removed and disposed of properly Dispensers With Sumps Sumps Any water removed and disposed of properly Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional	RP900 8.15 - Fuel Dis	•	YES	NO	N/A
All Dispensers manufacturer's specifications		safe wiring in good condition			Х
Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Dispensers With Sumps Dispensers With Sumps Dispensers With Sumps Dispensers With Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space open to the sump Piping Interstitial Space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Sensors Stage II piping functional or else capped and sealed at elevation X X X X X X X X X X X X X	All Dispensers	·			
Dispensers Without Sumps Flex connectors and other metallic piping are not in contact with soil or water or are cathodically protected X					X
Sumps or water or are cathodically protected Any water removed and disposed of properly Sump free of trash, debris, and used filters Sumps Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional					Х
Dispensers With Sump free of trash, debris, and used filters Sumps Sump is free of cracks, holes, bulges, or other defects X Penetration fittings intact and secured X Piping Interstitial Space Piping interstitial space open to the sump X Piping interstitial space closed to the sump X Sensor present in the fuel-dispenser sump with closed double- walled piping system Sump sensor properly mounted at the bottom of the sump X Electronic sensor tested and functional X X X X X X X X X X X X X X X X X X X	•	1			Х
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured X Piping Interstitial Piping Interstitial Piping interstitial space open to the sump X Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump X Sump sensor tested and functional X X X X X X X X X X X X X X X X X X X		Any water removed and disposed of properly			Х
Penetration fittings intact and secured Piping Interstitial space open to the sump X Piping Interstitial space open to the sump Space Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X X X X X Electronic sensor tested and functional	Dispensers With	Sump free of trash, debris, and used filters			Х
Piping Interstitial space open to the sump Space Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X X X X Electronic sensor tested and functional	Sumps	Sump is free of cracks, holes, bulges, or other defects			Х
Piping Interstitial Space Closed to the sump Space Sensor present in the fuel-dispenser sump with closed double-walled piping system Dispenser Sump Sensors Piping interstitial space closed to the sump X X X Electronic sensor tested and functional X X		Penetration fittings intact and secured			Х
Space Sensor present in the fuel-dispenser sump with closed double- walled piping system Sump sensor properly mounted at the bottom of the sump Sensors Electronic sensor tested and functional X	Piping Interstitial	Piping interstitial space open to the sump			
Walled piping system Sump sensor properly mounted at the bottom of the sump Sensors Valued piping system Sump sensor properly mounted at the bottom of the sump X X X X X X X X X X X X X		_ · · · · ·			X
Dispenser Sump Sensors Electronic sensor tested and functional X	Space				Х
Sensors Electronic sensor tested and functional X	Diamans Com-				Х
Mechanical float sensor free to move and properly adjusted X					Х
	Sensors	Mechanical float sensor free to move and properly adjusted			Х

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 21 - Heating Plant #2 Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			Х
	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			Х
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			Х
All STP	Electronic line-leak detector passes 3.0 gph test			Х
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			^
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
No STP Sump	Piping in good condition			X
	Submersible pump head, flex connector(s) and other metal product			X
	piping are not in contact with soil or are cathodically protected			X
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
O II III Guilip	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	N/A
	Any water or product removed and disposed of properly			Х
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			X
Sump (Same Procedure as STP Sump)	system only)			^
	Entire interstitial space under pressure or vacuum (closed piping			X
	system only)			Λ
	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				
` STP Sump)	system only)			X
1 /	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Man		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14//
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	Tro probe dap una mannote dever	YES	NO	N/A
INF 300 0.3 - 1 III Alea	Drop tube extends to within 6 inches of the tank bottom (if no flow	TES	NO	IN/A
Drop Tube	diffuser present)			X
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	NI/A
RP300 6.10 - Overilli		IEO	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications Valve installed at proper height			<u> </u>
	Ball float can be removed and inspected			X
	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			_ ^
Overfill Alarm	Alarm is functional			
Overilli Alaimi	Alarm sounds at the proper product level			
DD000 0 44 1 1 1 D	1 1 1	\/F0	NO	1 1/0
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATG Console	Verify in-tank leak-detection tests are being completed			X
	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			Х
L	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			X
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
	If pressurized piping has been tested in the last year, review the			X
Line Tightness Testing	results and verify that the test passed			
	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			Х
Under Pump Check	Below grade piping slopes continuously back to the tank			Х
Valve (Suction)	There is only one check valve, and it is located as close as			Х
	practicable to the suction pump			

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			
Testing	the results and verify that the test passed			
Continuous Soil-	Conging device colibrated and tested			
Vapor Monitoring	Sensing device calibrated and tested			
Continuous				
Groundwater	Sensing device tested			
Monitoring				
RP900 8.12 - Corrosi	on Protection	YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			
Impressed Current CP	years and test passed			X
CF	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Concrete of aspiral over of flear tanks is level, no significant cracks			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			Х
Collection Points	Cap in good condition, his lightly, little of no liquid in bottom			^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			Х
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			X
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			
Inspection	If fuel-dispenser sump is present, sump is dry			
RP900 8.15 - Fuel Dis		YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			
	Piping in good condition			
	Stage II piping functional or else capped and sealed at elevation			
	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			
Dispensers With	Sump free of trash, debris, and used filters			
Sumps	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
Piping Interstitial Space	Piping interstitial space open to the sump			
	Piping interstitial space closed to the sump			
	Sensor present in the fuel-dispenser sump with closed double-			
	walled piping system			
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			
Sensors	Electronic sensor tested and functional			
Selisois	Mechanical float sensor free to move and properly adjusted			
Describe any Deficie	ncies Here:			

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 22 - Heating Plant #3 Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			
	safe wiring in good condition			Х
	Mechanical line-leak detector properly vented, vent tube not kinked			Х
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
All STP	Electronic line-leak detector passes 3.0 gph test			Х
	Flexible connector not twisted, kinked, or bent beyond			Х
	manufacturer's specifications			^
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			X
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
140 OTT Gump	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			X
OTD : 0	system only)			
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			X
	system only)			Х
	Sump sensor properly mounted at the bottom of the sump Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			^_
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta		YES	NO	N/A
THE SOU G.O - Other Tu	Any water or product removed and disposed of properly	TLO	110	X
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
	Alarm sounds when pressure or vacuum is released (closed piping			
Other Tank-Top	system only)			X
Sump (Same Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			
	system only)			X
Sump)	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition		<u></u>	

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				
` STP Sump)	system only)			X
1 /	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Man		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14//
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	Tro probe dap una mannote dever	YES	NO	N/A
INF 300 0.3 - 1 III Alea	Drop tube extends to within 6 inches of the tank bottom (if no flow	TES	NO	IN/A
Drop Tube	diffuser present)			X
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	NI/A
RP300 6.10 - Overilli		IEO	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications Valve installed at proper height			<u> </u>
	Ball float can be removed and inspected			X
	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			_ ^
Overfill Alarm	Alarm is functional			
Overilli Alaim	Alarm sounds at the proper product level			
DD000 0 44 1 1 1 D	1 1 1	\/F0	NO	1 1/0
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATG Console	Verify in-tank leak-detection tests are being completed			X
	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			Х
L	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			X
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
	If pressurized piping has been tested in the last year, review the			X
Line Tightness Testing	results and verify that the test passed			
	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			Х
Under Pump Check	Below grade piping slopes continuously back to the tank			X
Valve (Suction)	There is only one check valve, and it is located as close as			Х
	practicable to the suction pump			

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			
Testing	the results and verify that the test passed			
Continuous Soil-	Conging device colibrated and tested			
Vapor Monitoring	Sensing device calibrated and tested			
Continuous				
Groundwater	Sensing device tested			
Monitoring				
RP900 8.12 - Corrosi	on Protection	YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			
Impressed Current CP	years and test passed			X
CF	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Concrete of aspiral over of flear tanks is level, no significant cracks			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			Х
Collection Points	Cap in good condition, his lightly, little of no liquid in bottom			^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			Х
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			X
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			
Inspection	If fuel-dispenser sump is present, sump is dry			
RP900 8.15 - Fuel Dis		YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			
	Piping in good condition			
	Stage II piping functional or else capped and sealed at elevation			
	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			
Dispensers With	Sump free of trash, debris, and used filters			
Sumps	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
Piping Interstitial Space	Piping interstitial space open to the sump			
	Piping interstitial space closed to the sump			
	Sensor present in the fuel-dispenser sump with closed double-			
	walled piping system			
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			
Sensors	Electronic sensor tested and functional			
Selisois	Mechanical float sensor free to move and properly adjusted			
Describe any Deficie	ncies Here:			

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 23 - Heating Plant #4 Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			Х
	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			Х
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
All STP	Electronic line-leak detector passes 3.0 gph test			Х
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			^
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			X
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
- Tto off camp	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
OTT III Guilip	system only)			X
	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tenk Ten	Alarm sounds when pressure or vacuum is released (closed piping			V
Other Tank-Top	system only)			X
Sump (Same Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			
	system only)			X
Sump)	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				
` STP Sump)	system only)			X
1 /	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Man		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14//
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	Tro probe dap and mannote devel	YES	NO	N/A
INF 300 0.3 - 1 III Alea	Drop tube extends to within 6 inches of the tank bottom (if no flow	TES	NO	IN/A
Drop Tube	diffuser present)			X
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	NI/A
RP300 6.10 - Overilli		IEO	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications Valve installed at proper height			<u> </u>
	Ball float can be removed and inspected			X
	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			_ ^
Overfill Alarm	Alarm is functional			
Overilli Alaim	Alarm sounds at the proper product level			
DD000 0 44 1 1 1 D	1 1 1	\/F0	NO	1 1/0
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATG Console	Verify in-tank leak-detection tests are being completed			X
	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			Х
L	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			X
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Line Tightness	If pressurized piping has been tested in the last year, review the			X
	results and verify that the test passed			
Testing	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			Х
Under Pump Check	Below grade piping slopes continuously back to the tank			X
Valve (Suction)	There is only one check valve, and it is located as close as			Х
	practicable to the suction pump			

RP900 8.11 - Leak Do	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			^
Continuous Soil-	Sensing device calibrated and tested			X
Vapor Monitoring	3			
Continuous	Compine device tested			V
Groundwater Monitoring	Sensing device tested			X
RP900 8.12 - Corrosi	on Protection	YES	NO	N/A
KF900 0.12 - C011051	Verify that CP testing of all metallic components in contact with soil	TES	NO	IN/A
Galvanic CP	or water has been conducted within the past three years and that			
Galvariic Ci	the test passed			
	Verify that CP testing has been conducted within the past three			.,
Impressed Current	years and test passed			X
СР	No exposed wires			Х
Tank Lining	Lining inspected as required and in good condition			Х
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Concrete of asphalt over of flear tanks is level, no significant cracks			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			X
Collection Points				^
Stage II Testing	Verify that Stage II testing has been conducted and test results are passing			X
Site Diagram	Site diagram accurately reflects the site conditions			Х
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			Х
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Dis	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			Х
	safe wiring in good condition			^
	Flexible connector not twisted, kinked, or bent beyond			X
All Dispensers	manufacturer's specifications			
	Piping in good condition			Х
	Stage II piping functional or else capped and sealed at elevation			Х
Dispensers Without	lower than the fuel dispenser island Flex connectors and other metallic piping are not in contact with soil			
Sumps	or water or are cathodically protected			Х
- Cumps	Any water removed and disposed of properly			Х
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			Х
Piping Interstitial Space	Piping interstitial space open to the sump			Х
	Piping interstitial space closed to the sump			Х
	Sensor present in the fuel-dispenser sump with closed double-			V
	walled piping system			Х
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			Х
Sensors	Electronic sensor tested and functional			X
Describe any Deficie	Mechanical float sensor free to move and properly adjusted			X

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 24 - Heating Plant #5 Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			Х
	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			Х
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
All STP	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			^
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			X
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
- No off cump	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			_ ^
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
OTT III Guilip	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly			Х
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			Х
•	system only)			_ ^
Sump (Same Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			X
Sump)	system only)			_ ^
Guilip)	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				
` STP Sump)	system only)			X
1 /	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Man		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14//
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	Tro probe dap and mannote devel	YES	NO	N/A
INF 300 0.3 - 1 III Alea	Drop tube extends to within 6 inches of the tank bottom (if no flow	TES	NO	IN/A
Drop Tube	diffuser present)			X
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	NI/A
RP300 6.10 - Overilli		IEO	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications Valve installed at proper height			<u> </u>
	Ball float can be removed and inspected			X
	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			_ ^
Overfill Alarm	Alarm is functional			
Overilli Alaim	Alarm sounds at the proper product level			
DD000 0 44 1 1 1 D	1 1 1	\/F0	NO	1 1/0
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATG Console	Verify in-tank leak-detection tests are being completed			X
	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			Х
L	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			X
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Line Tightness	If pressurized piping has been tested in the last year, review the			X
	results and verify that the test passed			
Testing	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			X
Under Pump Check	Below grade piping slopes continuously back to the tank			X
Valve (Suction)	There is only one check valve, and it is located as close as			Х
	practicable to the suction pump			

RP900 8.11 - Leak Do	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			^
Continuous Soil-	Sensing device calibrated and tested			X
Vapor Monitoring	3			
Continuous	Compine device tested			V
Groundwater Monitoring	Sensing device tested			X
RP900 8.12 - Corrosi	on Protection	YES	NO	N/A
KF900 0.12 - C011051	Verify that CP testing of all metallic components in contact with soil	TES	NO	IN/A
Galvanic CP	or water has been conducted within the past three years and that			
Galvariic Ci	the test passed			
	Verify that CP testing has been conducted within the past three			.,
Impressed Current	years and test passed			X
СР	No exposed wires			Х
Tank Lining	Lining inspected as required and in good condition			Х
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Concrete of asphalt over of flear tanks is level, no significant cracks			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			X
Collection Points				^
Stage II Testing	Verify that Stage II testing has been conducted and test results are passing			X
Site Diagram	Site diagram accurately reflects the site conditions			Х
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			Х
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Dis	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			Х
	safe wiring in good condition			^
	Flexible connector not twisted, kinked, or bent beyond			X
All Dispensers	manufacturer's specifications			
	Piping in good condition			Х
	Stage II piping functional or else capped and sealed at elevation			Х
Dispensers Without	lower than the fuel dispenser island Flex connectors and other metallic piping are not in contact with soil			
Sumps	or water or are cathodically protected			Х
- Ourips	Any water removed and disposed of properly			Х
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			Х
Piping Interstitial Space	Piping interstitial space open to the sump			Х
	Piping interstitial space closed to the sump			Х
	Sensor present in the fuel-dispenser sump with closed double-			V
	walled piping system			Х
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			Х
Sensors	Electronic sensor tested and functional			X
Describe any Deficie	Mechanical float sensor free to move and properly adjusted			X

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 25 - Heating Plant #6 Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			Х
	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			Х
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
All STP	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			^
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			X
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
- Tto off camp	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
OTT III Guilip	system only)			X
	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly			Х
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank Tan	Alarm sounds when pressure or vacuum is released (closed piping			
Other Tank-Top	system only)			X
Sump (Same Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			
	system only)			X
Sump)	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				
` STP Sump)	system only)			X
1 /	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Man		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14//
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	Tro probe dap and mannote devel	YES	NO	N/A
INF 300 0.3 - 1 III Alea	Drop tube extends to within 6 inches of the tank bottom (if no flow	TES	NO	IN/A
Drop Tube	diffuser present)			X
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	NI/A
RP300 6.10 - Overilli		IEO	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications Valve installed at proper height			<u> </u>
	Ball float can be removed and inspected			X
	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			_ ^
Overfill Alarm	Alarm is functional			
Overilli Alaimi	Alarm sounds at the proper product level			
DD000 0 44 1 1 1 D	1 1 1	\/F0	NO	1 1/0
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATG Console	Verify in-tank leak-detection tests are being completed			X
	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			Х
L	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			X
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Line Tightness	If pressurized piping has been tested in the last year, review the			X
	results and verify that the test passed			
Testing	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			Х
Under Pump Check	Below grade piping slopes continuously back to the tank			Х
Valve (Suction)	There is only one check valve, and it is located as close as			Х
	practicable to the suction pump			

RP900 8.11 - Leak Do	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			_ ^
Continuous Soil-	Sensing device calibrated and tested			X
Vapor Monitoring	Ochsing device camprated and tested			^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi		YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			x
CP	years and test passed			
	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Control of deprisant ever of mean tanne is note; no eignineant ever of			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			x
Collection Points				
Stage II Testing	Verify that Stage II testing has been conducted and test results are passing			X
Site Diagram	Site diagram accurately reflects the site conditions			Х
RP900 8.14 - Initial F	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Dis	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			V
	safe wiring in good condition			X
	Flexible connector not twisted, kinked, or bent beyond			V
All Dispensers	manufacturer's specifications			X
	Piping in good condition			Х
	Stage II piping functional or else capped and sealed at elevation			Х
	lower than the fuel dispenser island			^
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			Х
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			Х
Dispensers With	Sump free of trash, debris, and used filters			Х
Sumps	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump			Х
Piping Interstitial Space	Piping interstitial space closed to the sump			Х
	Sensor present in the fuel-dispenser sump with closed double-			V
	walled piping system			X
D: 0	Sump sensor properly mounted at the bottom of the sump			Х
Dispenser Sump	Electronic sensor tested and functional			Х
Sensors	Mechanical float sensor free to move and properly adjusted			Х
Describe any Deficie				

UST Annual Inspection Checklist (PEI RP900)					
UST Information					
Tank ID:	UST 28 - Motor Pool Gasoline UST Date:				
Inspector:					
Item		Status			
RP900 8.4		YES	NO	N/A	
	Complete monthly checklist and compare to previously completed				
Monthly Inspections	monthly checklists				
	Monthly inspections reviewed and found adequate				
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A	
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt				
	safe wiring in good condition				
	Mechanical line-leak detector properly vented, vent tube not kinked				
	or twisted				
	Mechanical line-leak detector passes 3.0 gph test			X	
All STP	Electronic line-leak detector passes 3.0 gph test			Х	
	Flexible connector not twisted, kinked, or bent beyond				
	manufacturer's specifications				
	Submersible pump and visible piping and fittings show no signs of				
	leakage				
	Piping in good condition				
No STP Sump	Submersible pump head, flex connector(s) and other metal product				
	piping are not in contact with soil or are cathodically protected				
	Any water or product removed and disposed of properly				
	Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured				
	Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping				
	system only)			Х	
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping				
31F III Suilip	system only)			Х	
	Sump sensor properly mounted at the bottom of the sump				
	Sensor tested and functional				
	Sump lid, gasket, and seals present and in good condition				
	Manway conver at grade in good condition, does not touch sump,	1			
	all bolts present, handles and lift mechanism in good condition				
RP900 8.6 - Other Ta		YES	NO	N/A	
	Any water or product removed and disposed of properly			X	
	Sump is free of cracks, holes, bulges, or other defects			X	
	Penetration fittings intact and secured			X	
	Piping interstitial space open to the sump (open piping system only)			X	
011 - 1 -	Alarm sounds when pressure or vacuum is released (closed piping				
Other Tank-Top	system only)			X	
Sump (Same Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping				
	system only)			X	
Sump)	Sump sensor properly mounted at the bottom of the sump			Х	
	Sensor tested and functional			Х	
	Sump lid, gasket, and seals present and in good condition			Х	
	Manway conver at grade in good condition, does not touch sump,			V	
	all bolts present, handles and lift mechanism in good condition			Х	

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` `
` STP Sump)	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Mar		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
ATG Manhole	Probe and floats in good condition, both floats present and move			
A 1 G IVIAI II I I I I	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area		YES	NO	N/A
Drop Tube	Drop tube extends to within 6 inches of the tank bottom (if no flow			
Втор таво	diffuser present)			
Vapor-Recovery	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
	tightly	\		
RP900 8.10 - Overfill		YES	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			
(Flapper Valve)	specifications			
, , ,	Valve installed at proper height Ball float can be removed and inspected			V
	Cage intact, ball in good condition, moves freely, seats firmly;			X
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
O VOITIII / NIGITII	Alarm sounds at the proper product level			
RP900 8.11 - Leak De		YES	NO	N/A
THE COUNTY LEAR DE	Console has no active warnings or alarms	120	140	14/74
	Alarm history shows no recurring leak alarms			
	Verify in-tank leak-detection trsts are being completed			
ATG Console	Verify correct set-up parameters for the in-tank test			
	Verify correct set-up parameters for electronic line-leak detector			Х
	Verify piping leak-detection tests are being completed			X
	Tank interstitial access is present			
Continuous Interstitial				
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			Х
ĺ	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Line Tightness Testing	If pressurized piping has been tested in the last year, review the			
	results and verify that the test passed			X
	If suction piping has been tested within the last three years, review			Х
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			Х
Under Pump Check	Below grade piping slopes continuously back to the tank			Х
Valve (Suction)	There is only one check valve, and it is located as close as			Х
	practicable to the suction pump			

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			
Testing	the results and verify that the test passed			
Continuous Soil-				
Vapor Monitoring	Sensing device calibrated and tested			X
Continuous				
Groundwater	Sensing device tested			l x
Monitoring				
RP900 8.12 - Corrosi	on Protection	YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			X
	the test passed			
	Verify that CP testing has been conducted within the past three			
Impressed Current	years and test passed			X
CP	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscella		YES	NO	N/A
Tank Pad &				1 177 1
Pavement	Concrete or asphalt over or near tanks is level, no significant cracks			
Stage II Liquid-				
Collection Points	Cap in good condition, fits tightly, little or no liquid in bottom			X
	Verify that Stage II testing has been conducted and test results are			
Stage II Testing	passing			
Site Diagram	Site diagram accurately reflects the site conditions			Х
RP900 8.14 - Initial F	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			
Inspection	If fuel-dispenser sump is present, sump is dry			
RP900 8.15 - Fuel Dis	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			
	Piping in good condition			
	Stage II piping functional or else capped and sealed at elevation			
	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			X
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			
Sumps	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
Piping Interstitial Space	Piping interstitial space open to the sump			
	Piping interstitial space closed to the sump			X
	Sensor present in the fuel-dispenser sump with closed double-			Х
	walled piping system			
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			Х
Sensors	Electronic sensor tested and functional			X
OCHOOLS	Mechanical float sensor free to move and properly adjusted			Х
Describe any Deficiencies Here:				

UST Information Tank ID: UST 29 - Motor Pool Diesel UST Date: Imspector: Item RP900 8.4 Complete monthly checklist and compare to previously completed monthly checklists Monthly inspections Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspection Monthly inspection reviewed and found adequate Monthly inspection reviewed and found adequate Monthly inspection Monthly inspection reviewed and found adequate Monthly inspection Monthl	UST Annual Insp	ection Checklist (PEI RP900)			
Inspector: Item RP900 8.4 Complete monthly checklists and compare to previously completed monthly checklists Monthly Inspections reviewed and found adequate RP900 8.5 - Submersible Turbine Pump (STP) Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt safe wiring in good condition Mechanical line-leak detector passes 3.0 gph test Mechanical line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor property mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping system only) Sump sensor property mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Any water or product removed and disposed of property Any water or product removed and disposed of property Any water or product removed and disposed of property Any water or product removed and processed of property Any water or product removed and disposed of property Any water or product removed and disposed of property Any wate	UST Information	,			
Item RP900 8.4 Complete monthly checklist and compare to previously completed monthly checklists Monthly Inspections February (Complete monthly checklists) Monthly Inspections reviewed and found adequate RP900 8.5 - Submersible Turbine Pump (STP) Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt safe wiring in good condition Mechanical line-leak detector properly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump No STP Sump Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Mamway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Mamway conver at grade in good condition, does not touch sump, system only) Sump (Same Procedure as STP Sump) Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping system only) Any water or product removed and disposed of properly X X Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping system only) Any water or product removed and disposed of properly X X Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping s	Tank ID:	UST 29 - Motor Pool Diesel UST Date:			
Complete monthly checklist and compare to previously completed monthly inspections Complete monthly checklists	Inspector:				
Complete monthly checklist and compare to previously completed monthly inspections Complete monthly checklists					
Monthly Inspections Monthly Inspections Monthly checklists and compare to previously completed monthly checklists and compare to previously completed monthly checklists Monthly inspections reviewed and found adequate RP900 8.5 - Submersible Turbine Pump (STP) Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt safe wiring in good condition Mechanical line-leak detector posers 3.0 gph test Mechanical line-leak detector passes 3.0 gph test Mechanical line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space upen to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Samp sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handless and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum is released (closed piping system only) Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum is released (closed piping system only) Any water or product r	Item		Status		
Monthly Inspections monthly checklists Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate Monthly inspections wing in good condition Mechanical line-leak detector passes 3.0 gph test Monthly inspections Mechanical line-leak detector passes 3.0 gph test Monthly inspections Monthly inspec	RP900 8.4		YES	NO	N/A
Monthly inspections reviewed and found adequate YES NO N/A					
RP900 8.5 - Submersible Turbine Pump (STP) Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt safe wiring in good condition Mechanical line-leak detector properly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (c	Monthly Inspections				
Junction box(es) sealed, not corroded; seal-offs present; intrinsicalit safe wiring in good condition Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings inlact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) X Alarm sounds when pressure or vacuum (closed piping system) X Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) X Alarm sounds when pressure or vacuum (closed piping system only) X Sump sensor properly mounted at the bottom of the sump Sump lid, gasket, and seals present and in good condition X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, Alarm sounds when pressure or vacuum (closed piping system only) X Sump sensor properly mounted at the bottom of the sum					
Safe wiring in good condition Mechanical line-leak detector properly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	RP900 8.5 - Submers	,	YES	NO	N/A
Mechanical line-leak detector properly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly X Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor test					
All STP All STP All STP Electronic line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) STP in Sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump open piping system only) Any water or product removed and disposed of properly X Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space open to the sump (open piping system only) X Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) X Sump sensor properly mounted at the bottom of the sump Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Annway conver at grade in good condition, does not touch sump,					
Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Malarm sounds when pressure or vacuum (closed piping system only) Entrie interstitial space under pressure or vacuum (closed piping system only) Malarm sounds when pressure or vacuum (closed piping system only) Malarm sounds when pressure or vacuum (clos		1 ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' '			
Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly X Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) X Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space open to the sump (open piping system only) X Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure o					
Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump No STP Sump No STP Sump No STP Sump Flexible connector (s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (seased (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition Reposon S.6 - Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Thir interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional X sump lid, gasket, and seals present and in good condition X and you sensor properly mounted at the bottom of the sump Sensor tested and functional X manway conver at grade in good condition, does not touch sump,					
manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition does not touch sump, all botts present, handles and lift mechanism in good condition Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, Manway conver at grade in good condition, does not touch sump,	All STP				Х
Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tiping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional X sensor tested and functional X sensor tested and functional X man bounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X sensor tested and functional X man bounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X sensor tested and functional X man bounds when pressure or vacuum (closed piping system only) X man procedure as STP Sumplied and seals present and in good condition X manway conver at grade in good condition, does not touch sump,		_ · · · · · · · · · · · · · · · · · · ·			
leakage					
Piping in good condition Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected X					
Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected X					
piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Cother Tank-Top Sump (Same Procedure as STP Sump) Other Tank-Top Sump (Same Procedure as STP Sump) Cother Tank-Top Sump (Same Procedure as STP Sump) Other Tank-Top Sump (Same Procedure as STP Sump) Other Tank-Top Sump (Same Procedure as STP Sump) Other Tank-Top Sump (Same of the sump (open piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	No STP Sump				
Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition X Manway conver at grade in good condition, does not touch sump,					X
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump (Same Procedure as STP Sump) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,			i		
Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					.,
Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					X
system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	STP in Sump				
Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					X
Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Sump sensor properly mounted at the bottom of the sump			
Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Sensor tested and functional			
all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump) Sump) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Sump lid, gasket, and seals present and in good condition			
Pother Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured X Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	
Other Tank-Top Sump (Same Procedure as STP Sump) Sump) Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Any water or product removed and disposed of properly			X
Other Tank-Top Sump (Same Procedure as STP Sump) Sump) Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Sump is free of cracks, holes, bulges, or other defects			
Other Tank-Top Sump (Same Procedure as STP Sump) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Penetration fittings intact and secured			
Sump (Same Procedure as STP Sump) Sump) Sump (Same Procedure as STP Sump) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Piping interstitial space open to the sump (open piping system only)			X
Sump (Same Procedure as STP Sump) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	Other Tank-Ton	· · · · · · · · · · · · · · · · · · ·			×
Procedure as STP Sump) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					^
Sump) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	Procedure as STP				X
Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Sump lid, gasket, and seals present and in good condition X Manway conver at grade in good condition, does not touch sump,	,				
Manway conver at grade in good condition, does not touch sump,					
					X
					Х

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				
STP Sump)	system only)			X
17	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Mar		YES	NO	N/A
11. 000 010 711 0 IIIai	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14// (
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area		YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow	120	110	14//
Drop Tube	diffuser present)			
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	N/A
-	Valve moves freely and operates according to manufacturer's			1 1,7 1
Drop Tube Shutoff	specifications			
(Flapper Valve)	Valve installed at proper height			İ
	Ball float can be removed and inspected			Х
Dell Fleet V	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			Х
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
	Alarm sounds at the proper product level			
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATC C	Verify in-tank leak-detection trsts are being completed			
ATG Console	Verify correct set-up parameters for the in-tank test			
	Verify correct set-up parameters for electronic line-leak detector			Х
	Verify piping leak-detection tests are being completed			Х
	Tank interstitial access is present			
Continuous Interstitial				
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			Х
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Line Tightness	If pressurized piping has been tested in the last year, review the			
	results and verify that the test passed			X
Testing	If suction piping has been tested within the last three years, review			V
	the results and verify that the test passed			X
	Below grade piping operates at less than atmospheric pressure			Х
Under Pump Check	Below grade piping slopes continuously back to the tank			Х
Valve (Suction)	There is only one check valve, and it is located as close as			V
	practicable to the suction pump			X

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			_ ^
Continuous Soil-	Sensing device calibrated and tested			X
Vapor Monitoring	Sensing device campiated and tested			_ ^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi	on Protection	YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			Х
CP	years and test passed			^
GP GP	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Congrete or conholt over or near tenks is level, no significant gracks			
Pavement	Concrete or asphalt over or near tanks is level, no significant cracks			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			X
Collection Points	cap in good condition, his lightly, little of no liquid in bottom			_ ^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			X
	passing			
Site Diagram Site diagram accurately reflects the site conditions				X
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			
Inspection	If fuel-dispenser sump is present, sump is dry			
RP900 8.15 - Fuel Dis	•	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			
	Piping in good condition			
	Stage II piping functional or else capped and sealed at elevation			l x
	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			Х
Dispensers With	Sump free of trash, debris, and used filters			
Sumps	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
Piping Interstitial Space	Piping interstitial space open to the sump			.,
	Piping interstitial space closed to the sump			X
	Sensor present in the fuel-dispenser sump with closed double-			X
	walled piping system			
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			X
Sensors	Electronic sensor tested and functional			X
	Mechanical float sensor free to move and properly adjusted			Х
Describe any Deficie	ncies Here:			

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 32 – Northwood Apartments Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			X
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
All STP	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			X
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			_ ^
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
OTT III Guillp	system only)			X
	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	N/A
	Any water or product removed and disposed of properly	i i		
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			Х
l e	system only)			^
Sump (Same Procedure as STP Sump)	Entire interstitial space under pressure or vacuum (closed piping			X
	system only)			^
Guilip)	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition	<u>[</u>		
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	imps	YES	NO	N/A
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			
(Same Procedure as	Entire interstitial space under pressure or vacuum (closed piping			
` STP Sump)	system only)			
. ,	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			
RP900 8.8 - ATG Mar	•	YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	,	YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow	ILO	140	14// (
Drop Tube	diffuser present)			
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	N/A
	Valve moves freely and operates according to manufacturer's	ILO	140	IN//A
Drop Tube Shutoff	specifications			
(Flapper Valve)	Valve installed at proper height			
	Ball float can be removed and inspected			X
	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			Λ
Overfill Alarm	Alarm is functional			
Overnii / tidiiii	Alarm sounds at the proper product level			
RP900 8.11 - Leak De	1 1 1	YES	NO	N/A
KF900 6.11 - Leak De	Console has no active warnings or alarms	TEO	NO	I IN/A
	Alarm history shows no recurring leak alarms			
	Verify in-tank leak-detection tests are being completed			X
ATG Console	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			X
-	Tank interstitial access is present			
Continuous Interstitial	·			V
	"Wet" tank sensor functional, reinstalled at bottom of tank			X
Monitoring				
Electronic Leek	"Wet" tank leak-detection liquid depth within proper range Leak-monitoring console is operational and has no active warnings			
Electronic Leak-	leak-monitoring console is operational and has no active warnings or alarms			
Detection Monitor				
Line Tightness Testing	If pressurized piping has been tested in the last year, review the			X
	results and verify that the test passed			
	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
Under Dump Chaste	Below grade piping operates at less than atmospheric pressure			
Under Pump Check	Below grade piping slopes continuously back to the tank			<u> </u>
Valve (Suction)	There is only one check valve, and it is located as close as			
	practicable to the suction pump			I

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			^
Continuous Soil-	Sensing device calibrated and tested			l x
Vapor Monitoring	densing device camprated and tested			
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi	ion Protection	YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			l x
CP	years and test passed			
G	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			Х
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or conholt over or near tanks is level, no significant cracks			
Pavement	Concrete or asphalt over or near tanks is level, no significant cracks	<u></u>	<u></u>	
Stage II Liquid-	Can in good condition fits tightly, little or no liquid in bottom			Х
Collection Points	Cap in good condition, fits tightly, little or no liquid in bottom			^
Ctage II Teeting	Verify that Stage II testing has been conducted and test results are			Х
Stage II Testing	passing			^
Site Diagram	Site diagram accurately reflects the site conditions			X
RP900 8.14 - Initial Fuel Dispenser Inspection		YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Di	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			V
	safe wiring in good condition			X
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			X
	Piping in good condition			X
	Stage II piping functional or else capped and sealed at elevation			Х
	lower than the fuel dispenser island			^
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			X
Sumps	or water or are cathodically protected			^
	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump			Х
Piping Interstitial	Piping interstitial space closed to the sump			X
Space	Sensor present in the fuel-dispenser sump with closed double-			
	walled piping system			X
D: 0	Sump sensor properly mounted at the bottom of the sump			X
Dispenser Sump	Electronic sensor tested and functional			X
Sensors	Mechanical float sensor free to move and properly adjusted			X
	encies Here:			

UST Annual Inspection Checklist (PEI RP900)					
UST Information					
Tank ID:	UST 35 - Plant Science Research Date:				
Inspector:					
Item		Status			
RP900 8.4		YES	NO	N/A	
	Complete monthly checklist and compare to previously completed			V	
Monthly Inspections	monthly checklists			X	
	Monthly inspections reviewed and found adequate			X	
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A	
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt				
	safe wiring in good condition				
	Mechanical line-leak detector properly vented, vent tube not kinked				
	or twisted				
	Mechanical line-leak detector passes 3.0 gph test				
All STP	Electronic line-leak detector passes 3.0 gph test				
	Flexible connector not twisted, kinked, or bent beyond				
	manufacturer's specifications				
	Submersible pump and visible piping and fittings show no signs of				
	leakage				
	Piping in good condition				
No STP Sump	Submersible pump head, flex connector(s) and other metal product				
	piping are not in contact with soil or are cathodically protected				
	Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects				
	Penetration fittings intact and secured			-	
	Piping interstitial space open to the sump (open piping system only)				
	Alarm sounds when pressure or vacuum is released (closed piping			-	
	system only)				
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping				
on in Sump	system only)				
	Sump sensor properly mounted at the bottom of the sump			 	
	Sensor tested and functional				
	Sump lid, gasket, and seals present and in good condition				
	Manway conver at grade in good condition, does not touch sump,				
	all bolts present, handles and lift mechanism in good condition				
RP900 8.6 - Other Ta		YES	NO	N/A	
	Any water or product removed and disposed of properly		,,,		
	Sump is free of cracks, holes, bulges, or other defects				
	Penetration fittings intact and secured				
	Piping interstitial space open to the sump (open piping system only)				
Otto T t- T	Alarm sounds when pressure or vacuum is released (closed piping				
Other Tank-Top	system only)			X	
Sump (Same Procedure as STP Sump)	Entire interstitial space under pressure or vacuum (closed piping			V	
	system only)			X	
	Sump sensor properly mounted at the bottom of the sump			Х	
	Sensor tested and functional			Х	
	Sump lid, gasket, and seals present and in good condition			Х	
	Manway conver at grade in good condition, does not touch sump,				
	all bolts present, handles and lift mechanism in good condition				

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			
(Same Procedure as	Entire interstitial space under pressure or vacuum (closed piping			
` STP Sump)	system only)			
. ,	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			
RP900 8.8 - ATG Man	ihole	YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
470.14	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area		YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow			
Drop Tube	diffuser present)			
., .	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			
RP900 8.10 - Overfill	Prevention	YES	NO	N/A
Drop Tubo Chuteff	Valve moves freely and operates according to manufacturer's			
Drop Tube Shutoff	specifications			
(Flapper Valve)	Valve installed at proper height			
	Ball float can be removed and inspected			
Ball-Float Valve	Cage intact, ball in good condition, moves freely, seats firmly;			
Dall-Float valve	breather hole open			
	Installed at proper height			
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
	Alarm sounds at the proper product level			
RP900 8.11 - Leak De	etection	YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATC Corrects	Verify in-tank leak-detection tests are being completed			
ATG Console	Verify correct set-up parameters for the in-tank test			
	Verify correct set-up parameters for electronic line-leak detector			
	Verify piping leak-detection tests are being completed			
	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			
	"Wet" tank leak-detection liquid depth within proper range			
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Line Tightness Testing	If pressurized piping has been tested in the last year, review the			
	results and verify that the test passed			
	If suction piping has been tested within the last three years, review			
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			
Under Pump Check	Below grade piping slopes continuously back to the tank			
Valve (Suction)	There is only one check valve, and it is located as close as			
	practicable to the suction pump			
	• •			

RP900 8.11 - Leak Do	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			
Testing	the results and verify that the test passed			
Continuous Soil-	Sensing device calibrated and tested			
Vapor Monitoring	Solicing device campitated and tested			
Continuous				
Groundwater	Sensing device tested			
Monitoring				
RP900 8.12 - Corrosi		YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			
CP	years and test passed			
	No exposed wires			
Tank Lining	Lining inspected as required and in good condition			
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Obtroicte of dispriant over of fredit taring is level, no significant orders			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			X
Collection Points				^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			X
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			X
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			
Inspection	If fuel-dispenser sump is present, sump is dry			
RP900 8.15 - Fuel Dis		YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			
	Piping in good condition			
	Stage II piping functional or else capped and sealed at elevation			
	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			
Dispensers With	Sump free of trash, debris, and used filters			
Sumps	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
Piping Interstitial Space	Piping interstitial space open to the sump			
	Piping interstitial space closed to the sump			
	Sensor present in the fuel-dispenser sump with closed double-			
	walled piping system			
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			
Sensors	Electronic sensor tested and functional			
	Mechanical float sensor free to move and properly adjusted			
Describe any Deficie	encies Here			

UST Annual Insp	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 36 - Plant Science Research Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed	Î		· ·
Monthly Inspections	monthly checklists			X
	Monthly inspections reviewed and found adequate			Х
RP900 8.5 - Submers	sible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			
	safe wiring in good condition			
	Mechanical line-leak detector properly vented, vent tube not kinked			
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			
All STP	Electronic line-leak detector passes 3.0 gph test			
	Flexible connector not twisted, kinked, or bent beyond			
	manufacturer's specifications			
	Submersible pump and visible piping and fittings show no signs of			
	leakage			
	Piping in good condition			
No STP Sump	Submersible pump head, flex connector(s) and other metal product			
No 311 Sump	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
	system only)			
	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition	\/=0	110	
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			X
Sump (Same	system only)			
Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			Х
Sump)	system only)			
.,	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			l

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			
(Same Procedure as	Entire interstitial space under pressure or vacuum (closed piping			
` STP Sump)	system only)			
. ,	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			
RP900 8.8 - ATG Man	ihole	YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
470.14	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area		YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow			
Drop Tube	diffuser present)			
., .	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			
RP900 8.10 - Overfill	Prevention	YES	NO	N/A
Drop Tubo Chuteff	Valve moves freely and operates according to manufacturer's			
Drop Tube Shutoff	specifications			
(Flapper Valve)	Valve installed at proper height			
	Ball float can be removed and inspected			
Ball-Float Valve	Cage intact, ball in good condition, moves freely, seats firmly;			
Dall-Float valve	breather hole open			
	Installed at proper height			
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
	Alarm sounds at the proper product level			
RP900 8.11 - Leak De	etection	YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATC Corrects	Verify in-tank leak-detection tests are being completed			
ATG Console	Verify correct set-up parameters for the in-tank test			
	Verify correct set-up parameters for electronic line-leak detector			
	Verify piping leak-detection tests are being completed			
	Tank interstitial access is present			
Continuous Interstitial	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			
	"Wet" tank leak-detection liquid depth within proper range			
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
Line Tightness Testing	If pressurized piping has been tested in the last year, review the			
	results and verify that the test passed			
	If suction piping has been tested within the last three years, review			
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			
Under Pump Check	Below grade piping slopes continuously back to the tank			
Valve (Suction)	There is only one check valve, and it is located as close as			
	practicable to the suction pump			
	• •			

RP900 8.11 - Leak Do	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			
Testing	the results and verify that the test passed			
Continuous Soil-	Songing dayion calibrated and tosted			
Vapor Monitoring	Sensing device calibrated and tested			
Continuous				
Groundwater	Sensing device tested			
Monitoring				
RP900 8.12 - Corrosi		YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			
CP	years and test passed			
CP	No exposed wires			
Tank Lining	Lining inspected as required and in good condition			
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Concrete of aspiral over of flear tanks is level, no significant cracks			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			Х
Collection Points	Cap in good condition, his lightly, little of no liquid in bottom			_ ^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			Х
Stage II Testing	passing			_ ^
Site Diagram	Site diagram accurately reflects the site conditions			X
RP900 8.14 - Initial F	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			
Inspection	If fuel-dispenser sump is present, sump is dry			
RP900 8.15 - Fuel Dis	spenser Inspection	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			
All Dispensers	manufacturer's specifications			
	Piping in good condition			
	Stage II piping functional or else capped and sealed at elevation			
	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			
Dispensers With	Sump free of trash, debris, and used filters			
Sumps	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
Piping Interstitial Space	Piping interstitial space open to the sump			
	Piping interstitial space closed to the sump			
	Sensor present in the fuel-dispenser sump with closed double-			
	walled piping system			
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			
	Electronic sensor tested and functional			
Sensors	Mechanical float sensor free to move and properly adjusted			
	intecrianical float sensor free to move and properly adjusted			

Tank ID: UST 40 - Springhill Isolation Farm Date: Imapector: Imapector: Status RP900 8.4 Complete monthly checklist and compare to previously completed Monthly inspections Monthly inspections reviewed and found adequate Monthly inspections reviewed and found adequate YES NO N/A Image: Monthly inspections reviewed and found adequate YES NO N/A Image: Image: Monthly inspections reviewed and found adequate YES NO N/A Image: Image: Monthly inspections reviewed and found adequate YES NO N/A Image:	UST Annual Inspe	ection Checklist (PEI RP900)			
Inspector: Item	UST Information				
Item RP900 8.4 Complete monthly checklist and compare to previously completed monthly checklists Monthly Inspections	Tank ID:	UST 40 - Springhill Isolation Farm Date:			
Complete monthly checklist and compare to previously completed monthly checklists	Inspector:				
Complete monthly checklist and compare to previously completed monthly checklists					
Monthly Inspections Complete monthly checklists and compare to previously completed monthly checklists Monthly inspections reviewed and found adequate RP900 8.5 - Submersible Turbine Pump (STP) Junction box(es) sealed, not corroded; seal-offs present; intrinsicalit safe wiring in good condition Mechanical line-leak detector poserly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test All STP Electronic line-leak detector passes 3.0 gph test Fiexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space upen to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump bid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump sensor properly mounted at the bottom of the sump Sump (Same Procedure as STP Sump) Any water or product removed and disposed of properly Sump sensor properly mounted at the bottom of the sump Sump (asaket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, Sump lid, gasket, and seals present and in good condition Menvay conver at grade in good condition, does not touch sump,	Item		Status		
Monthly Inspections	RP900 8.4		YES	NO	N/A
RP900 8.5 - Submersible Turbine Pump (STP) Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt safe wiring in good condition Mechanical line-leak detector properly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) STP in Sump STP in Sump STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Wannaway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping system only) Anamay conver at grade in good condition, does not touch sump, all botts present, handless and lift mechanism in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sump is free of cracks,		Complete monthly checklist and compare to previously completed			
RP900 8.5 - Submersible Turbine Pump (STP) Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt safe wiring in good condition Mechanical line-leak detector properly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Anaway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Anaway conver at grade in good condition described piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Anaway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Anaway conver at grade in good condition, does not touch sump, supplied interstitial space under pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sump lid, gas	Monthly Inspections				
Junction box(es) sealed, not corroded; seal-offs present; intrinsicalit safe wiring in good condition Mechanical line-leak detector properly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) ARP900 8.6 - Other Tank-Top Sump Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum					
safe wiring in good condition Mechanical line-leak detector properly vented, vent tube not kinked or twisted Mechanical line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Any water or product removed and disposed of properly Sump lid, gasket, and seals present and in good condition Anway conver at grade in good condition, does not touch sump, all bolls present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuu	RP900 8.5 - Submers		YES	NO	N/A
All STP Bleckroine-leak detector passes 3.0 gph test X X All STP Bleckroine-leak detector passes 3.0 gph test X X All STP Bleckroine-leak detector passes 3.0 gph test X X All STP Bleckroine-leak detector passes 3.0 gph test X X All STP Bleckroine-leak detector passes 3.0 gph test X X All STP Bleckroine-leak detector passes 3.0 gph test X X All STP Bleckroine-leak detector passes 3.0 gph test X X All STP Bleckroine-leak detector passes 3.0 gph test X X All STP Bleckroine-leak detector passes 3.0 gph test X X All STP All STP Any All Streek detector passes 3.0 gph test X X All STP Any All Streek detector passes 3.0 gph test X X All STP Any All Streek detector passes 3.0 gph test X X Any All Streek detector passes 3.0 gph test X Any All Streek detector passes 3.0 gph test X X Any All Streek detector passes 3.0 gph test X Any All Streek detector passes 3.0 gph test X Any All Streek detector passes 3.0 gph test X Any All Streek detector passes passes not touch sump, all bolts present, handles and lift mechanism in good condition All Streek detector passes detector					X
All STP All STP All STP All STP Electronic line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (closed piping system only) Sump sensor property mounted at the bottom of the sump Sump lid, gasket, and seals present and in good condition Any water or product removed and disposed of property X Sump sensor property mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Any water or product removed and disposed of property X Sump sensor property mounted at the bottom of the sump Any water or product removed and disposed of property Sensor tested and functional X Sump lid, gasket, and seals present and in good condition X Sump lid, gasket, and seals present and in good condition Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only)					
All STP All STP Electronic line-leak detector passes 3.0 gph test Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) STP in Sump STP in Sump STP in Sump Entire intersititial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Any water or product removed and disposed of properly Sump sensor properly mounted at disposed of properly Sump sensor properly mounted at disposed of properly Sump sensor properly mounted at disposed of properly Sump sensor properly mounted at disposed of properly Sump sensor properly mounted and disposed of properly Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire intersitial space open to the sump (open piping system only) Any water or product removed and disposed of properly Sump sensor properly mounted at the bottom of the sump Sump system only) Entire intersitial space open to the sump (open piping system only) Any water or product removed and disposed of properly Sump sensor properly mounted at the bottom of the sump Sensor tested and func					X
Electronic line-leak detector passes 3.0 gph test Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Any water or product removed and disposed of properly Sump sensor properly mounted at the bottom of the sump Ary water or product removed and disposed of properly Sump sensor properly mounted at the bottom of the sump Ary water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Ary Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Ary water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum					
Flexible connector not twisted, kinked, or bent beyond manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Xump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) STP in Sump STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Xump lid, gasket, and seals present and in good condition Xumy water or product removed and disposed of properly Sump (Same Procedure as STP Sump) Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Cother Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Entire interstitial space open to the sump (open piping system only) Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Full diam sounds when pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Xump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	A II O T D				
manufacturer's specifications Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump since of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds	All STP				X
Submersible pump and visible piping and fittings show no signs of leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of property Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire intersitial space under pressure or vacuum (closed piping system only) Entire intersitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition X RP900 8.6 - Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					Х
leakage Piping in good condition No STP Sump Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) X STP in Sump STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Procedure as STP Sump) Other Tank-Top Sump Other Tank-Top Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space copen to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Piping in good condition Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					Х
Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected X					V
piping are not in contact with soil or are cathodically protected Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only)					^
Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) X Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	No STP Sump				Х
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Other Tank-Top Sump Other Tank-Top Sump (Same Procedure as STP Sump) Other Tank-Top Sump (Same Procedure as STP Sump) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					X
Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump (Same Procedure as STP Sump) Sump) Sump id, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					Х
STP in Sump Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					· ·
System only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					X
System only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire intersitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	·	system only)			^
Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Sump sensor properly mounted at the bottom of the sump			
Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Sensor tested and functional			
all bolts present, handles and lift mechanism in good condition RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Sump lid, gasket, and seals present and in good condition			Х
RP900 8.6 - Other Tank-Top Sump Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump) Sump) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		Manway conver at grade in good condition, does not touch sump,			V
Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	RP900 8.6 - Other Ta		YES	NO	N/A
Other Tank-Top Sump (Same Procedure as STP Sump) Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Other Tank-Top Sump (Same Procedure as STP Sump) Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Other Tank-Top Sump (Same Procedure as STP Sump) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Sump (Same Procedure as STP Sump) Sump) Sump (Same Procedure as STP Sump) Sump (Same Procedure as STP Sump) Sump (Same Sump) Sump (Closed piping System only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Sump (Same Procedure as STP Sump) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	Other Tank-Top	, , , , ,			Х
Sump) system only) Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Sump sensor properly mounted at the bottom of the sump X Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,		· · · · · · · · · · · · · · · · · · ·			Х
Sensor tested and functional X Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,	Sump)				 v
Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump,					
Manway conver at grade in good condition, does not touch sump,					
		all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			Х
All Other Sumps	system only)			^
(Same Procedure as				X
STP Sump)	system only)			
	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			Х
RP900 8.8 - ATG Mar	all bolts present, handles and lift mechanism in good condition	YES	NO	N/A
KF900 0.0 - ATG WAI	Cap in good condition, seals tightly, hole sealed at probe wiring	TES	NO	I X
	Wire splices sealed and wire in good condition			X
	Junction box and conduit sealed, in good condition			X
	Probe and floats in good condition, both floats present and move			^
ATG Manhole	freely			X
	Verify operation of water- and product-level warnings and alarms			X
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			Х
RP900 8.9 - Fill Area		YES	NO	N/A
Drop Tubo	Drop tube extends to within 6 inches of the tank bottom (if no flow			
Drop Tube	diffuser present)			
Vapor-Recovery	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			X
	tightly			
RP900 8.10 - Overfill		YES	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications			
, , ,	Valve installed at proper height			X
	Ball float can be removed and inspected			X
Ball-Float Valve	Cage intact, ball in good condition, moves freely, seats firmly; breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			X
Overfill Alarm	Alarm is functional			X
Overnii Alaini	Alarm sounds at the proper product level			X
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms	120	110	X
	Alarm history shows no recurring leak alarms			X
	Verify in-tank leak-detection tests are being completed			X
ATG Console	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			X
Continuous Interstitial Monitoring	Tank interstitial access is present			Х
	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			X
	"Wet" tank sensor functional, reinstalled in proper position			Х
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			V
Detection Monitor	or alarms			X
	If pressurized piping has been tested in the last year, review the			X
Line Tightness	results and verify that the test passed			
Testing	If suction piping has been tested within the last three years, review			Х
	the results and verify that the test passed			
	Below grade piping operates at less than atmospheric pressure			1
Under Pump Check	Below grade piping operates at less than atmospheric pressure			-

_			
Valve (Suction)	There is only one check valve, and it is located as close as		
, ,	practicable to the suction pump		

RP900 8.11 - Leak D	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			_ ^
Continuous Soil-	Sensing device calibrated and tested			X
Vapor Monitoring	Ochsing device camprated and tested			^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi		YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current CP	Verify that CP testing has been conducted within the past three			x
	years and test passed			
	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscell	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Consider of deprical even of mean tanke to level, the digital carte ordere			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			x
Collection Points				^
Stage II Testing	Verify that Stage II testing has been conducted and test results are			x
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			X
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Di		YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			x
	safe wiring in good condition			
	Flexible connector not twisted, kinked, or bent beyond			l x
All Dispensers	manufacturer's specifications			
	Piping in good condition			X
	Stage II piping functional or else capped and sealed at elevation			x
5	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			X
Sumps	or water or are cathodically protected			
Diamana ana Mith	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
<u> </u>	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump			Х
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump			
	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-			Х
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system			X X X
Piping Interstitial Space	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump			X X X
Piping Interstitial	Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system			X X X

UST Annual Insp	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 41 - Springhill Isolation Farm Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	sible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			X
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			Х
All STP	Electronic line-leak detector passes 3.0 gph test			Х
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			^
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			Х
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
	piping are not in contact with soil or are cathodically protected			X
	Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			
	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			X
-	system only)			^
Sump (Same Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			X
Sump)	system only)			
Guilip)	Sump sensor properly mounted at the bottom of the sump			X
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			V
All Other Sumps	system only)			Х
(Same Procedure as				Х
STP Sump)	system only)			^
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			Х
	all bolts present, handles and lift mechanism in good condition			^
RP900 8.8 - ATG Mar		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring			Х
	Wire splices sealed and wire in good condition			Х
	Junction box and conduit sealed, in good condition			X
ATG Manhole	Probe and floats in good condition, both floats present and move			
AT S WATHOUT	freely			X
	Verify operation of water- and product-level warnings and alarms			X
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			Х
RP900 8.9 - Fill Area		YES	NO	N/A
Drop Tube	Drop tube extends to within 6 inches of the tank bottom (if no flow			
Бтор тавс	diffuser present)			
Vapor-Recovery	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			l x
	tightly	\/=0	110	
RP900 8.10 - Overfill		YES	NO	N/A
Drop Tube Shutoff	Valve moves freely and operates according to manufacturer's			X
(Flapper Valve)	specifications			V
	Valve installed at proper height			X
	Ball float can be removed and inspected			
Ball-Float Valve	Cage intact, ball in good condition, moves freely, seats firmly;			X
	breather hole open			Х
	Installed at proper height			
Over will Alama	Alarm mounted near fills, clearly labeled Alarm is functional			X
Overfill Alarm				
RP900 8.11 - Leak De	Alarm sounds at the proper product level	YES	NO	X
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			X
	Alarm history shows no recurring leak alarms			
ATG Console	Verify in-tank leak-detection tests are being completed			X
	Verify correct set-up parameters for the in-tank test			X
	Verify correct set-up parameters for electronic line-leak detector			X
	Verify piping leak-detection tests are being completed			X
Continuous Interstitial Monitoring	Tank interstitial access is present			X
	"Dry" tank sensor tested and functional, reinstalled at bottom of tank			X
	"Wet" tank sensor functional, reinstalled in proper position			X
	"Wet" tank leak-detection liquid depth within proper range			Х
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			X
Detection Monitor	or alarms			
Line Till	If pressurized piping has been tested in the last year, review the			X
Line Tightness	results and verify that the test passed			
Testing	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
Under Pump Check	Below grade piping operates at less than atmospheric pressure Below grade piping slopes continuously back to the tank			X
	IBEIOW GRADE DIDING SIGNES CONTINUOUSLY DACK TO THE TANK			. X

Valve (Suction)	There is only one check valve, and it is located as close as		V
	practicable to the suction pump		^

Tank Tightness Testing Continuous Soil- Vapor Monitoring Continuous Groundwater Monitoring RP900 8.12 - Corrosion Protection Verify that CP testing of all metallic components in contact with soil or water has been conducted within the past three years and that the test passed Impressed Current CP Werify that CP testing of all metallic components in contact with soil or water has been conducted within the past three years and that the test passed No exposed wires Tank Lining Lining inspected as required and in good condition XRP900 8.13 - Miscellaneous Tank Pad & Pavement Cap in good condition, fits tightly, little or no liquid in bottom Stage II Liquid- Collection Points Size Diagram Site Diagram Site Diagram Site diagram accurately reflects the site conditions XRP900 8.14 - Initial Fuel Dispenser Inspection All dispenser components are clean and dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers All Dispensers Without Cap in good condition Dispensers Without Sumps Fiex Done Correct or act and dispensed in proceeding the first or no twisted, kinked, or bent beyond manufacturer's specifications Piping in good condition Dispensers Without Sumps Sumps	RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Vanior Monitoring Continuous Groundwater Monitoring RP900 8.12 - Corrosion Protection Werify that CP testing of all metallic components in contact with soil or water has been conducted within the past three years and that the test passed Impressed Current CP Verify that CP testing of all metallic components in contact with soil or water has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three Verify that CP testing has been conducted within the past three Verify that CP testing has been conducted within the past three Verify that CP testing has been conducted within the past three Verify that CP testing has been conducted within the past three Verify that CP testing has been conducted within the past three Verify that Stage II testing has been conducted within the past three Verify that Stage II testing has been conducted and test results are passing Stage II Testing Verify that Stage II testing has been conducted and test results are passing Site Diagram Site diagram accurately reflects the site conditions X X RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser If fuel-dispenser sump is present, sump is dry X X RP900 8.15 - Fuel Dispenser inspection All Dispensers All Dispensers Piping in good condition Flexible connector to thyisted, kinked, or bent beyond manufacturer's specifications Piping in good condition Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Piping in feer of tracks, holes, bulges, or other defects Any water removed and disposed of properly Any water removed and disposed of properly Any water removed and disposed of properly Any water removed and disposed of properly Any water removed and disposed of properly Any water removed and disposed of properly Any water removed and disposed of properly Any water removed and disposed of properly Any water removed and disposed of properly Any water removed and disposed of properly An		•			Х
Groundwater Monitoring RP900 8.12 - Corrosion Protection Verify that CP testing of all metallic components in contact with soil or water has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and test passed No exposed wires X		Sensing device calibrated and tested			Х
RP900 8.12 - Corrosion Protection	Groundwater	Sensing device tested			x
Galvanic CP Galvanic CP Galvanic CP Galvanic CP Impressed Current the test passed Impressed Current CP No exposed wires Tank Lining Lining inspected as required and in good condition Tank Pad & Pavement Stage II Liquid-Collection Points Stage II Testing Site Diagram Site Diagram Site diagram accurately reflects the site conditions X P900 8.15 - Fuel Dispenser Inspection Initial Dispenser Suffing in good condition All Dispensers All Dispensers Without Sumps Dispensers With Sumps Dispenser Sump Space Dispenser Sump Space Dispenser Sump Sensor represent in the fuel-dispenser sump with closed double-walled piging system Dispenser Sump Sensor represent in the fuel-dispenser sump with closed double-walled piging system Sumps Sump Suspenser Inspection to the fuel-dispenser siand functional or water or are additional fullers sump Suspenser Sump Suspenser Sump Suspenser Sump Suspenser Sump Suspenser Sump Suspenser Sump Suspenser Sump Suspenser Sump Suspenser Sump Suspenser Sump Suspenser Sump Sump Suspenser Sump Sump Suspenser Sump Sump Sump Sump Sump Sump Sump Sump		on Protection	YES	NO	N/A
Galvanic CP or water has been conducted within the past three years and that the test passed Verify that CP testing has been conducted within the past three years and test passed years and test passed Services and test passed Verify that CP testing has been conducted within the past three years and test passed Services Servic					
Pars and test passed No exposed wires X No exposed wires X X No exposed wires X X X X X X X X X	Galvanic CP	or water has been conducted within the past three years and that the test passed			
Tank Lining Lining inspected as required and in good condition X RP900 8.13 - Miscellaneous YES NO N/A Tank Pad & Pavement Stage II Liquid-Collection Points Stage II Testing Site Diagram Site diagram accurately reflects the site conditions YES NO N/A RP900 8.14 - Initial Fuel Dispenser Inspection YES NO N/A Initial Dispenser Inspection Inspection Junction boxes sealed, not corroded; seal-offs present; intrinsically safe wiring in good condition All Dispensers Piping in good condition Dispensers Without Sumps Dispensers Without Sumps Dispensers Without Sumps Dispensers Without Sumps Sump is free of cracks, holes, bulges, or other defects Piping interstitial space dosed to the sump Dispenser Sump Sensor Sump Sump Sump Sensors Sump Sump Sump Sensors Sump Sump Sump Sump Sump Sump Sump Sump	•	years and test passed			Х
RP900 8.13 - Miscellaneous		·			
Tank Pad & Pavement Stage II Liquid-Collection Points Stage II Testing Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Site Diagram Site Dispenser Inspection Initial Dispenser Inspection Inspection If fuel-dispenser sere unique in good condition All Dispensers All Dispensers All Dispensers All Dispensers Without Sumps Dispensers Without Sumps Dispensers Without Sumps Dispensers With Sumps Piping in good condition Dispensers With Sumps Piping in free of trash, debris, and used filters Piping Interstitial Space Piping Interstitial Space Piping interstitial space copen to the sump Sensors Sensors Sensors Concrete or asphalt over or near tanks is level, no significant cracks X X X X X X X X X X X X X					Х
Pavement Stage II Liquid-Collection Points Cap in good condition, fits tightly, little or no liquid in bottom X		aneous	YES	NO	N/A
Collection Points Stage II resting Verify that Stage II testing has been conducted and test results are passing Site Diagram Site diagram accurately reflects the site conditions X X X X X X X X X	Pavement	Concrete or asphalt over or near tanks is level, no significant cracks			
Site Diagram Site diagram accurately reflects the site conditions RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser Inspection Initial Dispenser Inspection All dispenser components are clean and dry If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers Without Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Any water or are cathodically protected Any water or are cathodically protected Any water removed and disposed of properly X Sump is free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Ax Piping Interstitial space open to the sump Piping Interstitial space closed to the sump Sensor properly mounted at the bottom of the sump Sensor properly mounted at the bottom of the sump Sensor properly mounted at the bottom of the sump Sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump Sump sensor properly mounted at the bottom of the sump					Х
RP900 8.14 - Initial Fuel Dispenser Inspection Initial Dispenser Inspection Initial Dispenser Inspection If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers All Dispensers Piping in good condition Dispensers Without Sumps Dispensers With Sumps Piping Interstitial Space Piping Interstitial Space Piping Interstitial Space Piping Interstitial Sumps Dispenser Sump Dispenser Sump Piping Interstitial Space Piping Interstitial Sumps Dispenser Sump Piping Interstitial Sumps Dispenser Sump Piping Interstitial Sumps Dispenser Sump Piping Interstitial Space Dispenser Sump Dispenser Sump Sensors Sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump Sump sensor property mounted at the bottom of the sump	Stage II Testing	passing			Х
Initial Dispenser Inspection If fuel-dispenser sump is present, sump is dry RP900 8.15 - Fuel Dispenser Inspection All Dispensers All dispenser Inspection All Dispensers Inspection All Dispensers All Dispensers All dispenser Inspection All Dispensers Inspection All Dispensers Without Safe wiring in good condition All Dispensers Without Stage II piping functional or else capped and sealed at elevation All Dispensers Without Stage II piping functional or else capped and sealed at elevation All Dispensers Without Stage II piping interstilications All Dispensers Without Stage II piping interstitial sport capped and sealed at elevation All Dispensers Without Stage II piping interstitial piping are not in contact with soil or water or are cathodically protected Any water removed and disposed of properly All Dispensers Without Stage II piping interstitial sport capped and sealed at elevation All Dispensers Without Stage II piping interstitial sport capped and sealed at elevation All Dispensers Without Stage II piping interstitial sport capped and sealed at elevation All Dispenser Sump Stage II piping interstitial sport capped and sealed at elevation All Dispenser Sump Stage II piping interstitial sport capped and sealed at elevation All Dispenser Sump Stage II piping interstitial sport capped and sealed at elevation All Dispenser Sump Stage II piping interstitial sport capped and sealed at elevation All Dispenser Sump Stage II piping interstitial sport capped and sealed at elevation All Disp		,			Х
Inspection If fuel-dispenser sump is present, sump is dry X			YES	NO	
RP900 8.15 - Fuel Dispenser Inspection All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Without Sumps Dispensers Without Sumps All Dispensers With Or Water or are cathodically protected Any water removed and disposed of properly Dispensers With Sump Sump Sensors All Dispensers With Or Water or are cathodically protected Any water removed and disposed of properly Any water removed and disposed of properly All Dispensers With Sump free of trash, debris, and used filters All Dispensers With Or Water or are cathodically protected Any water removed and disposed of properly All Dispensers With Or Water or are cathodically protected Any water removed and disposed of properly All Dispensers With Or Water or are cathodically protected Any water removed and disposed of properly All Dispensers With Or Water or are cathodically protected Any water removed and disposed of properly All Dispensers With Or Water or are cathodically protected Any water removed and disposed of properly All Dispensers Without Or Water or are cathodically protected Any water removed and disposed of properly All Dispensers Without Or Water or are cathodically protected Any water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of properly A Water removed and disposed of pro					
All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Without Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Any water removed and other metallic piping are not in contact with soil or water or are cathodically protected Any water removed and disposed of properly Dispensers With Sumps Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Dispenser Sump Dispenser Sump Dispenser Sump Sensors Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional			\ (T0		
All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers All Dispensers Piping in good condition Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Dispensers With Dispensers With Dispensers With Dispensers With Sumps Any water removed and disposed of properly Dispensers With Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Dispenser Sump Dispenser Sump Sensors Sump sensor properly mounted at the bottom of the sump X X X X X X X X X X X X X	RP900 8.15 - Fuel Dis	•	YES	NO	N/A
All Dispensers manufacturer's specifications		safe wiring in good condition			Х
Stage II piping functional or else capped and sealed at elevation lower than the fuel dispenser island Dispensers Without Sumps Plex connectors and other metallic piping are not in contact with soil or water or are cathodically protected Any water removed and disposed of properly Sump free of trash, debris, and used filters Sumps Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping Interstitial Space Piping interstitial space open to the sump Sensor present in the fuel-dispenser sump with closed doublewalled piping system Sump sensor properly mounted at the bottom of the sump Sensors Sump sensor tested and functional	All Dispensers	·			
Lower than the fuel dispenser island					Х
Sumps or water or are cathodically protected Any water removed and disposed of properly Sump free of trash, debris, and used filters Sumps Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured X Piping Interstitial Space Piping interstitial space open to the sump Sensors Dispenser Sump Sensors Sump or water or are cathodically protected Any water removed and disposed of properly X X X Puping free of trash, debris, and used filters X Penetration fittings intact and secured X Piping interstitial space open to the sump X Sensor present in the fuel-dispenser sump with closed double- walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X					Х
Any water removed and disposed of properly Sump free of trash, debris, and used filters Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured X Piping Interstitial Space Piping interstitial space open to the sump Piping interstitial space closed to the sump Sensors Dispenser Sump Sensors Any water removed and disposed of properly X X X Puping interstiting interstitial space closed to the sump X Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X X X X Electronic sensor tested and functional	· ·				Х
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured X Piping Interstitial space open to the sump Piping Interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Dispenser Sump Sensors Sump sensor properly mounted at the bottom of the sump X X X X Z Z Z Z Z Z Z Z Z					Х
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured X Piping Interstitial space open to the sump Sensors Sump is free of cracks, holes, bulges, or other defects X Penetration fittings intact and secured X Piping interstitial space open to the sump X Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X	Dispensers With				Х
Piping Interstitial space open to the sump Space Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X X X X X Electronic sensor tested and functional	-	Sump is free of cracks, holes, bulges, or other defects			Х
Piping Interstitial space open to the sump Space Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X X X X X Electronic sensor tested and functional		Penetration fittings intact and secured			Х
Space Sensor present in the fuel-dispenser sump with closed double- walled piping system Sump sensor properly mounted at the bottom of the sump Sensors Electronic sensor tested and functional					Х
Walled piping system Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X X X X X X X X X X X X X	Piping Interstitial	Piping interstitial space closed to the sump			Х
Dispenser Sump Sensors Sump sensor properly mounted at the bottom of the sump Electronic sensor tested and functional X	Space				Х
Sensors Electronic sensor tested and functional X	D: 0				Х
Selisuis Machanical float concer from to make and managing divisted	· ·				
International sensor free to move and property adjusted X	Sensors	Mechanical float sensor free to move and properly adjusted			Х

UST Daily Inspection Checklist (PEI RP900)		
UST Information		
Tank ID: UST 44 - UConn Fire Dept	Date:	
Inspector:		
Tank ID: UST 44 - UConn Fire Dept	Date:	

Item		Status		
RP900 6.4 - Leak Det	ection	YES	NO	N/A
	The power is on			
Automatic Tank	There are no warning or alarm lights blinking or lit			
	There is a liquid measurement for each tank and the reading			Х
Gauge (ATG)	appears accurate			^
	The printer has paper and is in working condition			Χ
Electronic Leak-	The power is on			Х
Detection Monitor	There are no warning or alarm lights blinking or lit			X
Mech. Line-Leak Detector	No customers have complained about slow flow			Х
Daily Inventory	Inventory records are reconciled daily and daily variance is within			Х
Daily Inventory	the guidelines set by the facility owner			^
RP900 6.5 - Tank Fill	Area	YES	NO	N/A
Fill Cover	Fill cover present, not broken or damaged			
Fill Cover	Fill covers are identified by color and located on the correct tank			X
	No dirt, trash, water, or product in the spill-containment manhole			Х
Spill-Containment	No cracks, bulges or holes in the spill-containment manhole			X
Manhole (Spill Bucket)	Below-grade containment manhole properly latched (if present)			X
	Below-grade containment manhole contains oil absorbent material			Х
Fill Dino	Fill cap in good condition, seals tightly			
Fill Pipe	No obstruction inside the fill pipe.			

NOTE: Tank is an overflow tank for the Oil Water Separator	 Therefore, it is not equipped with typical UST comp 	onents
--	---	--------

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID:	UST 45 - Waste Water Head Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X
	safe wiring in good condition			
	Mechanical line-leak detector properly vented, vent tube not kinked			X
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			X
All STP	Electronic line-leak detector passes 3.0 gph test			X
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			X
	Piping in good condition			_ ^
No STP Sump	Submersible pump head, flex connector(s) and other metal product piping are not in contact with soil or are cathodically protected			X
'	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
	system only)			X
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			V
- · · · · · · · · · · · · · · · · · · ·	system only)			X
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			Х
	Sump lid, gasket, and seals present and in good condition			Х
	Manway conver at grade in good condition, does not touch sump,			V
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	N/A
	Any water or product removed and disposed of properly			
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			X
Sump (Same Procedure as STP Sump)	system only)			^
	Entire interstitial space under pressure or vacuum (closed piping			X
	system only)			
1 /	Sump sensor properly mounted at the bottom of the sump Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition			
	an solic prosent, namico ana int medianism in good condition		l	

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			Х
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				
STP Sump)	system only)			X
17	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Mar		YES	NO	N/A
111 000 010 711 0 11141	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14//
1	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	p p	YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow	120	110	14//
Drop Tube	diffuser present)			
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	N/A
	Valve moves freely and operates according to manufacturer's			1471
Drop Tube Shutoff	specifications			
(Flapper Valve)	Valve installed at proper height			
	Ball float can be removed and inspected			Х
Dell Fleet Velve	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			X
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
	Alarm sounds at the proper product level			
RP900 8.11 - Leak De	etection	YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATC Concolo	Verify in-tank leak-detection tests are being completed			Х
ATG Console	Verify correct set-up parameters for the in-tank test			Х
	Verify correct set-up parameters for electronic line-leak detector			Х
	Verify piping leak-detection tests are being completed			X
	Tank interstitial access is present			
Continuous Interstitial	,			Х
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			
	"Wet" tank leak-detection liquid depth within proper range			
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
	If pressurized piping has been tested in the last year, review the			X
Line Tightness	results and verify that the test passed			
Testing	If suction piping has been tested within the last three years, review			X
	the results and verify that the test passed			
I	Below grade piping operates at less than atmospheric pressure			
Under Pump Check	Below grade piping slopes continuously back to the tank			
Valve (Suction)	There is only one check valve, and it is located as close as			X
	practicable to the suction pump			

RP900 8.11 - Leak De	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			^
Continuous Soil-	Sensing device calibrated and tested			l x
Vapor Monitoring	Consing device campitated and tested			^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corrosi		YES	NO	N/A
Galvanic CP	Verify that CP testing of all metallic components in contact with soil			
	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			l x
CP	years and test passed			
	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscella	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	definition of aspiral over of flear tarks is level, the significant orders			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			l x
Collection Points				
Stage II Testing	Verify that Stage II testing has been conducted and test results are			l x
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			Х
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Dis		YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			l x
	safe wiring in good condition			
All Dispensers	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			
	Piping in good condition			Х
	Stage II piping functional or else capped and sealed at elevation			X
	lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			l x
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			Х
Dispensers With Sumps	Sump free of trash, debris, and used filters			Х
	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
Piping Interstitial Space	Piping interstitial space open to the sump			Х
	Piping interstitial space closed to the sump			Х
	Sensor present in the fuel-dispenser sump with closed double-			Х
	walled piping system			^
Dispenser Sump Sensors	Sump sensor properly mounted at the bottom of the sump			Х
	Electronic sensor tested and functional			Х
	Mechanical float sensor free to move and properly adjusted			Х
Describe any Deficie				

UST Annual Inspection Checklist (PEI RP900)							
UST Information							
Tank ID:	UST 46 - Waste Water Control Date:						
Inspector:							
Item		Status					
RP900 8.4		YES	NO	N/A			
Monthly Inspections	Complete monthly checklist and compare to previously completed						
	monthly checklists						
	Monthly inspections reviewed and found adequate						
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A			
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			X			
	safe wiring in good condition			^			
	Mechanical line-leak detector properly vented, vent tube not kinked			X			
	or twisted						
	Mechanical line-leak detector passes 3.0 gph test			Х			
All STP	Electronic line-leak detector passes 3.0 gph test			Х			
	Flexible connector not twisted, kinked, or bent beyond			X			
	manufacturer's specifications						
	Submersible pump and visible piping and fittings show no signs of			X			
	leakage						
	Piping in good condition			Х			
No STP Sump	Submersible pump head, flex connector(s) and other metal product			Х			
<u>'</u>	piping are not in contact with soil or are cathodically protected			X			
	Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects			X			
	Penetration fittings intact and secured			X			
	Piping interstitial space open to the sump (open piping system only)			X			
	Alarm sounds when pressure or vacuum is released (closed piping						
	system only)			X			
STP in Sump	Entire interstitial space under pressure or vacuum (closed piping			.,			
O II III Guilip	system only)			X			
	Sump sensor properly mounted at the bottom of the sump			Х			
	Sensor tested and functional			Х			
	Sump lid, gasket, and seals present and in good condition			Х			
	Manway conver at grade in good condition, does not touch sump,						
	all bolts present, handles and lift mechanism in good condition			X			
RP900 8.6 - Other Ta	nk-Top Sump	YES	NO	N/A			
	Any water or product removed and disposed of properly			X			
	Sump is free of cracks, holes, bulges, or other defects						
	Penetration fittings intact and secured						
	Piping interstitial space open to the sump (open piping system only)						
Other Tank-Top	Alarm sounds when pressure or vacuum is released (closed piping			X			
Sump (Same Procedure as STP Sump)	system only)			^			
	Entire interstitial space under pressure or vacuum (closed piping			X			
	system only)						
	Sump sensor properly mounted at the bottom of the sump						
	Sensor tested and functional						
	Sump lid, gasket, and seals present and in good condition	<u> </u>					
	Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition						
	fail boils present, nancies and filt mechanism in good condition	I					

RP900 8.7 - Other Su	mps	YES	NO	N/A
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump (open piping system only)			X
	Alarm sounds when pressure or vacuum is released (closed piping			
All Other Sumps	system only)			X
(Same Procedure as				
` STP Sump)	system only)			X
17	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			X
RP900 8.8 - ATG Mar		YES	NO	N/A
	Cap in good condition, seals tightly, hole sealed at probe wiring	120	110	14// (
	Wire splices sealed and wire in good condition			
	Junction box and conduit sealed, in good condition			
	Probe and floats in good condition, both floats present and move			
ATG Manhole	freely			
	Verify operation of water- and product-level warnings and alarms			
	Manhole cover in good condition, adequate clearance between the			
	ATG probe cap and manhole cover			
RP900 8.9 - Fill Area	F	YES	NO	N/A
	Drop tube extends to within 6 inches of the tank bottom (if no flow	120	110	14// (
Drop Tube	diffuser present)			
	Poppet of vapor-recovery adaptor (dry break) moves freely, seals			
Vapor-Recovery	tightly			X
RP900 8.10 - Overfill		YES	NO	N/A
-	Valve moves freely and operates according to manufacturer's			1 1,7 1
Drop Tube Shutoff	specifications			
(Flapper Valve)	Valve installed at proper height			
	Ball float can be removed and inspected			Х
Dell Fleet V	Cage intact, ball in good condition, moves freely, seats firmly;			
Ball-Float Valve	breather hole open			X
	Installed at proper height			Х
	Alarm mounted near fills, clearly labeled			
Overfill Alarm	Alarm is functional			
	Alarm sounds at the proper product level			
RP900 8.11 - Leak De		YES	NO	N/A
	Console has no active warnings or alarms			
	Alarm history shows no recurring leak alarms			
ATC C	Verify in-tank leak-detection tests are being completed			Х
ATG Console	Verify correct set-up parameters for the in-tank test			Х
	Verify correct set-up parameters for electronic line-leak detector			Х
	Verify piping leak-detection tests are being completed			Х
	Tank interstitial access is present			
Continuous Interstitial				Х
Monitoring	"Wet" tank sensor functional, reinstalled in proper position			
	"Wet" tank leak-detection liquid depth within proper range			
Electronic Leak-	Leak-monitoring console is operational and has no active warnings			
Detection Monitor	or alarms			
	If pressurized piping has been tested in the last year, review the			
Line Tightness	results and verify that the test passed			X
Testing	If suction piping has been tested within the last three years, review			
	the results and verify that the test passed			X
	Below grade piping operates at less than atmospheric pressure			
Under Pump Check	Below grade piping slopes continuously back to the tank			
Valve (Suction)	There is only one check valve, and it is located as close as			V
	practicable to the suction pump			X
	i samp			

RP900 8.11 - Leak D	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			^
Continuous Soil-	Sensing device calibrated and tested			l x
Vapor Monitoring	Certaing device cambrated and tested			^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corros		YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			l x
СР	years and test passed			
	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscell	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	consiste of aspiral over of mountaine to level, the dignilloant draste			
Stage II Liquid-	Cap in good condition, fits tightly, little or no liquid in bottom			l x
Collection Points				
Stage II Testing	Verify that Stage II testing has been conducted and test results are			l x
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			X
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry			X
RP900 8.15 - Fuel Di		YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			l x
	safe wiring in good condition			
A II . D.:	Flexible connector not twisted, kinked, or bent beyond			X
All Dispensers	manufacturer's specifications			
	Piping in good condition			Х
	Stage II piping functional or else capped and sealed at elevation			X
	lower than the fuel dispenser island			
Dispensers Without				X
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			Х
Sumps	Sump is free of cracks, holes, bulges, or other defects			Х
	Penetration fittings intact and secured			Х
				X
	Piping interstitial space open to the sump			
Piping Interstitial	Piping interstitial space closed to the sump			X
Piping Interstitial Space	Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-			Х
	Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system			
Space	Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double- walled piping system Sump sensor properly mounted at the bottom of the sump			X X X
	Piping interstitial space closed to the sump Sensor present in the fuel-dispenser sump with closed double-walled piping system			X

Describe any Deficiencies Here:

UST Annual Inspe	ection Checklist (PEI RP900)			
UST Information				
Tank ID: UST	52 – Supplemental Utility Plant Date:			
Inspector:				
Item		Status		
RP900 8.4		YES	NO	N/A
	Complete monthly checklist and compare to previously completed			
Monthly Inspections	monthly checklists			
	Monthly inspections reviewed and found adequate			
RP900 8.5 - Submers	ible Turbine Pump (STP)	YES	NO	N/A
	Junction box(es) sealed, not corroded; seal-offs present; intrinsicallt			Х
	safe wiring in good condition			^
	Mechanical line-leak detector properly vented, vent tube not kinked			Х
	or twisted			
	Mechanical line-leak detector passes 3.0 gph test			Х
All STP	Electronic line-leak detector passes 3.0 gph test			Х
	Flexible connector not twisted, kinked, or bent beyond			X
	manufacturer's specifications			
	Submersible pump and visible piping and fittings show no signs of			X
	leakage			
	Piping in good condition			Х
No STP Sump	Submersible pump head, flex connector(s) and other metal product			X
- No off Gump	piping are not in contact with soil or are cathodically protected			
	Any water or product removed and disposed of properly			X
	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			X
	Piping interstitial space open to the sump (open piping system only)			^
	Alarm sounds when pressure or vacuum is released (closed piping system only)			Х
CTD in Comen	Entire interstitial space under pressure or vacuum (closed piping			
STP in Sump	system only)			Х
	Sump sensor properly mounted at the bottom of the sump			Х
	Sensor tested and functional			X
	Sump lid, gasket, and seals present and in good condition			X
	Manway conver at grade in good condition, does not touch sump,		<u> </u>	
	all bolts present, handles and lift mechanism in good condition			Х
RP900 8.6 - Other Ta		YES	NO	N/A
	Any water or product removed and disposed of properly	120	110	X
	Sump is free of cracks, holes, bulges, or other defects			
	Penetration fittings intact and secured			
	Piping interstitial space open to the sump (open piping system only)			
Other Taul: Tau	Alarm sounds when pressure or vacuum is released (closed piping			V
Other Tank-Top	system only)			X
Sump (Same Procedure as STP	Entire interstitial space under pressure or vacuum (closed piping			V
Sump)	system only)			X
Sump)	Sump sensor properly mounted at the bottom of the sump			
	Sensor tested and functional			
	Sump lid, gasket, and seals present and in good condition			
	Manway conver at grade in good condition, does not touch sump,			
	all bolts present, handles and lift mechanism in good condition			

RP900 8.7 - Other Sumps Any water or product removed and disposed of properly Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Marway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height Ball float can be removed and inspected
Sump is free of cracks, holes, bulges, or other defects Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) STP Sump) STP Sump) STP Sump) Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover Pipop Tube Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly PRP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Penetration fittings intact and secured Piping interstitial space open to the sump (open piping system only) Alarm sounds when pressure or vacuum is released (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
All Other Sumps (Same Procedure as STP Sump) STP Sump) Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition ATG Manhole ATG Manhole ATG Manhole ATG Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly Vapor-Recovery RP900 8.10 - Overfill Prevention Piping interstitial space open to the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted at the bottom of the sump (losed piping system only) Sump sensor properly mounted by sump sensor proper besure or vacuum (closed piping system only) Sump sensor properly mounted by sump sensor proper besure or vacuum (closed piping system only) Sump sensor properly mounted by sump sensor proper besure or vacuum (losed piping system only) S
All Other Sumps (Same Procedure as STP Sump) Entire interstitial space under pressure or vacuum (closed piping system only) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly Valve moves freely and operates according to manufacturer's specifications Valve moves freely and operates according to manufacturer's specifications Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
ATG Manhole ATG Manhole ATG Manhole ATG Manhole ATG Manhole Drop Tube Drop Tube Drop Tube Drop Tube Drop Tube Drop Tube Drop Tube ATG Manholf Drop Tube Drop Tube Drop Tube Drop Tube ATG Symp Sump Suspensor properly mounted at the bottom of the sump sensor properly mounted at the bottom of the sump sensor properly mounted at the bottom of the sump sensor tested and functional sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition YES NO Test No
(Same Procedure as STP Sump) Entire interstitial space under pressure or vacuum (closed piping system only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all botts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
STP Sump) System only) Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole ATG Manhole
Sump sensor properly mounted at the bottom of the sump Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Sensor tested and functional Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Sump lid, gasket, and seals present and in good condition Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop Tube Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Manway conver at grade in good condition, does not touch sump, all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery RP900 8.10 - Overfill Prevention Drop Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
all bolts present, handles and lift mechanism in good condition RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring
RP900 8.8 - ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
ATG Manhole Cap in good condition, seals tightly, hole sealed at probe wiring Wire splices sealed and wire in good condition Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover YES NO NO NO NO NO NO NO N
ATG Manhole ATG M
ATG Manhole ATG Manhole Junction box and conduit sealed, in good condition Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
ATG Manhole Probe and floats in good condition, both floats present and move freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
freely Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Verify operation of water- and product-level warnings and alarms Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Drop Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Manhole cover in good condition, adequate clearance between the ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Drop Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
ATG probe cap and manhole cover RP900 8.9 - Fill Area Drop Tube Drop Tube Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Drop Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
RP900 8.9 - Fill Area Drop Tube Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Drop Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Drop Tube Drop tube extends to within 6 inches of the tank bottom (if no flow diffuser present) Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention Drop Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Vapor-Recovery diffuser present) Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention YES NO NO NO NO NO NO NO N
Vapor-Recovery Poppet of vapor-recovery adaptor (dry break) moves freely, seals tightly RP900 8.10 - Overfill Prevention YES NO NO NOTE Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Tightly Tigh
RP900 8.10 - Overfill Prevention Drop Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
Drop Tube Shutoff (Flapper Valve) Valve moves freely and operates according to manufacturer's specifications Valve installed at proper height
(Flapper Valve) specifications Valve installed at proper height
valve installed at proper height
Ball float can be removed and inspected
Ball-Float Valve Cage intact, ball in good condition, moves freely, seats firmly;
breather hole open
Installed at proper height
Alarm mounted near fills, clearly labeled
Overfill Alarm
Alarm sounds at the proper product level
RP900 8.11 - Leak Detection YES NO N
Console has no active warnings or alarms
Alarm history shows no recurring leak alarms
ATG Console Verify in-tank leak-detection tests are being completed
verify correct set-up parameters for the in-tank test
Verify correct set-up parameters for electronic line-leak detector
Verify piping leak-detection tests are being completed
Tank interstitial access is present
Continuous Interstitial "Dry" tank sensor tested and functional, reinstalled at bottom of tank
Monitoring "Wet" tank sensor functional, reinstalled in proper position
"Wet" tank leak-detection liquid depth within proper range
Electronic Leak- Leak-monitoring console is operational and has no active warnings
Detection Monitor or alarms
If pressurized piping has been tested in the last year, review the
Line Tightness results and verify that the test passed
Testing If suction piping has been tested within the last three years, review
the results and verify that the test passed
Below grade piping operates at less than atmospheric pressure
Under Pump Check Below grade piping operates at less than atmospheric pressure Below grade piping slopes continuously back to the tank
Below grade piping operates at less than atmospheric pressure

RP900 8.11 - Leak D	etection Continued	YES	NO	N/A
Tank Tightness	If a tank test has been conducted within the last five years, review			Х
Testing	the results and verify that the test passed			^
Continuous Soil-	Sensing device calibrated and tested			X
Vapor Monitoring	deribility device calibrated and tested			^
Continuous				
Groundwater	Sensing device tested			X
Monitoring				
RP900 8.12 - Corros		YES	NO	N/A
	Verify that CP testing of all metallic components in contact with soil			
Galvanic CP	or water has been conducted within the past three years and that			
	the test passed			
Impressed Current	Verify that CP testing has been conducted within the past three			l x
СР	years and test passed			
	No exposed wires			X
Tank Lining	Lining inspected as required and in good condition			X
RP900 8.13 - Miscell	aneous	YES	NO	N/A
Tank Pad &	Concrete or asphalt over or near tanks is level, no significant cracks			
Pavement	Control of deprical control of mean taline is noted, in eight			
Stage II Liquid- Collection Points	Cap in good condition, fits tightly, little or no liquid in bottom			X
Stage II Testing	Verify that Stage II testing has been conducted and test results are			X
	passing			
Site Diagram	Site diagram accurately reflects the site conditions			X
	uel Dispenser Inspection	YES	NO	N/A
Initial Dispenser	All dispenser components are clean and dry			X
Inspection	If fuel-dispenser sump is present, sump is dry	\/=0		X
RP900 8.15 - Fuel Di	•	YES	NO	N/A
	Junction boxes sealed, not corroded; seal-offs present; intrinsically			l x
	safe wiring in good condition			
All D:	Flexible connector not twisted, kinked, or bent beyond			X
All Dispensers	manufacturer's specifications			
	Piping in good condition			Х
	Stage II piping functional or else capped and sealed at elevation			X
D: Maria (lower than the fuel dispenser island			
Dispensers Without	Flex connectors and other metallic piping are not in contact with soil			X
Sumps	or water or are cathodically protected			
	Any water removed and disposed of properly			X
Dispensers With	Sump free of trash, debris, and used filters			X
Sumps	Sump is free of cracks, holes, bulges, or other defects			X
	Penetration fittings intact and secured			Х
	Piping interstitial space open to the sump			Х
Piping Interstitial	Piping interstitial space closed to the sump			Х
Space	Sensor present in the fuel-dispenser sump with closed double-			l x
	walled piping system			
Dispenser Sump	Sump sensor properly mounted at the bottom of the sump			X
Sensors	Electronic sensor tested and functional			X
Sensors	Mechanical float sensor free to move and properly adjusted			

Describe any Deficiencies Here:

APPENDIX B

EXAMPLE SPCC PERSONNEL TRAINING LOG

*Please see EHS electronic files for actual annual training and logs.

SPCC Plan Training Log


UConn Storrs Campus
Training Conducted By: EHS
Date:

Name (print)	Department

APPENDIX C

UCONN EMERGENCY SPILL PROCEDURAL FLOW DIAGRAM

Public Safety/EHS After-hours Communication Decision Tree



Environmental Health and Safety (EHS) operates 8:00 am to 4:00 pm Monday through Friday

For assistance during regular business hours Call 860-486-3613

EHS After-hour Contacts	Telephone#
Terri Dominguez Director	860-234-3514
Cheryl Radzvilowicz, Sanitarian	860-933-6108
Amy Courchesne, Radiation Safety Officer (RSO)	860-234-3515

EHS Environmental Programs 24/7 Contact	Telephone#
Paul Ferri Manager	860-573-7842



Emergency Spill Response Procedures

Emergency Spill Response Procedures

Examples

- Fuel, oil, or chemical spills onto the ground or into surface water, groundwater, storm drains, or sanitary sewers
- Leaking or reacting drums of known or unknown oils, chemicals, or hazardous wastes
- Leaking above and underground storage tanks
- Fires or explosions involving oils, PCBs, pesticides, chemicals, or hazardous wastes
- Accidents involving the transportation of oils, chemicals, or hazardous wastes



Employee Emergency Response Procedure

- 1. Relocate everyone in the immediate area to a safe location.
- Dial 911.
- **3.** Answer questions and follow the directions of the dispatcher.



Fire Department Emergency Response Procedure

The highest ranking member of the Fire Department will become the Incident Commander on-site. The Incident Commander will:

- 1. Assess the risk from the spill and take into account the:
 - Risk of fire/explosion,
 - Potential overexposure to airborne contaminants,
 - Potential for dangerous chemical reactions,
 - Contact hazards with corrosive and/or toxic chemicals, and
 - Threat to the environment.
- 2. Determine whether to clean-up the spill or contact a vendor below for assistance:

•	Triumvirate Environmental, Newington, CT	(800) 966-9282
•	Clean Harbors, Bristol, CT	(800) 645-8265
•	Environmental Services, Inc., South Windsor, CT	(860) 486-7745

- **3.** Report any spills or uncontrolled discharges of fuel, oil, petroleum or chemical liquids; solid, liquid or gaseous products; or hazardous wastes to:
 - CT Department of Energy and Environmental Protection (860) 424-3338

If the spill or uncontrolled discharge enters a waterway contact:

1.	National Response Center	(800) 424-8802
2.	CT Department of Energy and Environmental Protection	(860) 424-3338

4. Contact Environmental Health and Safety to remove and properly dispose of the waste (if necessary) at 860-486-3613 or ehs@uconn.edu.

APPENDIX D

UCONN SPILL CONTRACTOR CONTACT LIST





UConn Spill Contractor List

Triumvirate Environmental, Inc.

80 Fenn Road, Unit C Newington, CT 06111 Contact: Mariana Siqueira Phone: 508-272-2789

*UConn specific contract # UC-20-CP061919-1

DAS Contract #16PSX0197

Clean Harbors Environmental Services, Inc.

51 Broderick Road Bristol, CT 06010 Contact: David Pannuto Phone: 860-836-4533

Email: pannutod@cleanharbors.com

Tradebe Environmental Services, Inc.

234 Hobart Street Meriden, CT 06450

Contact: David Holmgreen Phone: 219-397-3951

Email: usa.bids@tradebe.com

DAS Contract #19PSX0249

ACV Environmental Services, Inc.

928 East Hazelwood Ave. Rahway NJ 07065 Contact: Jamie McIlvaine

Phone: 732-375-9988

Email: jmcilvaine@acvenviro.com

Environmental Services, Inc.

90 Brookfield St.

Contact: Bethany Callahan Phone: 860-528-9500

Cisco LLC

525 Ella Grasso Blvd. New Haven, CT 06519 Contact: Chris Dickman Phone: 203-752-2558 Email: cdickman@snet.net

Moran Environmental Recovery, LLC

20 Commerce Rd. Newtown, CT

Contact: Michael Barden Phone: 203-270-0095

Email: mbarden@moranenvironmental.com

South Windsor, CT 06074

Email: bids@e-s-i.com

Laydon Industries, LLC

51 Longhini Lane New haven, CT 06519 Contact: Kristy Laydon Phone: 203-562-7283

Email: kristy@laydonindustries.com

Manafort Brothers Incorporated

414 New Britain Ave. Plainville, CT 06062 Contact: Michelle Brandon Phone: 860-793-6415

Email: mbrandon@manafort.com

NRC EAST ENVIRONMENTAL SERVICES INC

89 Commerce Circle Durham, CT 06422 Contact: Angela Coe Phone: 508-966-6008 Email: acoe@nrcc.com

APPENDIX E

UCONN SPILL HISTORY LOG

SPILL HISTORY

UConn Storrs Campus

			Person Responsible	Date of Completion	
Date	Description of Spill	Corrective Action			Steps to Prevent Recurrence
8/3/2016	Leak from ruptured hydraulic line on Willimantic Waste truck, located at Rome Dining Hall loading dock. Amount - approx. 10 gallons. Flowing over blacktop, no storm drains affected. UCFD and Katie Milardo (OEP) responded.	Speedi Dry and absorbent pads used to absorb spill. Willimantic Waste personnel called to site applied additional Speedi Dry, cleaned up the area and removed the cleanup materials. DEEP notified (case # 4116).	Willimantic Waste	8/3/2016	N/A - accidental release by a vendor, no control by UConn
8/3/2016	During response to event on line above, UCFD discovered an additional, unrelated grease spill/runoff from the Rome Dining Hall loading dock dumpster as a result of normal dumping operations.	Triumvirate contracted to assist with the clean up.	UConn Dining	8/3/2016	Dining Supervisor, Steven Anthony notified and reminder of proper grease disposal.
10/20/2016	Motor vehicle accident in front of Public Safety Complex. Contents of vehicle radiator spilled. UCFD responded.	Speedi Dry applied and spill cleaned up. DEEP notified.	UCFD	10/20/2016	N/A - accidental release during MVA, no control by UConn
12/2/2016	Transmissions fluid spill from vehicle at Alumni House parking lot and spreading to rear partking lot behind College Square. Several gallons UCFD responded	Vehicle towed. Speedi Dry applied and spill cleaned up. DEEP notified.	UCFD	12/2/2016	N/A - accidental release by private motor vehicle, no control by Uconn
1/26/2017	Hydraulic fluid spill of approx. 25 gallons from USA Trucking waste removal truck located at Student Union loading dock. No waterways/storm drains/environmentally sensitive areas involved. UCFD responded.	UCFD notified DEEP and OEP. Speedi Dry applied to spill initially and cleanup crew from USA Trucking called in to respond and clean up the spill.	USA Trucking	1/26/2017	N/A - accidental release by a vendor, no control by UConn
4/18/2017	Puddles of fluid reported in Charter Oak parking lot which appeared to be transmission fluid leaked from a car no longer on scene. UCFD responded.	Puddles covered with Speedi Dry. DEEP notified.	UCFD	4/18/2017	N/A - presumed accidental release by private motor vehicle, no control by Uconn
4/19/2017	Hydraulic fluid spill (approx. 20 oz) at Pharmacy loading dock due to hydraulic line being pinched by loading dock lift. Spill contained to loading dock concrete area under lift. UCFD responded.	Hydraulic pump locked out/tagged out. Speedi Dry applied. DEEP notified of spill. Facilities notified for repair.	UCFD	4/19/2017	Facilities repaired the hydraulic line and no further action was taken.
9/2/2017	Oil puddle discovered in parking space at Hilltop #21 (residence). No waterways involved. UCFD responded.	Speedi Dry applied and spill cleaned up. DEEP notified.	UCFD	9/2/2017	N/A - presumed accidental release by private motor vehicle, no control by Uconn
3/27/2018	Two quart oil spill at Babbidge Library loading dock; unknown event/cause.	Spill was covered with Speedi Dry. DEEP notified.	UCFD	3/27/2018	None - event unknown
4/12/2018	Hydraulic oil spill at South Campus Dining Hall, approx. 1 quart spread over 2'x6' area. When UCFD arrived, spill had been covered in absorbent material.	UCFD notified DEEP. UCFD discussed issue with dining hall manager, who made the 911 call, and arranged for that person to contact CISCO to notify them that their truck had a possible leak.	CISCO	4/12/2018	N/A - accidental release by a vendor, no control by UConn

7/20/2018	Diesel fuel spill, < 5 gallons, driveway on east side of Engineering 2 Building. Spill came from a truck with a loose fuel cap. UCFD responded.	Driver had covered the spill with sand. DEEP and OEP notified.	UCFD	7/20/2018	N/A - accidental release by a vendor or contractor, no control by UConn
11/2/2018	Oil spill discovered west side of Central Warehouse near Transportation office, approximately 3 months old. UCFD responded. Observed an approximately 5' x 10' area of dead grass and soil with puddles of oil. Caller reported that a temporary boiler was placed there for approximately one year and removed from the location 3 months prior.	Absorbent pads applied to visible oil puddles. OEP and DEEP notified and responded. DEEP case number 2018-05805. Two drums of impacted soil were removed from the site by Triumvirate Environmental. DEEP was satisfied with this level of cleanup.	UConn - OEP	12/12/2018	For future placements of temporary boilers, we will take care to place over impervious surface and ensure spill response materials are close at hand.
11/29/2018	UCFD responded to report of fluid trail extending from Farmer Brown Lot to Motor Pool. Fluid was determined to be hydraulic oil leaking from a front end loader, driven to Motor Pool to address problem. The loader was left outside of Motor Pool prior to normal business hours, still leaking. UCFD notified DEEP and OEP (Paul Ferri).	Motor Pool staff applied Speedi Dry and performed cleanup at their location. The oil trail along the traveled roadway had previously been absorbed into road material and distributed by traffic. DEEP was notified of the incident and satisfied with report of less than 5 gallons of oil spread over a 1500 ft area with no waterways involved.	UCFD	11/29/2018	
2/7/2019	Hydraulic oil leak from compactor at Student Union when Willimantic Waste truck driver forgot to detach hydraulic lines from the compactor and pulled lines out of the wall. Five to seven gallons. UCFD responded and DEEP and UConn EH&S were notified.	On arrival, UCFD found spill that had been covered in Speedi Dry by the Willimantic Waste driver. The open lines had been clamped off with vice grips. Willi Waste driver wanted to collect oil-soaked Speedi Dry and load it onto his truck for transport back to the Willi Waste facility; EH&S approved the action. Another Willi Waste employee arrived to repair the broken hydraulic line.	Willimantic Waste	2/7/2019	N/A - accidental release by a vendor, no control by UConn
2/19/2019	Motor vehicle accident (car vs. light pole) at corner of Hillside Rd. and Alumni Drive. Approx 1 qt of oil spilled. UCFD responded.	Speedi Dry applied and left in place. DEEP notified and satisfied.	UCFD	10/20/2016	N/A - accidental release during MVA, no control by UConn
4/19/2019	Report from Dave Perko at Motor Pool that a bus had driven around campus with an oil leak, leaving a trail. The leak was noticed when the bus parked at Motor Pool.	Motor Pool staff cleaned up leaked oil at their location with Speedy Dri and stopped the oil leak. UCFD drove the approximately 2 mile bus route and noted only oil staining on the pavement with the exception of several bus stops and turn areas, where small puddles were treated with Speedy Dri. No waterways involved. DEEP notified and satisfied.	UCFD	4/19/2019	There is no more that needs to be done. Preventive maintenance is regularly performed on the buses and the driver was unaware of the leak at the time. It was identified as dealt with as soon as the bus returned to Motor Pool. UCFD performed due diligence in driving the route and treating any necessary areas.
5/31/2019	Hydraulic oil spill at Putnam Dining Hall; approximately 8 oz. UCFD responded. No waterways	Covered with Speedi Dry. DEEP notified.	UCFD	5/31/2019	
3/11/2020	Oil spill reported at intersection of LeDoyt Rd and Discovery Dr. One to two quarts of oil observed in roadway. UCFD responded.	Applied Speedi Dry to absorb oil in roadway. Leaking vehicle located in adjacent lot with no active leak noted. UCPD also responded and arranged for tow of vehicle. DEEP notified.	UCFD	3/11/2020	N/A - accidental release by private motor vehicle, no control by Uconn


7/22/2020	Hydraulic transmission fluid spill reported on Hillside Rd in front of Student Rec Center. Approx 5 gallon spill from a UConn bus. No waterways involved.	Contained and cleaned up by Motor Pool staff using available spill response materials. DEEP and OEP (Paul Ferri) notified.	UCFD	7/22/2020	None taken. Preventive maintenance performed regularly.
9/2/2020	Transformer oil leak near parking lot of Foundation Bldg.UCFD responded. Utility crews working pulled a line out of the transformer, causing it to leak oil. No waterways involved.	A large amound of Speedi Dry used to absorb oil as it leaked. This continued while transformer was denergized, grounded and made safe for cleanup crews to remove the remaining oil from the transformer. Triumvirate responded for cleanup. DEEP notified and satisfied. EHS-Env Programs (Paul Ferri) also notified and responded.	Contractor	9/2/2020	Reminder to read and adhere to UConn Contractor Safety Manual
9/22/2020	Hydraulic oil leak from Willimantic Waste garbage truck at Psychology Bldg loading dock area; estimated approximately 2 gallons. Spill onto driveway, no waterways involved.	Willimantic Waste Environmental Services responded to scene for cleanup before UCFD arrived. Speedi Dry and sand applied. Willimantic Waste to notify DEEP.	Willimantic Waste	9/22/2020	N/A - accidental release by a vendor, no control by UConn
9/24/2020	A tractor compacting corn silage on a standalone pile rolled over spilling crankcase oil and antifreeze onto the ground. No waterways involved	Incident not initially reported to EHS and 911 was not called to activate a UCFD response. Motor Pool provided Speedi Dry to absorb oil. Oil, antifreeze and glass-contaminated silage was collected and deposited in nearby trash dumpster. EHS was notified on 9/28/2020, reported the spill to DEEP, and attempted to trace the contaminated silage. It was determined that the dumpster had already been emptied by Willimantic Waste. EHS followed up with Willimantic Waste to determine the ultimate destination of the trash from that dumpster, American Ref-fuel in Preston, CT, where it was incinerated. This further information was provided to DEEP (satisfied).	UConn Farm Services	10/5/2020	Changes to wording of SPCC Plan to be sure appropriate personnel is captured in training requirements and refresher of proper procedures for those involved.
10/22/2020	Small diesel spill at fuel pumps at Motor Pool. Discovered by MP staff after it occurred. No vehicle on scene. No waterways involved.	Motor Pool staff applied Speedi Dry. UC advised to notify DEEP of 1 cup diesel spill.	Uconn Motor Pool	10/22/2020	Nothing further to address.
1/20/2021	UCFD responded to a report of sheen in various locations from spill of unknown fluid on roadways (no waterway involvement). Locations were Storrs Road, North Eagleville Road and C-Lot. No obvious cause found. No pooling. Fluid dissipated by traffic by the time of report.	1	UCFD	1/20/2021	No cause found so no action can be taken to prevent recurrence.

APPENDIX F

DISCHARGE NOTIFICATION FORMS

CONNECTICUT RELEASE REPORTING REGULATIONS – REPORTABLE QUANTITIES

Rev. 7/21/2022



^aExceptions – Allowed (regardless of exceedance or violation) by: = exceptions 1) State or federal law; = oil or petroleum 2) Judgement or order of the court; 3) Contained under a laboratory fume hood; = non-petroleum 4) Minor sheen from roadway, parking lot, driveway normal vehicle use; 5) Food products (if it does not pose a risk to human health or the environment); = always report 6) Domestic sewage less than 100 gallons; ^bCriteria for releases to containment, must be cleaned within 2 hours AND must NOT be: 1) more than 100lbs or 15gal.; 2) involve a UST or PCB; 3) create an emergency ^cUnless it is limited to drips from nozzle during dispensing; dUnless contained under a laboratory fume hood *risk includes actual or imminent releases per 22a-450-2(c)



STATE OF CONNECTICUT DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION

79 Elm Street Hartford, CT 06106-5127 http://dep.state.ct.us

Bureau of Waste Management Oil and Chemical Spill Response Division

REPORT OF PETROLEUM OR CHEMICAL PRODUCT DISCHARGE, SPILLAGE OR RELEASE

When did the incident occ	ur? Date// month/day/		:		
Where did the incident oc	our?				
Under whose control was				me of the incident?	
Name:					
Mailing & street address:					
				Telephone:	
Who is the owner of the p	roperty onto which th	e spill occurre	d?		
If this is a corporate prope				presents the owner?	
Corporate property □	Prope	erty owned joir	ıtly □		
Name:					
Town:	State:	Zip:	Tel	lephone:	
When was the incident ve	rbally reported to the	Department o	of Enviro	onmental Protection?	
Date// month/day/year					



STATE OF CONNECTICUT DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION

79 Elm Street Hartford, CT 06106-5127 http://dep.state.ct.us

Mailing & street address:			
			Telephone:
			discharged? Give an exact description of earcent concentrations, trade names, etc.
If the chemicals are Extreme and include the reportable q	ely Hazardous substance uantity (RQ). Please att	es or CERCLA h ach a Material S	nazardous substances they must be identified Safety Date Sheet (MSDS) for each chemical
	vater)? [NOTE: Connect		discharged to each environmental medium (atutes requires the reporting of any amount of
_			
Did any of the chemical(s) tr	avel beyond the properterty line.]	y line? [NOTE: N	Materials that enter the ground water are con



STATE OF CONNECTICUT DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION

79 Elm Street Hartford, CT 06106-5127 http://dep.state.ct.us

What actions are being	taken to preve	ent reoccurrenc	e of an incident	of this type? (Attach a	dditional sheets if nec
_	·			, ,	
_					
_					
Were there any injuries numbers and describe					uals, their addresses,
Name:					
Mailing & street addres	s:				
Town:					
What is the appropriate					
Triacio allo appropriate	aurioo rogaro	mig modiodi dil		у тог одросси таттай	



14.

1

STATE OF CONNECTICUT DEPARTMENT OF ENERGY AND ENVIRONMENTAL PROTECTION

79 Elm Street Hartford, CT 06106-5127 http://dep.state.ct.us

Was the incident completely cleaned actions and their duration?	up by the time this report was subm	nitted? If not, what are the anticipated ren
CERTIFICATION: I hereby affirm that	at the foregoing statement is true to	the best of my knowledge.
CERTIFICATION: I hereby affirm the	at the foregoing statement is true to	the best of my knowledge. Date

This form may be reproduced or computerized as long as it contains all of the information requested and is on an 8½ x 11 white paper, black type format. For serious incidents the questions may be answered in narrative format which must

Are there any known or anticipated health risks, acute or chronic, associated with the release of this chemical or medical

MAIL TO:

include the preparer's affidavit.

State of Connecticut
Department of Energy and Environmental Protection
Bureau of Waste Management
Oil and Chemical Spill Response Division
79 Elm Street
Hartford, CT 06106-5127

Telephone: Routine Calls (860) 424-3024

Emergency 24 hours (860) 424-3338

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY (USEPA) REGION 1

OIL SPILL REPORT FORM

REPORTING ADDRESS:

US EPA, Region 1 1 Congress St. Boston, MA 02114-2023 (888) 372-7341 (617) 918 1111

1.	Facility Name:
2.	Facility Owner:
3.	Facility Location:
4.	Facility Contact Name and Address:
5.	Date and Year of Initial Facility Operation:
6.	Maximum Storage Capacity:
7.	Normal Daily Throughput:
8.	Description of Facility (Include topographical maps indicating direction of flow.):
9.	Cause of Spill (Include failure analysis):
10.	Exact Identity of Oil Spilled:
11.	Exact Quantity Spilled:
12.	Corrective Actions, Countermeasures, Repairs, and/ or Equipment Replacements:
13.	Additional Measures Taken to Avoid Recurrence:
14.	Any Additional Information Requested by the EPA: